
5370 N Chestnut Ave M/S OF18 Fresno, CA 93740-8021 559.278.2066 FAX 559.278.6033 www.californiawater.org()



## IrriRich 4 inch SW valve



Test psi: 50.0 HL =  $0.000026312870 \text{ Q}^{-1.97390}$  R<sup>2</sup> = 1.000 CV = 210.1

Flow Rate (gpm)	Headloss (psi)	Estimate	Residual
49.6	0.06	0.06	-2.6 %
74.1	0.13	0.13	-0.7 %
97.9	0.22	0.22	1.7 %
126.2	0.37	0.37	-0.2 %
151.2	0.54	0.53	-2.3 %
177.4	0.72	0.72	0.5 %
200.7	0.92	0.92	0.3 %
224.5	1.12	1.15	2.7 %
244.9	1.35	1.37	1.2 %
275.4	1.73	1.72	-0.4 %
300.5	2.02	2.05	1.3 %
324.7	2.33	2.39	2.3 %
350.2	2.79	2.77	-0.7 %
376.5	3.22	3.20	-0.8 %
399.1	3.54	3.58	1.2 %
427.2	4.09	4.10	0.2 %
454.5	4.59	4.63	0.9 %
477.0	5.03	5.10	1.3 %
503.9	5.67	5.68	0.2 %
527.2	6.17	6.21	0.6 %
551.1	6.76	6.78	0.3 %
574.3	7.31	7.35	0.6 %
602.6	8.13	8.08	-0.6 %
625.1	8.80	8.69	-1.2 %
652.2	9.62	9.45	-1.8 %

Flow Rate (gpm)	Headloss (psi)	Estimate	Residual
676.2	10.37	10.15	<b>-</b> 2.2 %
702.4	11.19	10.94	-2.3 %

Test Date: 1/19/17