

CLOUD TECH SMART SOLUTIONS

Electrical Installation Documentation

System Documentation & Schematics

Project ID:	STR-001
Location:	Struga, North Macedonia
Last Updated:	16 June 2026
Status:	Active / Verified

This document is restricted to property owners and authorized personnel only.

SECTION 1: GENERAL SPECIFICATIONS

1.1 Overview

This documentation specifies the electrical wiring standards and installation configurations engineered for the STR-001 project in Struga. The system is designed to operate on a 3-phase supply and integrates directly with a smart home management system.

1.2 Standards & Safety Compliance

All installation procedures, wire dimensions, and safety layouts comply with **IEC 60364** regulations. Residual Current Devices (RCD) are rated at 30mA for shock hazard prevention in all wet rooms and general utility socket circuits.

1.3 Cable Wiring Details

The standard wiring utilizes halogen-free copper cables to guarantee maximum fire safety standards:

Circuit Type	Cable Specification	Protection
Lighting Circuit	NYM-J 3x1.5 mm ² HF	10A MCB (B-Curve)
General Sockets	NYM-J 3x2.5 mm ² HF	16A MCB (B-Curve) + RCD
Heavy Appliances	NYM-J 3x4.0 mm ² HF	20A MCB (C-Curve)
Smart Bus Cabling	EIB/KNX 2x2x0.8 mm ² Green	KNX PSU Protected