## **Futek Calibration Certificate**

4220011

**Certificate Number...... 0404220011** 

Sensor

 Model Number..... LCB200
 Stock Number..... LCB10002

 ID Number....... 61631
 Capacity............. 3000 lb

Model: LCB200 - 3000 lb (L1652) Tension & Compression Load Cell Ver.1 - Standard P/N: LCB10002 (FP10080) 17-4 PH S.S. 3/8-24 Thread Standard

## REFERENCE CALIBRATION EQUIPMENT

## **Calibration House:**

**Futek** 

10 Thomas, Irvine, CA92618

949-465-0900

Reference Load Cell and Digital Indicator:

Model: 12000LBF Cap.: 5000 ID No: 062825

**Display:** Newport ID No: 125765

**ID No:** 125765

System Error does not exceed 0.01% for transfer standard

**Reference NIST Number:** SJT.01/107659 System Cal. Date: 10/5/2006

12:00:00 AM **Next Cal. Date by:** 10/5/2007 12:00:00 AM

**Digital Indicator:** 

**HP Model Number:** Agilent 34401A **S/N:** US36135067

**Cal. Date:** 1/13/2004 12:00:00 AM **Next Cal. Date by:** 1/13/2005 12:00:00

AM

**Uncertainty Value: 0.005%** 

## Calibration Data

**Test Temp ......** 74.00 °F (23.33 °C) **Relative Humidity .....** 22.00 %

direction: Tension

**Rated Output ...** 1.0141 (NaN) **ZeroReturn ....** -0.033 % of R.O.

**Linearity ......** -0.208 % of R.O.

Data Points					
Load	Output	Non-Lin Error (%)	Hysteresis (%)		
<u>channel: 1</u>					
(lb)	(mV/V)				
direction: Tension					
0.0	0.0000	0.000			
600.0	0.2011	-0.166			
1200.0	0.4037	-0.192			
1800.0	0.6063	-0.208			
2400.0	0.8097	-0.151			
3000.0	1.0141	0.000			

0.0	-0.0003	NaN			
ASTM Uncertainty: 0.003661075 (mV/V)					
* Error and Uncertainty were calculated using Straight Line Method in accordance with ASTM E74 with $K = 2$ Best Fit Equation: $Y = A0 + A1X + A2X^2 + A3X^3$					
	Best Fit Equation: $Y = A$	$0 + A1X + A2X^2 + A3X^3$			
	A0 = -6.44795e-005	A2 = 1.03066e-009			
	A1 = 3.35067e-004	A3 = -1.49184e-014			
	Best Fit Equation: $X = B0 + B1Y + B2Y^2 + B3Y^3$				
	B0 = 1.93636e-001	B2 = -2.72841e + 001			
	B1 = 2.98445e + 003	B3 = 1.53852e + 000			
	Y = Output	X = Load			
Best Fit Equation Was Calculated using the Method of Least Squares.					

	Shunt Calibration				
Shunt Value (K ohm)	Output (mV/V)	Load			
	channel: 1				
		(lb)			
	direction: Tension				
301	.8322	2461.914			
Shunt Cal is placed across (-E)(-S)					

Futek Advanced Sensor Technology Inc. 10 Thomas Irvine CA. 92618 Tel: 1(800)23-FUTEK Fax: (949)465-0905