



Water Accessibility - Our Priority!

REPUBLIC OF THE PHILIPPINES
CAGAYAN DE ORO CITY WATER DISTRICT
Corrales Avenue, Cagayan de Oro City



2 September 2026

HON. ROLANDO A. UY
City Mayor
Cagayan de Oro City

Attention:
COUNCILOR ENRICO D. SALCEDO
Chairman, Committee on Public Utilities

Republic of the Philippines
OFFICE OF THE CITY COUNCIL
City of Cagayan de Oro

RECEIVED

Date: SEP 04 2026
Time: 11:04
By: [Signature]
Local Legislative Staff Officer I
JUSTIN KYL E. P. ASNE

Dear Mayor Uy:

This refers to the construction of a deepwell by CDO Polymedic Medical Center and Hanabana, Inc. near Cagayan de Oro City Water District (COWD) Production Well No. 10A, located in Calaanan, Barangay Canitoan, Cagayan de Oro City.

Based on the District's field verification, the drilling has already been completed to a depth of approximately ninety (90) meters, and a pump has been installed in the newly constructed well. The well is situated approximately ten (10) meters from COWD Production Well No. 10A. As of this writing, no Water Permit issued by the National Water Resources Board (NWRB) has been presented or made readily available to the District for verification.

Section 43(l) of the Implementing Rules and Regulations of Presidential Decree No. 1067, otherwise known as the *Water Code of the Philippines*, provides the following minimum spacing requirements:

RATE OF WITHDRAWAL IN LITERS PER SECOND	MINIMUM DISTANCE BETWEEN WELLS IN METERS
2 – 10	200
More than 10 – 20	400
More than 20 – 40	600
More than 40	1000

Considering that the newly constructed well has a depth of approximately ninety (90) meters and is located only approximately ten (10) meters from COWD Production Well No. 10A. The District has serious concerns regarding its compliance with the applicable well spacing and Water Permit requirements. Its operation may cause well interference, reduced well yield, and excessive groundwater drawdown, which may adversely affect the continued operation and the sustainability of the groundwater resource in the area.

The District previously brought the matter to the attention of Barangay Canitoan through its letter dated 10 July 2026. Despite this, the drilling was completed and a pump was subsequently installed.

Relative to this, the District humbly requests the assistance of your good office, through the Committee on Public Utilities in calling CDO Polymedic Medical Center and Hanabana, Inc. to a hearing. The hearing will provide an opportunity for the concerned parties to clarify the

"WATER ACCESSIBILITY – OUR PRIORITY!"


TEL. NOS. 72-62-48, 72-83-59; 856-4509, 856-4373; TEL./FAX 72-27-05

circumstances surrounding the construction of the deepwell and to present the applicable water permit, and other relevant documents.

Representatives from COWD are willing to attend the hearing and present the District's field findings and technical concerns. Hence, you may communicate Engr. Euljun Salarda thru the following email and contact number: euljunsalarda@gmail.com and/or +63 917 571 0117. The participation of representatives from Barangay Canitoan and the appropriate regulatory authorities may also be requested to ensure a comprehensive discussion of the matter.

We trust in your prompt attention and assistance in protecting the City's groundwater resources and ensuring compliance with existing water laws and regulations.

Very truly yours,


EDNA S. NAJEAL
General Manager

Copy Furnished:

*National Water Resources Board
Department of Environment and Natural Resources – Region X
Barangay Canitoan
CDO Polymedic Center
Hanabana, Inc.*

"WATER ACCESSIBILITY – OUR PRIORITY!"

TEL. NOS. 72-62-48, 72-83-59; 856-4509, 856-4373; TEL./FAX 72-27-05