

CML INTERNATIONAL

O&M REVIEW COMMENT DETAILS



Contractor	CML International	Revision	A
Module	1.0 Mechanical Services	Date Uploaded	13/05/2014
Package	1.2 LTHW & Chilled Water Pumps	Uploaded By	callum.king@cmlgroup.ae
Manual Title	LTHW & Chilled Water Pumps O&M Manual	Current Status	Accepted with Comments

SI #	Section #	Page #	Comment	Comment By	Date	CML Response
1	2.3.1	24	More information on UPS conditioned paralleled output and totalizer panel functioning.	Jose Joseph	18/05/14	We will review the information and add to the description in the next few days. We will inform you once the document has been updated.
2	3.5.7	39	Load shedding should be clearly defined.	Sooraj Padmasan	24/05/14	Load shedding is supplied as part of the new sequence of operation.
3	4.2.2	50	Add PPM	Sooraj Padmasan	24/05/14	Noted
4	5.8.6	68	Add equipment schedule	Sooraj Padmasan	24/05/14	Noted