CO 370 Winter 2026: Group Project Formulation

Sa'ad Farooq[*] Maxwell Fang[†] Buck Chen[‡] Timothy Zheng[§]

February 22, 2026

1 Topic

Optimal Power Flow (Direct Current Approximation)

Abstract

The North American electricity grid operates as a market on a nodal network of energy "settlement points" connected by capacity-constrained transmission lines. Participants are generators (gens) and loads, which buy and sell power in real time through an auction process.

The role of the grid operator (RTO) is to ensure economic dispatch of power through a clearing process that tells gens and loads how much power they are allowed (or obligated) to deposit or withdraw from the grid at each settlement point at any given time. Generation and usage capacity is pre-determined 24 hours ahead in the Day-Ahead (DA) market and then additional capacity can be purchased or sold in the Real-time market.

Since electricity cannot be easily stored, it is instantly delivered across power lines. All market participants are obligated to generate or consume their scheduled amount of electricity to maintain grid stability. Participants must buy or sell in the Real-time market if they are unable to meet their obligations to make their positions whole. Due to the limit in transmission capacity across power lines, power prices tend to be different in different geographical regions, and can be deterministically calculated through LP.

We propose to write an LP formulation that emulates (approximately) the one run by the grid operator. Our group has access to grid data through a connection from a member's previous co-op. We believe this project is highly relevant given the rapid rise of electricity demand from data centers and manufacturing, and the rise of extreme weather that makes key grid elements more sensitive to catastrophic failures that can result in blackouts.

Optimal power flow has a common approximation assuming DC power flow (the grid is actually run on AC), which allows us to formulate the problem as an LP in the DC model. We hope to implement advanced concepts in OR such as sensitivity analysis, graphs/network flow, and large-scale optimization.

The goal of this project is to simulate an end-to-end market clearing process for a mock electric grid, deriving electricity prices across the grid, and as an extension, clearing one auction round in the electricity derivatives market for a product called Financial Transmission Rights

[*] s4farooq@uwaterloo.ca
[†] m34fang@uwaterloo.ca
[‡] b39chen@uwaterloo.ca
[§] t54zheng@uwaterloo.ca

(FTR). We believe this application to be especially enriching to those of us exploring a career in electricity trading, as well as serving as insight into the pricing mechanics of this market in the age of surging power prices due to the rising adoption of datacenters and Artificial Intelligence.

Contents

1 Topic **1**

2 Problem Scope and Specification **4**

3 Data Sources **4**

4 Constraints **4**

5 Contingencies and Monitored Lines **5**

6 Shift Factor Calculation **5**

7 Day-Ahead Clearing process **6**

8 Shadow Price Calculation **6**

9 Locational Marginal Price Calculation **7**

10 FTR Contracts **7**

11 FTR Clearance **8**

12 DA Clearance LP **8**

13 FTR Clearance LP **8**

14 Results **9**

15 IP Formulation for DA / FTR (first extension) **9**

16 Extensions **9**

A Appendix: Data Previews **10**

A.1 `branches.csv` preview 10

A.2 `buses.csv` preview 10

A.3 `ptdf.csv` preview 10

B References **12**

2 Problem Scope and Specification

In this project, we focus first on the Day-Ahead (DA) market clearing process. The DA market clearing process involves the grid operator collecting bids from generators (to sell) and loads (to buy) electricity from pre-specified settlement points (pricing nodes) in the power grid for the next 24 hours. In this market, virtual traders also purchase power allocation to be sold later in the real-time market, which settles every 5 minutes in real-time. We decided that this application is out of scope for this assignment and instead we only focus on DA settlement for power and financial derivatives.

It is the role of the RTO to clear this auction, ensuring grid stability while minimizing economic cost. Our goal is to produce the unit allocations (in MW) to each participant and clearing prices (Locational Marginal Prices) of electricity at every node, giving us transparency into the pricing mechanics of this market.

3 Data Sources

Most real-world grid models are confidential, kept behind non-disclosure agreements due to their sensitivity in relation to national security.[1] Therefore for the purpose of this assignment we use the IEEE N-bus systems[2] which serve as reference examples to real-world grids as they exist today.

Moreover, as these network models are provided as raw topological specifications, we use **PowerWorld**, a grid analysis tool to derive shift factors which we use for this project. This calculation is outside the scope of this course, as it does not use LP methods, and is a necessary prerequisite.

We will also be synthesising participant bids and perturbing the grid for exploratory purposes. With this, we have all the necessary inputs to solve our problems.

4 Constraints

The power grid is inherently limited by the amount of electricity that can pass through a transmission line. For the purpose of the project, we will only consider constraints as thermal limits to power lines which effectively limit their capacity.

It is the responsibility of the RTO, through the DA clearing process, to ensure the allocations given to the generators and the loads do not overload any transmission line across the grid.

Constraints are defined in `branches.csv`; see the appendix table preview here: `branches.csv` preview.

[1] "Electronic copies of the SPP transmission map are currently available to those that provide an Non-Disclosure Agreement (NDA) and appropriate business justification.", Southwest Power Pool

[2] `https://github.com/ITI/models/tree/master/electric-grid/physical/reference`

5 Contingencies and Monitored Lines

The RTO also has the additional responsibility to ensure there is no overload across any transmission line in the event an unplanned outage occurs. This is a somewhat common occurrence, as transmission lines can go out for reasons such as wear and tear, extreme weather, trees falling on lines, or circuit breakers being tripped due to line overload. Grid overload can result in temporary power outages, and in severe cases, cascading failure and large-scale blackouts as any significant deviation from the expected generation and load balance can throw off the grid's frequency, damage equipment, and incur high costs to re-sync and restart generators.

Contingencies are always defined with reference to a monitored line. That is, for each contingency and monitored line pair, we open the contingency (so flow across that contingency is 0), and then figure out what the power flow across the rest network will be under the optimized unit allocation. The flow must not exceed the flow limit (constraint) on the monitored line.

The solution employed by RTOs is to evaluate this set of all possible contingencies concurrently, and ensure any cleared auction results in a grid that is stable even if any of the contingencies are activated.

TODO: We will need to create every pair for each line, and collect the respective shift factor for that contingency. Requires Python script to edit the file generated by PowerWorld.

6 Shift Factor Calculation

Power Transfer Distribution Factors, a.k.a Shift Factors (sf) are coefficients describing what fraction of electricity will flow through a certain branch (which could comprise multiple lines) if 1 additional MW is injected into the source node and 1 additional MW is withdrawn from the sink node.

In PowerWorld, shift factors are calculated with reference to a fixed slack bus k and are defined per node.

That is, in the PowerWorld data, shift factors are defined as $\mathrm{sf}_{i \to k}$.

Then we can derive for any two nodes a, b in the network $\mathrm{sf}_{a \to b} = \mathrm{sf}_{a \to k} - \mathrm{sf}_{b \to k}$

DONE: Shift factor matrix for all branches.

TODO: extract shift factor table like ptdf.csv but for contingencies.

7 Day-Ahead Clearing process

Ignoring the objective, currently we try to optimize under X, a matrix with the unit allocations for each participant on each node.

The total power flowing on a directed branch (path) with source node i and sink node j is

$$\text{flow}_{i\to j} = \sum_{s\in\mathcal{N}} \left(\text{sf}^{(s)}_{i\to j}\right) \text{inj}_s,$$

where $\mathcal{N}$ is the set of nodes, $\text{sf}^{(s)}_{i\to j}$ denotes the shift factor on branch $i \to j$ with reference node s, and inj_s is the net injection at node s.

Note that negative flow just means the power goes in the opposite direction. That is, the flow from b to a is the same as the negative of the flow from a to b. However to save on computation we just need to check if the absolute value is within the node constraint, meaning we need to double each constraint when we implement.

TODO: We need to do this formulation given the branch matrix and the SF matrix.

Next, we need to formulate the contingencies. Like the calculation above, we have a matrix of shift factors, but this time each column is a monitored line given some contingency being open in the constraint definition list, while the previous matrix had columns equal to each branch.

TODO: We need to add these formulations too, ensuring the absolute flow is less than the flow limit.

TODO: Economic Dispatch (see Iowa State Paper Pp. 10 linked below), NB that generators will always get their unit allocation after contingency analysis (the contingency constraints).

8 Shadow Price Calculation

TODO: Extract the dual variables needed for LMP computation from the DA-clearing LP.

- Let λ denote the dual variable associated with the (system-wide) power-balance constraint.
- Let μ_l denote the dual variable (shadow price) associated with the transmission constraint for line l (binding only when the line is congested).

After solving the LP, we will record λ and the vector $\{\mu_l\}_{l\in\text{Lines}}$ and use them in

$$\text{LMP}_i = \lambda + \sum_{l\in\text{Lines}} \left(\text{PTDF}_{l,i}\,\mu_l\right).$$

9 Locational Marginal Price Calculation

TODO: Use dual variables to calculate LMP.

For our project, the locational marginal price (LMP) at bus i is the DC approximation:

$$\mathrm{LMP}_i = \lambda + \sum_{l \in \mathrm{Lines}} \left(\mathrm{PTDF}_{l,i} \, \mu_l \right).$$

Where:

- λ is the dual variable of the system power-balance constraint.
- μ_l is the dual variable (shadow price) of the transmission line constraint for line l.
- $\mathrm{PTDF}_{l,i}$ is the power transfer distribution factor (shift factor) for line l and bus i.

10 FTR Contracts

Financial Transmission Rights (FTR) are derivative contracts[3] where the underlying is the congestion between any two nodes (a, b) in a power grid. Their payout is calculated as

$$\text{Payout} = (LMP_{Sink} - LMP_{Source}) \times \text{Quantity (MW)}$$

where the $(LMP_{Sink} - LMP_{Source})$ is known as congestion.

Congestion is only non-zero in the case where constraints in the DA clearance are binding (the inequality replaced with equality).

The trading of these contracts does not affect the underlying power market, however it is a common tool used by market participants to hedge their operations against congestion costs. If the difference is positive, the contract holder is paid by the RTO. If the difference is negative, the contract holder is obligated to pay the RTO the difference. For example, a utility provider may purchase FTRs to guarantee their customers a fixed price for electricity, which is preferred to power prices that fluctuate daily and are unpredictable. Power plants may also purchase these contracts to guarantee a sale price to lock in their profit margins.

[3] `https://en.wikipedia.org/wiki/Derivative_(finance)`

11 FTR Clearance

The clearing process is formally defined in the references in the Iowa State paper (Ma, et al.) As a summary, the FTR clearing process is mostly similar to the DA clearing process however the unit allocation is not bounded by the generation/demand capacity, but instead the amount of bids and offers, ultimately capped by the transmission capacity of a branch. For example, on a line going from node $A \to B$ with capacity 100MW, up to 150MW of capacity can be cleared for that line, given that for the 50MW of excess capacity sold, there are at least 50MW cleared for $B \to A$.

Rationale (to why net FTR volume over a line is capped by the transmission limit of the line): Note that the shadow price of a line is going to be 0 if it is not binding (the amount of electricity being transmitted is less than the limit). The shadow price is only going to be non-zero if the line is binding, and the capacity is reached.

Since the RTO only needs to pay out (or receive payment) from the derivative in the case where the congestion is non-zero, and congestion on a line is a linear function of the shadow price on the line (**TODO:** proof needed), the RTO only wants to sell up to the capacity of the line to ensure they can collect the necessary congestion rent from the difference from the DA market.

Why is congestion rent positive? Generators sometimes sell at a lower price at their pricing node, but electricity purchased at another node (suppose this node has no generation) will be more expensive due to demand at a supply-constrained node; then the buyers pay a higher LMP while the seller only receives the cheaper node's LMP. The "profit" generated by the RTO goes straight into paying FTRs.

TODO: Need to come up with all constraints, and implement SFT - simultaneous feasibility test

Potential extensions: Add already cleared capacity from previous action rounds, bidding on node pairs that are non-adjacent.

12 DA Clearance LP

TODO: Formulate LP and then implement in Gurobi. Run all intermediate steps and produce output.

13 FTR Clearance LP

TODO: Formulate LP and then implement in Gurobi. Run all intermediate steps and produce output.

14 Results

TODO: Collect and Interpret Results

15 IP Formulation for DA / FTR (first extension)

TODO: Both DA and FTR markets require users to bid on a curve, giving (pi, qi) price, quantity pairs. We find an optimal solution such that the result is an integer multiple of 0.1MW (the base unit).

16 Extensions

1. MIP for unit allocation given that gens have startup cost, cost-curves
2. Predictive analysis (possible worst states of the grid -> we want to guarantee grid stability.) Which lines can cause the greatest price impact if they suddenly go out for an unexplained reason?

A Appendix: Data Previews

Heads of each csv in the workspace.

A.1 `branches.csv` preview

Summary: Branch definitions and parameters. Only Limit A applies for now.

ID	From #	To #	Ckt	Status	Type	Xfrmr	R	X	B	Limit A
1	1	2	1	Closed	Line	NO	0.00070	0.00123	0.00065	175.0
2	1	5	1	Closed	Line	NO	0.02243	0.08490	0.02440	175.0
3	2	4	1	Closed	Line	NO	0.03361	0.12730	0.03660	175.0
4	2	6	1	Closed	Line	NO	0.05064	0.19201	0.05570	175.0
5	3	1	1	Closed	Line	NO	0.05419	0.21114	0.06130	175.0
6	3	9	1	Closed	Line	NO	0.03148	0.11921	0.03430	175.0
7	4	9	1	Closed	Line	NO	0.02692	0.10779	0.02790	175.0
8	5	10	1	Closed	Transformer	YES	0.02334	0.08837	0.02540	175.0
9	7	8	1	Closed	Line	NO	0.01614	0.06103	0.01790	175.0
10	8	9	1	Closed	Line	NO	0.04234	0.16482	0.04780	175.0

A.2 `buses.csv` preview

Summary: Bus-level voltage, angle, generation, and load data.

Bus #	Nom kV	PU Volt	Angle (deg)	Gen (MW)	Load (MW)
1	138.00	1.00000	0.00	35.85	0.00
2	138.00	0.99783	0.01	67.00	97.00
3	138.00	0.86395	10.75	0.00	90.00
4	138.00	0.88721	-0.42	0.00	74.00
5	138.00	0.92693	-0.22	0.00	71.00
6	138.00	0.90837	0.39	0.00	68.00
7	138.00	0.79668	-0.58	64.00	62.00
8	230.00	0.80581	-0.87	0.00	85.00
9	138.00	0.83528	4.98	0.00	175.00
10	138.00	0.88216	3.72	0.00	100.00

A.3 `ptdf.csv` preview

Summary: PTDF/shift-factor matrix (rows: buses; columns: branches). Below is a small subset of columns.

Bus #	ETLR	WTLR	1 to 2	3 to 1	1 to 5
1	0.0000	0.0000	0.0000	0.0000	0.0000
2	-0.9962	-1.4054	-0.9946	0.0021	-0.0033
3	1.1629	1.0685	-0.3619	0.4416	-0.1965
4	-1.7811	-1.6472	-0.7309	0.1304	-0.1387
5	-1.3303	-1.0981	-0.2290	0.0790	-0.6920
6	-1.7217	-1.9384	-0.5453	0.1377	-0.3170
7	-0.6366	-0.9519	-0.4875	0.2002	-0.3124
8	-1.6366	-1.0722	-0.4875	0.2002	-0.3124
9	-0.5991	-0.5184	-0.5076	0.2391	-0.2533

Bus #	ETLR	WTLR	1 to 2	3 to 1	1 to 5
10	-0.6740	-0.7555	-0.4673	0.1612	-0.3714

B References

Sun, Junjie, and Leigh Tesfatsion. "DC Optimal Power Flow Formulation and Solution Using QuadProgJ." *ISU Economics Working Paper No. 06014*, revised 1 Mar. 2010, Iowa State University. https://faculty.sites.iastate.edu/tesfatsi/archive/tesfatsi/DC-OPF.JSLT.pdf. Accessed 5 Feb. 2026.

ITI. "models/electric-grid/physical/reference at master · ITI/models." *GitHub*. https://github.com/ITI/models/tree/master/electric-grid/physical/reference. Accessed 5 Feb. 2026.

Southwest Power Pool. "SPP Maps Frequently Asked Questions." *SPP*. https://www.spp.org/engineering/modeling/spp-maps-frequently-asked-questions/. Accessed 5 Feb. 2026.

Ma, Xingwang, David I. Sun, and Andy Ott. "Implementation of the PJM Financial Transmission Rights Auction Market System." *IEEE Power Engineering Society Summer Meeting*, 2002. https://home.engineering.iastate.edu/~jdm/OldInfo/ArevaPJM2002.pdf. Accessed 5 Feb. 2026.