



May 21, 2025

Attention: Gabriel Winebarger
Project: FHA Foundation Inspection for Manufactured Home
110 Amber Ln.
Statesville, NC
Project# 25-196

This is to advise that Darden Engineering inspected the foundation at the above referenced address. The foundation is adequate for supporting the structure and resisting wind loading as required by the NC State Building Code and as required by FHA and HUD. The foundation satisfies the prescriptive requirements of HUD Handbook No. HUD-4930.3 and HUD-007487 revised September 1996 Permanent Foundation Guide for Manufactured Housing.

The foundation has footings suitable for the soil, climate, and geological conditions of the site to support the size and weight of the existing manufactured home. The foundation for the manufactured home meets the federal, state, and local laws, rules, and regulations. The wheels, axles, and towing hitches have been removed.

From our observation the house doesn't appear to have been moved from its original location. The front and rear porches have been repaired so they do not directly affect the structural integrity of the house framing and foundation.

Please advise if additional information is required.

Sincerely, John C. Darden III PE



Sincerely,
John C. Darden III PE
Darden Engineering Services, PLLC
Firm License #P-1663