

Analytical Results



Wastewater Solutions

4919 E. Maiden Rd
Maiden, NC 28650

Receive Date: 05/23/2025
Reported: 05/27/2025
For: 1135 Brook Path Trl., Denver
Comments: Acceptable limits for drinking water are:

Total Coliform = Absent, E.Coli = Absent, Lead <0.015 mg/L,
Nitrate <10.0 mg/L, Nitrite <1.0 mg/L

Sample Number	Parameter	Sample ID	Result	Unit	Method	Analyzed	Analyst
250523-09-01	E. Coli	Dist. Tap	Absent		9223B	05/23/2025	ZH
250523-09-01	Total Coliforms	Dist. Tap	Absent		9223B	05/23/2025	ZH

Respectfully submitted,

Melissa Myers
NC Cert #440,
NCDW Cert #37755,
EPA #NC00909



Statesville Analytical, Inc.

122 Court Street; PO Box 228; Statesville, NC 28687

Phone (704) 872-4697, www.sa-nc.com

Client Name:(usually buyer)_____

Address (where sample taken) 1135 Brook Path Trl., Denver.

Location of Sample Taken Dist. tap (kitchen, bath, outside, etc.)

Sampling Time 10 : 35 A M Sampling Date 5 / 23 / 25

Person collecting sample Gustavo

Parameters requested for analysis: *Please check tests needed:*

☒ Total Coliform Bacteria ☐ Lead ☐ Nitrate ☐ Nitrite

Other _____

Mail Results to: wastewater solution

Phone: _____ Email: _____

LABORATORY ID #37755

CONTAMINANT	METHOD CODE	RESULTS		INVALID CODE
		PRESENT ^{1,2}	ABSENT	
Total Coliform	9223B		✓	
Fecal/E. coli	9223B		✓	

	DATE:	TIME:
ANALYSES BEGUN:	<u>05/23/25</u> (MM/DD/YY)	<u>14:40.</u> <u>P</u> M (Specify AM or PM)
ANALYSES COMPLETED:	<u>05/24/25</u> (MM/DD/YY)	<u>09:50.</u> <u>A</u> M (Specify AM or PM)

Laboratory Log #: 250523-09-01 Certified By: om

Comments: _____

