

4e kw 2016 Waternet

Locatie: Leiduin
Naam: Rein water

Omschrijving	Eenheid	gemiddelde	Norm
Aluminium	μg/l	1	< 200
Calcium	mg/l	41	
Chloride	mg/l	69	< 150
EGV (elek. geleid.verm. 20°C)	mS/m	52.9	
Waterstofcarbonaat	mg/l	179	> 60
Totale hardheid	mmol/l	1.39	>1
Totale hardheid	°Duits	7.8	
Magnesium	mg/l	9	
Natrium	mg/l	66	< 150
Ammonium	mg/l NH4	< 0.02	< 0.20
Nitraat	mg/l NO3	2.57	< 50
pH berekend	рН	8.1	7.0 <ph<9.5< td=""></ph<9.5<>
Verzadigingsindex S.I. berekend	рН	0.26	> -0.2
Sulfaat	mg/l	42	< 150
Temperatuur	°C	11.3	< 25
Coli 37°C	kve/100 ml	0	0
Legionella	kve/l	<100	< 100