

2e kw 2016 Waternet

Locatie: Leiduin
Naam: Rein water

Omschrijving	Eenheid	gemiddelde	Norm
Aluminium	μg/l	2	< 200
Calcium	mg/l	39	
Chloride	mg/l	76	< 150
EGV (elek. geleid.verm. 20°C)	mS/m	53.8	
Waterstofcarbonaat	mg/l	161	> 60
Totale hardheid	mmol/l	1.37	>1
Totale hardheid	°Duits	7.7	
Magnesium	mg/l	9	
Natrium	mg/l	67	< 150
Ammonium	mg/l NH4	<0.02	< 0.20
Nitraat	mg/I NO3	4.65	< 50
pH berekend	pН	8.1	7.0 <ph<9.5< td=""></ph<9.5<>
Verzadigingsindex S.I. berekend	рН	0.27	> -0.2
Sulfaat	mg/l	46	< 150
Temperatuur	°C	14.5	< 25
Coli 37°C	kve/100 ml	0	0
Legionella	kve/l	<100	< 100