

TAMLITE LIGHTING

LUMINAIRE SCHEDULE

VISION
LIGHTING CONTROLS



Tamlite Lighting – Free Lighting Design Service Terms and Conditions

Tamlite Lighting offers a complimentary lighting design service to assist with preliminary project planning. This service is provided free of charge and without obligation and is intended strictly for guidance purposes only.

Given that actual site conditions may differ from those provided at the design stage, it is the client's sole responsibility to ensure that the proposed design is suitable, accurate, and compliant with all applicable requirements prior to acceptance or installation. Tamlite Lighting does not accept liability for any decisions made based on this design without independent verification.

Where luminaires have been proposed as alternatives, these are cost-effective Tamlite options and not necessarily direct equivalents. Performance, specification, or aesthetic differences may therefore apply. It remains the purchaser's responsibility to obtain formal approval from the project consultant, contractor, or end client before proceeding.

Standard Design Assumptions

Unless we are advised otherwise in writing, the design is based on the following assumptions:

An open-plan space with no obstructions above the working plane.

Lighting levels based on BS EN 12464-1:2021 – Light and Lighting. Lighting of Workplaces – Indoor Workplaces. UGR and luminance data can be provided upon request. In some cases, a separate UGR assessment may be required, even if luminance appears compliant.

For outdoor lighting schemes, lighting levels are based on BS EN 12464-2:2021 – Light and Lighting. Lighting for Workplaces – Outdoor Workplaces.

Emergency lighting layouts are indicative only and based on BS 5266-1:2016. Final layouts must be verified by the client and approved by the building owner or relevant authority (e.g. fire officer).

Escape routes, where shown, are designed to 1 lux, open areas to 0.5 lux. Additional fittings may be necessary depending on site specifics.

The design assumes compliance with Part L2 of the Building Regulations. Where required, appropriate fire protection measures (e.g. fire hoods) must be confirmed by the installer or specifier. Please contact us for support or a quotation.

Product Suitability and Performance

All luminaire choices and layouts are subject to the approval of the end user or client. Calculations are based on published rated lumen outputs, which may vary depending on on-site ambient conditions.

The following values have been used in the absence of project-specific data:

Maintenance factor: 0.80

Reflectance values:

Office-type interior: 70 / 50 / 20

Warehouse-type interior: 50 / 30 / 20

Ambient temperature: 25°C

If any aspect of the proposed scheme or product selection is deemed unsuitable for the application, please contact us to discuss a revised design prior to placing an order. Quantities and layouts should be reviewed and confirmed before installation. Tamlite cannot accept responsibility for errors, omissions, or deviations if the scheme is used without verification.

Important Notice

This service support lighting design considerations but does not constitute certified design advice or regulatory compliance. It is not exhaustive and should not be used as the sole basis for procurement or approval.