

CALAMBA ALLIED INDUSTRIAL CORPORATION

MOTOR TEST REPORT

BRAND/NAME : LanMotors

TAG ID: 1064

H.P. 4K.W. N/AMP: 2RPM: 1500VOLTS: 220PHASE: 3HZ: 60SR#

A. BEFORE RECONDITION

DATE:

A1.	WINDING RESISTANCE TEST (OHMS)		INSULATION RESISTANCE TEST (MEGA-OHMS)				TESTING W/O LOAD (AMPS.)																																
			TIME	T-G @500V	T-G @1000V	T-G @2000V																																	
	T1-T2/Pri	0	30 SECONDS				L1	L1																															
	T1-T3/Sec	0	1 MINUTE	0 m ohm			L2	L2																															
	T2-T3	0	10 MINUTES	0 m ohm			L3	L3																															
	REMARKS	FAILED	Polarization Index	1.01			L4	L4																															
WINDING TEMP.			C°	ABM. TEMP.	C°	L5	L5																																
REMARKS: FAILED					L6	L6																																	
A2.	HIGH POTENTIAL TEST (MICRO-AMPS)				TESTING W/O LOAD (AMPS.)																																		
		T-G@500V	T-G@1000V	T-G@1500V	T-G@2000V	Pri. (Volts)	Sec. (Volts)	Pri. (Amps)	Sec (Amps.)																														
	T1	TRIP				L1																																	
	T2	TRIP				L2																																	
	T3	TRIP				L3																																	
	REMARKS	FAILED																																					
A3.	SURGE TEST/COMPARISON TEST:				VOLTAGE INPUT: 1500																																		
<div><div>PHASE</div><div><div>1-21-32-3</div><table><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td>x</td><td>x</td><td>x</td></tr></table></div><div>TURN TO TURN SHORT COIL TO COIL SHORT REVERSED COIL CONNECTION OPEN COIL CONNECTION ARCING BETWEEN THE WINDINGS OR PHASES</div></div>																		x	x	x	<div><div>PHASE</div><div><div>1-21-32-3</div><table><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr></table></div><div>COMPLETE GROUND PARTIAL GROUND PHASE TO PHASE SHORT GOOD WINDING</div><div>For Rewind--> For Recon</div></div>																		
x	x	x																																					
RECOMMENDATION:			asdas																																				
NOTE:			cxasc																																				
B. AFTER RECONDITION/REWINDING						DATE:																																	
B1.	WINDING RESISTANCE TEST (OHMS)		INSULATION RESISTANCE TEST (MEGA-OHMS)				TESTING W/O LOAD (AMPS.)																																
			TIME	T-G @500V	T-G @1000V	T-G @2000V																																	
	T1-T2/Pri	12.4	30 SECONDS				L1	L1																															
	T1-T3/Sec	12.4	1 MINUTE	176 m ohm			L2	L2																															
	T2-T3	12.4	10 MINUTES	449 m ohm			L3	L3																															
	REMARKS	PASSED	Polarization Index	1.02			L4	L4																															
WINDING TEMP.			C°	ABM. TEMP.	C°	L5	L5																																
REMARKS: PASSED					L6	L6																																	
B2.	HIGH POTENTIAL TEST (MICRO-AMPS)				TESTING W/O LOAD (AMPS.)																																		
		T-G@500V	T-G@1000V	T-G@1500V	T-G@2000V	Pri. (Volts)	Sec. (Volts)	Pri. (Amps)	Sec (Amps.)																														
	T1	60				L1																																	
	T2	60				L2																																	
	T3	60				L3																																	
	REMARKS	PASSED																																					
B3.	SURGE TEST/COMPARISON TEST:				VOLTAGE INPUT: 1500																																		
<div><div>PHASE</div><div><div>1-21-32-3</div><table><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr></table></div><div>TURN TO TURN SHORT COIL TO COIL SHORT REVERSED COIL CONNECTION OPEN COIL CONNECTION ARCING BETWEEN THE WINDINGS OR PHASES</div></div>																					<div><div>PHASE</div><div><div>1-21-32-3</div><table><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td>x</td><td>x</td><td>x</td></tr></table></div><div>COMPLETE GROUND PARTIAL GROUND PHASE TO PHASE SHORT GOOD WINDING</div></div>													x	x	x			
x	x	x																																					
RECOMMENDATION:			adas																																				
NOTE:			qeq																																				
TESTED BY:RECEIVED BY:CERTIFIED BY: Walter A. Oplencia																																							