

CALAMBA ALLIED INDUSTRIAL CORPORATION

MOTOR TEST REPORT

BRAND/NAME : LanMotors

TAG ID: 1063

H.P. 4

K.W. N/A

AMP: 2

RPM: 1500

VOLTS: 220

PHASE: 3

HZ: 60

SR#

A. BEFORE RECONDITION

DATE:

A1.	WINDING RESISTANCE TEST (OHMS)		INSULATION RESISTANCE TEST (MEGA-OHMS)					TESTING W/O LOAD (AMPS.)																																
			TIME	T-G @500V	T-G @1000V	T-G @2000V																																		
	T1-T2/Pri		30 SECONDS				L1	L1																																
	T1-T3/Sec		1 MINUTE				L2	L2																																
	T2-T3		10 MINUTES				L3	L3																																
	REMARKS		Polarization Index				L4	L4																																
WINDING TEMP.			C°	ABM. TEMP.	C°	L5	L5																																	
REMARKS:			L6	L6																																				
A2.	HIGH POTENTIAL TEST (MICRO-AMPS)				TESTING W/O LOAD (AMPS.)																																			
		T-G@500V	T-G@1000V	T-G@1500V	T-G@2000V		Pri. (Volts)	Sec. (Volts)	Pri. (Amps)	Sec (Amps.)																														
	T1					L1																																		
	T2					L2																																		
	T3					L3																																		
	REMARKS	FAILED																																						
A3.	SURGE TEST/COMPARISON TEST:					VOLTAGE INPUT: 1500																																		
<div>PHASE</div> <div>1-21-32-3</div> <table><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr></table> <div>TURN TO TURN SHORT COIL TO COIL SHORT REVERSED COIL CONNECTION OPEN COIL CONNECTION ARCING BETWEEN THE WINDINGS OR PHASES</div> <div>Remarks:</div>																					<div>PHASE</div> <div>1-21-32-3</div> <table><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr></table> <div>COMPLETE GROUND PARTIAL GROUND PHASE TO PHASE SHORT GOOD WINDING</div> <div>For RewindFor Recon</div>																			
RECOMMENDATION:																																								
NOTE:																																								
B. AFTER RECONDITION/REWINDING						DATE:																																		
B1.	WINDING RESISTANCE TEST (OHMS)		INSULATION RESISTANCE TEST (MEGA-OHMS)					TESTING W/O LOAD (AMPS.)																																
			TIME	T-G @500V	T-G @1000V	T-G @2000V																																		
	T1-T2/Pri		30 SECONDS				L1	L1																																
	T1-T3/Sec		1 MINUTE				L2	L2																																
	T2-T3		10 MINUTES				L3	L3																																
	REMARKS		Polarization Index				L4	L4																																
WINDING TEMP.			C°	ABM. TEMP.	C°	L5	L5																																	
REMARKS:			L6	L6																																				
B2.	HIGH POTENTIAL TEST (MICRO-AMPS)				TESTING W/O LOAD (AMPS.)																																			
		T-G@500V	T-G@1000V	T-G@1500V	T-G@2000V		Pri. (Volts)	Sec. (Volts)	Pri. (Amps)	Sec (Amps.)																														
	T1					L1																																		
	T2					L2																																		
	T3					L3																																		
	REMARKS																																							
B3.	SURGE TEST/COMPARISON TEST:					VOLTAGE INPUT: 1500																																		
<div>PHASE</div> <div>1-21-32-3</div> <table><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr></table> <div>TURN TO TURN SHORT COIL TO COIL SHORT REVERSED COIL CONNECTION OPEN COIL CONNECTION ARCING BETWEEN THE WINDINGS OR PHASES</div> <div>Remarks:</div>																					<div>PHASE</div> <div>1-21-32-3</div> <table><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr></table> <div>COMPLETE GROUND PARTIAL GROUND PHASE TO PHASE SHORT GOOD WINDING</div>																			
RECOMMENDATION:																																								
NOTE:																																								
TESTED BY:RECEIVED BY:CERTIFIED BY: Walter A. Opulencia																																								