


TAX INVOICE


Original for Receipt
Duplicate for supplier/ Transporter
Triplicate for Supplier




ASHBOND ENGINEERS PRIVATE LIMITED

B-9/3, Mianwali Nagar, Rohtak Road, New Delhi - 110087
Ph. 91-11-25264696, 25271161 Fax No. : 91-11-25264696
E-mail : sales@ashbond.in, info@ashbond.in
GSTIN | 07AAACA6708J1ZQ

P.O. NO. & Date: 4000195892-M94-1026 DT 01.02.2018		Tax invoice no. : 362		Invoice Dt.: 09.02.2018		
Details of Receiver/ Billed To: TALCHER SUPER THERMAL POWER STATION		Details of Consignee/ Shipped To: TALCHER SUPER THERMAL POWER STATION				
Manager/ Sr. Manager (Store) NTPC LTD. Talcher Super Thermal Power Station P.O. Deepshikha, Angul Odisha - 759147		Manager/ Sr. Manager (Store) NTPC LTD. Talcher Super Thermal Power Station P.O. Deepshikha, Angul Odisha - 759147				
State Code : ODISHA		State code : 21				
GSTIN : 21AAACN0255D1ZA		GSTIN : 21AAACN0255D1ZA				
Sl. No.	Description of Goods or/and Services	HSN/ SAC Code	GST @	Qty.	Unit Rate (In Rs.)	Total Value (In Rs.)
1	ACTUATOR: CCI-AG: STEUERBLOCK - 103226757260 Material Code: M9470207101 (Blocking Element BL 10-2)	8481	IGST@18%	1 NOS.	148,500.00	148,500.00
Total						148,500.00
Less : Discount						-
TOTAL TAXABLE VALUE FOR GOODS & SERVICES						148,500.00
SGST @ Total						-
CGST @ Total						-
IGST @ 18% Total						26,730.00
Round Off Value						175,230.00
Total Amount After GST						175,230.00
Tax Is Payable On Reverse Charge						NO
Rupees One Lac Seventy Five Thousand Two Hundred Thirty Only						
Certified that the particulars given above are true and correct. For Ashbond Engineers Pvt. Ltd.  Authorised Signatory		Bank Details: Account Name : Ashbond Engineers Pvt. Ltd. Bank Name : State Bank Of India Account No. : 54006819546 Bank's Branch IFSC : SBIN0040506 : Terms and Conditions: All matters are subject to Delhi Jurisdiction.				

DELIVERY CHALLAN**ASHBOND ENGINEERS PRIVATE LIMITED**

B-9/3, Mianwali Nagar, Rohtak Road, New Delhi - 110087
Ph. 91-11-25264696, 25271161 Fax No. : 91-11-25264696
E-mail : sales@ashbond.in, info@ashbond.in
GSTIN | 07AAACA6708J1ZQ

Recipient details		DC No. : AEPL/DC/17-18\1249			
Name : TALCHER SUPER THERMAL POWER STATION		DC Date : 09.02.2018			
Bill To Address: Manager/ Sr. Manager (Store) NTPC LTD. Talcher Super Thermal Power Station P.O. Deepshikha, Angul Odisha - 759147		P.O. No. & Dt : 4000195892-M94-1026 DT 01.02.2018			
		Address of delivery: Manager/ Sr. Manager (Store) NTPC LTD. Talcher Super Thermal Power Station P.O. Deepshikha, Angul Odisha - 759147			
State : ODISHA		State code : 21			
GSTIN : 21AAACN0255D1ZA		Tax Is Payable On Reverse Charge : NO			
Sl. No.	Description of Goods or/and Services	HSN/ ACS Code	Qty.	Unit Rate (In Rs.)	Total Value (In Rs.)
10	ACTUATOR: CCI-AG: STEUERBLOCK - 103226757260 Material Code: M9470207101	8481	1 NOS.	148,500.00	148,500.00
TOTAL TAXABLE VALUE OF GOODS/SERVICES					148,500.00
TOTAL ASSESSABLE VALUE FOR GST					148,500.00
Rupees One Lac Forty Eight Thousand Five Hundred Only					
For ASHBOND ENGINEERS PVT.LTD.					
 Authorised Signatory					
Received The Goods In Good Order & In Good Condition					
Customer's Signature					



**ASHBOND
ENGINEERS
PVT. LTD.**

AEPL/NTPC Talcher/17-18/1250

February 09, 2018

Manager/ Sr. Manager (Store)
NTPC LTD.
Talcher Super Thermal Power Station
P.O. Deepshikha, Angul
Odisha – 759147

B-9/3, Mianwali Nagar, Rohtak Road, New Delhi - 110087
Ph.: 011-25264696, 25271161 Fax : 011-25264696
E-mail : sales@ashbond.in, info@ashbond.in
Website : www.ashbond.in

Sub. : **Guarantee/ Warranty Certificate**

Ref.: **Your P.O. No. 4000195892-M94-1026 DT 01.02.2018**

Dear Sir,

This is to certify that the following item supplied by us against your above referred Purchase Order are guaranteed for full satisfactory performance against all manufacturing defects, faulty material and bad workmanship for a period of 12 months from the date of installation or 18 months from the date of supply whichever is earlier. If any item is found defective due to faulty material/design/bad workmanship within this period, the same will be replaced by us free of cost.

Sr. No.	Material Code	Description	Qty.
01	M9470207101	ACTUATOR: CCI-AG: STEUERBLOCK - 103226757260	01

Thanking you,

Yours faithfully

For ASHBOND ENGINEERS PRIVATE LIMITED


ASHISH DHAMIJA
DIRECTOR

**SITE : - M/S. NTPC - TALCHER SUPER THERMAL POWER STATION
(ASHBOND ENGG)**

BLOCKING ELEMENT TEST REPORT

SL NO	TYPE	CURRENT DRAWN BY SOLENOID VALVE 430 mA (Min)	DRIFTING 0.5 mm IN 15 Min OPEN / CLOSE	REMARKS
489	BL 10/2	440	0.08 / 0.03	ACCEPTED

S. Jey

INSPECTOR SIGNATURE