

# Virtual Power Plant server technical documentation

Ubbe Welling  
ubbe@eng.au.dk

July 4, 2016

# Contents

<b>1</b>	<b>Overview</b>	<b>2</b>
1.1	Purpose . . . . .	2
1.2	Functionality . . . . .	2
<b>2</b>	<b>Configuration</b>	<b>4</b>
2.1	Main configuration file . . . . .	4
2.2	Data provider: measurements from FTP . . . . .	6
2.3	Data provider: measurements from RabbitMQ . . . . .	10
<b>3</b>	<b>How to run</b>	<b>12</b>
3.1	Scripts . . . . .	12
<b>4</b>	<b>Database design</b>	<b>13</b>
4.1	Tables . . . . .	15
4.2	CIM compliance . . . . .	16
<b>5</b>	<b>Application design</b>	<b>17</b>
5.1	Static structure . . . . .	17
5.2	Runtime processes . . . . .	21

# Chapter 1

## Overview

This report provides technical documentation of the VPP software located in <https://github.com/comsyslab/vpp>. To use the software, read chapters 1, 2 and 3. To modify/extend the software, read chapters 4 and 5 as well.

### 1.1 Purpose

The purpose of the Virtual Power Plant (VPP) platform is to:

- receive measurements from sensors deployed in a building.
- receive current and forecast information from external sources on grid load, electricity price and more.
- process measurements and external information to make decisions on power usage.
- actuate devices deployed in a building to implement above mentioned decisions.

In the current state, only the two first bullets (i.e. data collection) have been implemented. In the design document located in [https://github.com/comsyslab/vpp/blob/master/documentation/design\\_doc/main.pdf](https://github.com/comsyslab/vpp/blob/master/documentation/design_doc/main.pdf), the original ideas and visions for further extensions to the system are documented. Note that the technical information in the design document is not up-to-date. The present document is intended to provide a comprehensive description of the software in its current state (May 31, 2016).

### 1.2 Functionality

The system can receive measurement and prediction data from data providers via FTP, SFTP and RabbitMQ. There is thus no direct connection to physical sensors.

Received data is stored in a local database which employs a *Rolling Window* scheme: Data is put into subtables according to timestamp (one subtable for e.g. every 24 hours), and when a subtables ages beyond the configured time limit (e.g. 5 days), the contents of it is transferred to the external data warehouse database and the table is deleted. This enables deployment of the VPP software on machines with limited disk size.

# Chapter 2

## Configuration

### 2.1 Main configuration file

The main configuration file is `vpp/vpp_server/resources/config.ini`. In the repository, a `config.ini.default` is provided. It is shown and explained below:

```
[DB]
user=[FILL IN]
password=[FILL IN]
host=[external address of localhost]
database=vpp
measurement_partition_period_hours=24
rolling_window_length_days=7

[DB-DW]
enabled=False
user=[FILL IN]
password=[FILL IN]
host=[host.sub.domain.dk]
database=vpp_dw

[LOG]
level=DEBUG
```

#### 2.1.1 Section [DB]

Section [DB] specifies how to connect to the Rolling Window DB that is intended to run on the same machine as the VPP application. Note that it is perfectly possible to run the database on a different machine if desired.

**host** This should be the external address (hostname or IP) of the machine running the database - usually the same as is running the application. While

writing `localhost` is sufficient for the application to access the DB, this address is also used by the data warehouse to extract data for export, and therefore it must be the machine's actual network address. Port 5432 (the PostgreSQL default) is assumed. Note that this port must be accessible from the data warehouse machine, as the data export SQL is sent to and executed in the data warehouse DB, connecting back to the main DB.

**database** The name of the database to connect to.

**measurement\_partition\_period\_hours** Incoming measurements and predictions will be stored in subtables covering time intervals of the number of hours specified here. Should be a divisor of 24 (e.g 24, 12, 6). Behavior with other values has not been tested. The partitioning happens with respect to UTC, not the local time of the server.

**rolling\_window\_length\_days** The number of days to retain subtables with measurements and predictions before exporting the data to data warehouse and deleting the tables. The current day is not counted, meaning that a value of 1 will cause data received during June 10th to be exported sometime during June 12th, since the last data of June 10th will at that time be at least 24 hours old. Behavior with value 0 has not been tested.

### 2.1.2 Section [DB-DW]

**enabled** If `true`, data export to data warehouse and subsequent local deletion will be performed. If `false`, data will be retained in the local database forever. In this case, configuration of user, password, host and database name may be omitted, and the `rolling_window_length_days` value above is irrelevant. Values are not case sensitive.

### 2.1.3 Section [LOG]

**level** Specifies the level of logging that will be output in `vpp_server/logs/console.log`. Valid values (case sensitive): `DEBUG`, `INFO`, `WARNING`, `ERROR`, `FATAL`, `CRITICAL` (the last two are equal) and integer values. `DEBUG` is level 10. Setting value 9 will add messages on files skipped when fetching from FTP servers. The log level can be changed while the application is running and should take effect within 5 seconds.

No file rotation is performed, which can cause log file to grow very large if the log level is set to `INFO` or lower and a high volume of messages is received. It is recommended to set level `WARNING`, in which case any problems will be reported, but nothing else.

Note that the log file is cleared on application startup.

## 2.2 Data provider: measurements from FTP

The retrieval of data is configured by placing a `.ini` file for each data source in folder `vpp_server/resources/data_providers`.

File `ftp.energinet_online.ini`:

```
[data_provider]
adapter = vpp.data_acquisition.adapter.ftp_adapter.FTPAdapter
interpreter = vpp.data_acquisition.interpreter.energinet_online_interpreter.D
processor = vpp.data_acquisition.processing_strategy.DefaultMeasurementProce
id_prefix = energinet

[fetch]
interval = 600
adapter_date_strategy = vpp.data_acquisition.adapter.adapter_date_strategy.D
last_fetch_adapter = 2016-05-27T00:00:00
fetch_again_when_date_equal = True
last_fetch_interpreter = 2016-05-27T14:55:00

[ftp]
host = 194.239.2.256
username = ftp000123
password = ...
port = 21
remote_dir = Onlinedata
file_pattern = ([0-9]{4})([0-1][0-9])([0-3][0-9])_onlinedata\.txt
encoding = iso-8859-1

[averaging]
enable = True
id_patterns = energinet_1; energinet_2; energinet_3; energinet_%%
intervals = 900; 1800; 3600; 7200
```

### 2.2.1 Section `[data_provider]`

This section configures the protocol for obtaining data, and how they should be interpreted and stored. The adapters, interpreters and processors (listed below) can be combined in any way, but the interpreter obviously must be matched to the data fetched/received by the data provider. It also would be pointless to combine a `PredictionProcessingStrategy` with a data source and interpreter that provides measurements.

**adapter** This specifies which data adapter to use for retrieving data from the provider. Available adapters:

```
vpp.data_acquisition.adapter.ftp_adapter.FTPAdapter
[...].ftp_adapter.SFTPAdapter
```

`[...].rabbitmq_adapter.RabbitMQAdapter`

The adapter will handle communication with the provider and extract a raw text body and pass it to the data interpreter.

**interpreter** This specifies which data interpreter to use for parsing the received raw text messages and transforming them to an internal data format that is then passed to the processor responsible for storing measurements (or predictions) in the database. Available interpreters:

```
vpp.data.acquisition.interpreter.energinet_online_interpreter.EnerginetOnlineInterpreter
[...].energinet_co2_interpreter.EnerginetCO2Interpreter
[...].nordpoolspot_interpreter.NordpoolspotInterpreter
[...].thor_interpreter.ThorInterpreter
[...].nrgi_abs_interpreter.NrgiAbsInterpreter
[...].nrgi_delta_interpreter.NrgiDeltaInterpreter
[...].grundfos_data_interpreter.GrundfosDataInterpreter
[...].smartamm_data_interpreter.SmartAmmDataInterpreter
```

**processor** Responsible for storing measurements or predictions in the database. Available processors:

```
vpp.data.acquisition.processing.strategy.DefaultMeasurementProcessingStrategy
vpp.data.acquisition.processing.strategy.DefaultPredictionProcessingStrategy
```

**id\_prefix** Among the data received will be sensors (logical sources of measurements) and endpoints (logical sources of predictions). The `id_prefix` specifies a prefix for the database ID of the sensors and endpoints which makes it easier to distinguish them and their measurements/predictions in the database.

## 2.2.2 Section [fetch]

Since the FTPAdapter must actively fetch data, this section is required.

**interval** In seconds. Every time this interval passes, the FTPAdapter will connect and fetch data which is then processed and stored. The time to next fetch is measured from launch, not finish, meaning that the interval will be maintained precisely as long as the fetch and processing completes before the next launch.

**adapter\_date\_strategy** Strategy for deciding whether a file should be fetched, based on the date extracted from the file name. Available strategies:

```
vpp.data.acquisition.adapter.adapter_date_strategy.DefaultAdapterFileDateStrategy
vpp.data.acquisition.adapter.adapter_date_strategy.CO2FileDateStrategy
```

The `DefaultAdapterFileDateStrategy` will fetch a file if the date is later (or equal to, depending on the value of `fetch_again_when_date_equal`) than the value of `last_fetch_adapter`.



`CO2FileDateStrategy` will fetch if the date extracted from the filename is in the future compared to the time of execution. This is useful for the CO2 predictions from Energinet.

`fetch_again_when_date_equal` Specifies whether files with timestamp identical to the value of `last_fetch_adapter` should be fetched. Setting this to `True` will enable repeated retrieval of the same file(s), which can be useful if file contents are updated.

`last_fetch_adapter` Updated by the data adapter when fetching files to the latest timestamp extracted from the fetched filenames. If configuring a new data provider, set this to a value close to the current time to avoid fetching many old files.

`last_fetch_interpreter` Updated by the data interpreter to the timestamp of the latest processed measurement/prediction. This is relevant in the case the same file is continuously updated with new data.

### 2.2.3 Section [ftp]

`host`, `username`, `password` and `port` should be self-explanatory.

`remote_dir` is the subdirectory to access on the FTP server. Use forward slashes.

`file_pattern` This should be a Python regex containing up to four groups which will match year, month, day and hour (in that order). Only year is required - the others are optional. Only files matching this pattern will be considered for fetching. The extracted timestamp is compared against the value of `last_fetch_adapter` to determine if the file should be fetched.

`encoding` Specifies the encoding of the files to be fetched. Tested values are `utf-8`, `ascii` and `iso-8859-1`.

### 2.2.4 Section [averaging]

`enable` If `True` or `true`, data transferred to data warehouse will be averaged over the intervals specified below in order to reduce data size in data warehouse. If not, entries will be bulk copied as-is.

`id_patterns` List of patterns of sensor/endpoint IDs to perform averaging for. Patterns are used in a PostgreSQL LIKE comparison. The wildcard `%` must be written twice due to Python's string parsing. Thus, to match all sensors starting with prefix `energinet`, write `energinet%%`. Patterns should be separated with semicolon `;`. Every pattern should have a corresponding interval in the

**intervals** list below. The patterns are processed in order, so it makes sense to add a catch-all pattern at the end of the list.

**intervals** Semicolon-separated list of time intervals in seconds, each interval corresponding to the pattern with the same position in the list above.

## 2.3 Data provider: measurements from RabbitMQ

File `rabbitmq_ecosense_smartamm.ini`:

```
[data_provider]
adapter =
vpp.data_acquisition.adapter.rabbit_mq_adapter.RabbitMQAdapter
interpreter =
vpp.data_acquisition.interpreter.smartamm_data_interpreter.SmartAmmDataInterpreter
processor =
vpp.data_acquisition.processing_strategy.DefaultMeasurementProcessingStrategy
id_prefix = smartamm

[exchange]
username = user123
password = 12345
serverAddressList = ecosensemq02.cs.au.dk
port = 5672
sslConnection = False
exchangeName = ecosense-exchange
exchangeDurable = True
exchangeType = topic

[queue]
name = vpp-listener-queue-new
routingKeys = smartamm.#
durable = False
exclusive = False
autoDelete = True

[ssl_options]
cacerts = /etc/rabbitmq/ssl/tesca/cacert.pem
certfile = /etc/rabbitmq/ssl/client/cert.pem
keyfile = /etc/rabbitmq/ssl/client/key.pem
cert_reqs = verify_peer
fail_if_no_peer_cert = True

[averaging]
enable = False
id_patterns = smartamm%%RMSCurrent%%; smartamm%%ActivePower%%;
intervals = 60; 120
```

### 2.3.1 Section `[exchange]`

`serverAddressList` The RabbitMQ exchange server to connect to. The "List" is misleading. Only a single host should be specified.

**sslConnection** If `True`, the `Pika` library will enable SSL when connecting. Not tested.

For the remaining configuration, look at <https://www.rabbitmq.com/getstarted.html> to understand how RabbitMQ works.

### **2.3.2 Section [queue]**

Specifies the RabbitMQ queue to connect to in the exchange with various parameters. Again: Look at <https://www.rabbitmq.com/getstarted.html> to understand how RabbitMQ works.

### **2.3.3 Section [ssl\_options]**

This section is not parsed, regardless of **sslConnection** setting above.

## Chapter 3

# How to run

The various scripts are placed in `vpp_server/run` and explained below. All scripts exist in a Linux (`.sh`) and Windows (`.bat`) version.

### 3.1 Scripts

`clear_db.sh` Use with care. Connects to the database specified in the [DB] section of `config.ini` and drops and recreates the entire database schema *without prompting for confirmation*. This can be used to initialize a new database.

`clear_db_dw.sh` Use with care. Identical to `clear_db.sh` above, but connects to the database specified in the [DB-DW] section of `config.ini`. Note that this may contain data accumulated over a long time.

`run_tests.sh` Executes all unit tests and outputs results to console.

`start_server.sh` Launches the VPP server.  
Logging is output in `vpp_server/logs/console.log`.

`stop_server.sh` Stops a running server. This is implemented in a very primitive fashion: The script creates a file named `stop` which the running server scans for every 5 seconds.

## Chapter 4

# Database design

The database should reside in a PostgreSQL DBMS. The schema is shown in figure 4.1 and explained in the following:




Figure 4.1: Database schema

## 4.1 Tables

### 4.1.1 Devices and measurements

**Device** Entries in **Device** correspond to physical control and sensor devices, with the modification that we store one logical device for each function of the physical device. Whether a device is a sensor or a controller is specified by its presence in table **Controller** or **Sensor**. Columns **Attribute**, **Unit** and **UnitPrefix** (such as milli) are for sensors specification of the incoming measurement values, while they for controllers specify the format of values to send to the controller when actuating it.

**Sensor** Table **Sensor** specifies an optional property **ValueInterval** which is used when measurement values are aggregated over a limited time interval (such as 15 minutes).

**Measurement** Contains a row for each measurement received from a sensor. It simply consists of a **value**, a **timestamp** and a **sensor\_id**, which enables interpretation of the value. Column **exported** indicates whether a row has been exported to data warehouse or not.

The **Measurement** table is partitioned into subtables for each e.g. 24 hours. Querying the **Measurement** table will automatically retrieve data from all its subtables, while insertion must happen directly to the correct subtable. Each subtable has a constraint on the **timestamp**, preventing measurements from being entered in the wrong subtable.

**ControlAction** Table **ControlAction** is intended to contain scheduled and past commands for controllers. An action is simply specified by a **value** which can be interpreted via the reference into table **Controller** and **Device**. Column **schedule** specifies the time for carrying out the action, and **status** indicates if execution is still pending or has been completed. Partitioning this table in the same way as table **Measurement** could be considered. In the current implementation of the VPP software, the **Controller** and **ControlAction** tables will always be empty.

**Building, FloorSection, Room** The physical properties of a building are modeled in these tables. A building consists of an integer range of floors. Each floor consists of **FloorSections** which in most cases will be equivalent to apartments. The generalized term **FloorSection** is intended to support other types of buildings where designations such as "South wing" or other may be desired. Finally, a floor consists of named **Rooms**. We do not expect to obtain device locations with a higher degree of accuracy than individual rooms.

**DeviceLocation** This table maps **Devices** to **Rooms** for specific time periods, indicating that devices may be moved around over time.



### 4.1.2 Predictions

While the data stored for predictions is quite similar to those for measurements, we have chosen to store them separately because of the fundamentally different semantics.

**PredictionEndpoint** A logical source of predictions of one type. Specifies the **attribute** and **unit** of the incoming values and provides an optional **description**.

**Prediction** Actual prediction values. **timestamp** indicates the time for which the value applies, while **time\_received** indicates when the prediction was received from the provider. This is relevant since multiple predictions for the same future point in time may be received over time. Some values actually cover an interval (for instance predicted power consumption for a given day of 24 hours), which is specified in column **value\_interval**. This table is partitioned in same way as table **Measurement**.

## 4.2 CIM compliance

Units, unit prefixes, timestamps and time durations are formatted to agree with CIM.

## Chapter 5

# Application design

The VPP application is implemented in object-oriented Python. The static structure and runtime behavior is det

### 5.1 Static structure




Figure 5.1: Overview of packages

The application is roughly structured in a layered architecture with the **database** as the bottom layer and the **core** and **data\_acquisition** packages as the domain layer. A **service** package could be added as the top layer, providing an external interface. The packages are explained in detail below.

## Package vpp.core




Figure 5.2: Package core

`Coordinator` is called by `start_server.sh` and launches the entire application. Mainly, it instantiates the `DataProviderProcess` and the `DBMaintenanceProcess`. The processes are each wrapped in a `ProcessHandle` which handles process launch and termination and receives log messages from the underlying `AbstractVPPProcess`. That is, all log messages are communicated (using Python interprocess message queues) to the main process which outputs to `logs/console.log`.

## Package vpp.data\_acquisition




Figure 5.3: Package `data_acquisition`

This package contains the framework for connecting to sources of measurement and prediction data. The `DataProviderProcess` launches a `DataProvider` for each configured `.ini`-file as described in 2.2. Each `DataProvider` instance employs a suitable `DataAdapter`. The `FetchingAdapters` employ a `DataProviderTimer` that will wake up according to configuration and execute data retrieval and processing. The `ListeningAdapter` will launch a thread that continuously listens for messages and processes them as they are received. Thus, each data provider does all processing in its own thread.

The **DataAdapters** handle communication with the data source and extract a raw string that is then passed to the configured **DataInterpreter**. The interpreter parses the string and outputs data as Python dictionaries to the **ProcessingStrategy** which interacts with a **DBManager** to store the data.

### Package `vpp.database`

This package contains the code that interfaces directly with the database.




Figure 5.4: Package `database`

`DBMaintainerProcess` wakes up in accordance with the period specified in `config.ini` and instantiates `DBMaintenance` that runs maintenance on the database, implementing the Rolling Window strategy.

`DBManager` provides an interface to the database. It relies on `SchemaManager` which implements initialization of the database schema as well as creation and lookup of subtables for the Rolling Window scheme. The `measurement` and `prediction` tables and their subtables are implemented directly in SQL, but the rest of the schema is implemented using the object-relational mapper (ORM) framework `SQLAlchemy`.

## 5.2 Runtime behavior

Separate Python processes are deployed to enable concurrent processing. Using processes instead of threads is necessary to fully utilize multiple cores, since Python employs a *Global Interpreter Lock* which prevents threads within the same Python interpreter from executing concurrently. Using processes mitigates this as each process will run with its own interpreter. For this prototype, the multiprocessing could probably have been omitted in favor of simpler multithreading since CPU load has not been an issue at all.

The runtime creation of processes within the main server application is shown below:




Figure 5.5: Simplified sequence diagram of process and thread creation

In the diagram above, the `ProcessHandle` class is omitted for clarity.

### 5.2.1 Data acquisition




Figure 5.6: Sequence diagram of receiving measurements from a RabbitMQ