

Virtual Power Plant technical documentation

Ubbe Welling
ubbe@eng.au.dk

May 31, 2016

Contents

1	Overview	2
1.1	Purpose	2
1.2	Functionality	2
2	Configuration	4
2.1	Main configuration file	4
2.2	Data provider: measurements from FTP	6
3	How to run	8
3.1	Scripts	8
4	Details	9
4.1	Database design	9
4.2	Application design	14

Chapter 1

Overview

This report provides technical documentation of the VPP software located in <https://github.com/comsyslab/vpp>. To use the software, read chapter 1 and 3. To modify/extend the software, read chapter 4 as well.

1.1 Purpose

The purpose of the Virtual Power Plant (VPP) platform is to:

- receive measurements from sensors deployed in a building.
- receive current and forecast information from external sources on grid load, electricity price and more.
- process measurements and external information to make decisions on power usage.
- actuate devices deployed in a building to implement above mentioned decisions.

In the current state, only the two first bullets (i.e. data collection) have been implemented. In the design document located in https://github.com/comsyslab/vpp/blob/master/documentation/design_doc/main.pdf, the original ideas and visions for further extensions to the system are documented. Note that the technical information in the design document is not up-to-date. The present document is intended to provide a comprehensive description of the software in its current state (May 31, 2016).

1.2 Functionality

The system can receive measurement and prediction data from data providers via FTP, SFTP and RabbitMQ. There is thus no direct connection to physical sensors.

Received data is stored in a local database which employs a *Rolling Window* scheme: Data is put into subtables according to timestamp (one subtable for e.g. every 24 hours), and when a subtables ages beyond the configured time limit (e.g. 5 days), the contents of it is transferred to the external data warehouse database and the table is deleted. This enables deployment of the VPP software on machines with limited disk size.

Chapter 2

Configuration

2.1 Main configuration file

The main configuration file is `vpp/vpp_server/resources/config.ini`. In the repository, a `config.ini.default` is provided. It is shown and explained below:

```
[DB]
user=[FILL IN]
password=[FILL IN]
host=[external address of localhost]
database=vpp
measurement_partition_period_hours=24
rolling_window_length_days=7

[DB-DW]
enabled=False
user=[FILL IN]
password=[FILL IN]
host=[host.sub.domain.dk]
database=vpp_dw

[LOG]
level=DEBUG
```

2.1.1 Section [DB]

Section [DB] specifies how to connect to the Rolling Window DB that is intended to run on the same machine as the VPP application. Note that it is perfectly possible to run the database on a different machine if desired.

host This should be the external address (hostname or IP) of the machine running the database - usually the same as is running the application. While

writing `localhost` is sufficient for the application to access the DB, this address is also used by the data warehouse to extract data for export, and therefore it must be the machine's actual network address. Port 5432 (the PostgreSQL default) is assumed. Note that this port must be accessible from the data warehouse machine, as the data export SQL is sent to and executed in the data warehouse DB, connecting back to the main DB.

database The name of the database to connect to.

measurement_partition_period_hours Incoming measurements and predictions will be stored in subtables covering time intervals of the number of hours specified here. Should be a divisor of 24 (e.g 24, 12, 6). Behavior with other values has not been tested. The partitioning happens with respect to UTC, not the local time of the server.

rolling_window_length_days The number of days to retain subtables with measurements and predictions before exporting the data to data warehouse and deleting the tables. The current day is not counted, meaning that a value of 1 will cause data received during June 10th to be exported sometime during June 12th, since the last data of June 10th will at that time be at least 24 hours old. Behavior with value 0 has not been tested.

2.1.2 Section [DB-DW]

enabled If `true`, data export to data warehouse and subsequent local deletion will be performed. If `false`, data will be retained in the local database forever. In this case, configuration of user, password, host and database name may be omitted, and the `rolling_window_length_days` value above is irrelevant. Values are not case sensitive.

2.1.3 Section [LOG]

level Specifies the level of logging that will be output in `vpp_server/logs/console.log`. Valid values (case sensitive): `DEBUG`, `INFO`, `WARNING`, `ERROR`, `FATAL`, `CRITICAL` (the last two are equal) and integer values. `DEBUG` is level 10. Setting value 9 will add messages on files skipped when fetching from FTP servers. The log level can be changed while the application is running and should take effect within 5 seconds.

No file rotation is performed, which can cause log file to grow very large if the log level is set to `INFO` or lower and a high volume of messages is received. It is recommended to set level `WARNING`, in which case any problems will be reported, but nothing else.

Note that the log file is cleared on application startup.

2.2 Data provider: measurements from FTP

The retrieval of data is configured by placing a `.ini` file for each data source in folder `vpp_server/resources/data_providers`.

File `ftp.energinet_online.ini`:

```
[data_provider]
adapter = vpp.data_acquisition.adapter.ftp_adapter.FTPAdapter
interpreter = vpp.data_acquisition.interpreter.energinet_online_interpreter.D
processor = vpp.data_acquisition.processing_strategy.DefaultMeasurementProce
id_prefix = energinet

[fetch]
interval = 600
adapter_date_strategy = vpp.data_acquisition.adapter.adapter_date_strategy.D
last_fetch_adapter = 2016-05-27T00:00:00
fetch_again_when_date_equal = True
last_fetch_interpreter = 2016-05-27T14:55:00

[ftp]
host = 194.239.2.256
username = ftp000123
password = ...
port = 21
remote_dir = Onlinedata
file_pattern = ([0-9]{4})([0-1][0-9])([0-3][0-9])_onlinedata\.txt
encoding = iso-8859-1

[averaging]
enable = True
id_patterns = energinet_1; energinet_2; energinet_3; energinet_%%
intervals = 900; 1800; 3600; 7200
```

2.2.1 Section `[data_provider]`

This section configures the protocol for obtaining data, and how they should be interpreted and stored. The adapters, interpreters and processors (listed below) can be combined in any way, but the interpreter obviously must be matched to the data fetched/received by the data provider. It also would be pointless to combine a `PredictionProcessingStrategy` with a data source and interpreter that provides measurements.

adapter This specifies which data adapter to use for retrieving data from the provider. Available adapters:

```
vpp.data_acquisition.adapter.ftp_adapter.FTPAdapter
[...].ftp_adapter.SFTPAdapter
```

`[...].rabbitmq_adapter.RabbitMQAdapter`

The adapter will handle communication with the provider and extract a raw text body and pass it to the data interpreter.

interpreter This specifies which data interpreter to use for parsing the received raw text messages and transforming them to an internal data format that is then passed to the processor responsible for storing measurements (or predictions) in the database. Available interpreters:

```
vpp.data_acquisition.interpreter.energinet_online_interpreter.EnerginetOnlineInterpreter
[...].energinet_co2_interpreter.EnerginetCO2Interpreter
[...].nordpoolspot_interpreter.NordpoolspotInterpreter
[...].thor_interpreter.ThorInterpreter
[...].nrgi_abs_interpreter.NrgiAbsInterpreter
[...].nrgi_delta_interpreter.NrgiDeltaInterpreter
[...].grundfos_data_interpreter.GrundfosDataInterpreter
[...].smartamm_data_interpreter.SmartAmmDataInterpreter
```

processor Responsible for storing measurements or predictions in the database. Available processors:

```
vpp.data_acquisition.processing.strategy.DefaultMeasurementProcessingStrategy
vpp.data_acquisition.processing.strategy.DefaultPredictionProcessingStrategy
```

id_prefix Among the data received will be sensors (logical sources of measurements) and endpoints (logical sources of predictions). The `id_prefix` specifies a prefix for the database ID of the sensors and endpoints which makes it easier to distinguish them and their measurements/predictions in the database.

2.2.2 Section [fetch]

Since the FTPAdapter must actively fetch data, this section is required.

`interval` = 600

`adapter_date_strategy` = `vpp.data_acquisition.adapter.adapter_date_strategy.DefaultAdapterFileDateStrat`

`last_fetch_adapter` = 2016-05-27T00:00:00

`fetch_again_when_date_equal` = True

`last_fetch_interpreter` = 2016-05-27T14:55:00

Chapter 3

How to run

3.1 Scripts

Chapter 4

Details

4.1 Database design

The database will reside in a PostgreSQL DBMS which is open source and should run well even on a smaller machine.

4.1.1 Schema: core

The central part of the database schema is shown in figure 4.1 and explained below:




Figure 4.1: Database core schema

Devices and measurements

Device Entries in **Device** correspond to physical control and sensor devices, with the modification that we store one logical device for each function of the physical device. Whether a device is a sensor or a controller is specified by its presence in table **Controller** or **Sensor**. Columns **Attribute**, **Unit** and **UnitPrefix** (such as milli) are for sensors specification of the incoming measurement values, while they for controllers specify the format of values to send to the controller when actuating it.

Sensor Table **Sensor** specifies an optional property **ValueInterval** which is used when measurement values are aggregated over a limited time interval (such as 15 minutes).

Measurement This table will contain a row for each measurement received from a physical sensor. It will simply consist of a **Value**, a **Timestamp** and a reference into **Sensor**, which enables interpretation of the value. The **Measurement** table is expected to grow very large and will therefore be partitioned into sub-tables that will each contain 24 hours of measurements and can be discarded on the fly according to the rolling window strategy explained in section 4.1.2.

ControlAction Table **ControlAction** will contain scheduled and past commands for controllers. An action is simply specified by a **Value** which can be interpreted via the reference into table **Controller** and **Device**. Column **Schedule** specifies the time for carrying out the action, and **Status** indicates if execution is still pending or has been completed. Finally, **IssuedBy** specifies which user scheduled the action. We might consider partitioning and discarding of old data in this table in the same way as for table **Measurement**.

Building, FloorSection, Room The physical properties of a building are modeled in these tables. A building consists of an integer range of floors. Each floor consists of **FloorSections** which in most cases will be equivalent to apartments. The generalized term **FloorSection** is intended to support other types of buildings where designations such as "South wing" or other may be desired. Finally, a floor consists of named **Rooms**. We do not expect to obtain device locations with a higher degree of accuracy than individual rooms.

DeviceLocation This table maps **Devices** to **Rooms** for specified time periods, indicating that devices may be moved around.

Predictions

Predictions of a wide range of values (power consumption, grid load, price, CO₂ emissions, ...) will be received from external data providers and will in addition be generated by our own application logic.

While the data stored for predictions is quite similar to those for measurements, we have chosen to store them separately because of the fundamentally different semantics.

PredictionProvider An entity providing predictions, such as energinet.dk or the system itself.

PredictionEndpoint A logical source of predictions of one type. Specifies the **Attribute**, **Unit** and **UnitPrefix** of the incoming values and provides an optional **Description**.

Prediction Actual prediction values. **Timestamp** indicates the time for which the value applies, while **TimeReceived** indicates when the prediction was received from the provider. This is relevant since multiple predictions for the same future point in time may be received over time. Some values actually cover an interval (for instance predicted power consumption for a given day of 24 hours), which is specified in column **ValueInterval**. This table is also expected to grow quickly, motivating the same partitioning and rolling window strategy as for table **Measurement**.

4.1.2 Rolling window

Since the **Measurement** table will grow very quickly, a partitioning and data discarding scheme will be employed. The table will be partitioned in time intervals, having one subtable for every 24 hours. Furthermore, subtables older than one week will be dropped. The time limits can naturally be configured. The same scheme might be applied to tables **ControlAction** and **Prediction**. This is done in order to accommodate the VPP server on a desktop size machine with limited disk space.

4.1.3 Data warehouse

In order to retain data, the VPP will periodically forward data to an external database (data warehouse) that can accommodate a larger volume of data for longer periods. When forwarding data, measurements may be averaged over limited time intervals to reduce data size. The data warehouse can then be used for statistics and historical analysis. While the data warehouse schema was initially planned to be identical to the VPP rolling window DB, the presence of users, privileges and most likely various other configuration indicates that probably only the core schema as shown in figure 4.1 should be present in the data warehouse.

4.1.4 CIM compliance

The Common Information Model (CIM) is being taken into consideration in the design. Where it is applicable, we will aim to make our data model compliant. Units, unit prefixes, timestamps and time durations will be formatted to agree with CIM. On the other hand, CIM does not provide any guidance on how to structure for instance the building/floor/room model.


4.2 Application design

The application will be programmed in object-oriented Python, using Python processes to enable concurrent processing.

Using processes instead of threads is necessary to utilize both cores in the intended machine, since Python employs a *Global Interpreter Lock* which prevents threads within the same Python interpreter from executing concurrently. Using processes mitigates this as each process will run with its own interpreter.

4.2.1 Static structure

structure is shown in figure 4.4 and elaborated below:



Powered By Visual Paradigm Community Edition

Figure 4.2: Class diagram.

The server application is roughly structured in a three-layered architecture with the `database` at lowest layer, the `core`, `control` and `data_acquisition`

packages as the middle "domain" layer and the **service** package as the top layer, providing an external interface.

The **webserver** will access the **service** layer to provide GUI. It will be a separate application deployed on the same machine. See section 4.2.4.

Package `vpp.core`

This package implements the core logic of the VPP server. Classes are explained in detail below.




Figure 4.3: Core

Coordinator is responsible for instantiating other classes and processes. For clarity, associations are not shown in the diagram.

DataProviderProcessManager launches the process which instantiates and manages the individual data providers that will supply measurements and predictions.

ControllerManager instantiates and keeps track of controllers for actuating physical devices. This will run in a separate process that periodically will check for and execute scheduled actions. It is expected that one process for handling all actions will be sufficient.

StatusMonitor runs a process that will poll **DataProviderManager** and **ControllerManager** for status and make this information available to the ser-


vice layer.

DBMonitor runs a process that will monitor the database status. It will give information on when the last measurements were received and similar.

Predictor will run a process to create predictions based the available data.

DBAccess provides a clean interface for retrieving and posting data from and to the database.

Package `vpp.data_acquisition`



Powered By Visual Paradigm Community Edition

Figure 4.4: Data acquisition

This package contains the framework for connecting to various sources of measurement and prediction data. Class **DataProvider** can be instantiated in a separate thread to model a single source of data. Each **DataProvider** instance employs a suitable **DataAdapter** to communicate with for instance a message queue or a SmartAmm server.

A distinction is made between listening adapters (**AbstractListeningAdapter**), which will be activated by external events, and fetching adapters (**AbstractFetchingAdapter**) which employ an internal timer to fetch data periodically.

Package `vpp.control`

Similar to `data_acquisition`, this package will provide a framework for communicating with the various control devices. A **Controller** can be instantiated with a suitable **ControllerAdapter** to communicate with a given device.

Package `vpp.database`

This package contains the code that interfaces directly with the database.

`DBMaintainer` will run maintenance on the database and implement the Rolling Window strategy.

Communication with the database could be implemented simply using SQL, or we could opt for an object-relational mapper (ORM) framework such as SQLAlchemy.

4.2.2 Runtime processes

The runtime creation of processes within the main server application is shown below:




Figure 4.5: Sequence diagram of thread creation

As can be seen, at least six concurrent processes will be running in addition to any `DataProviders` configured.

Process communication overhead

There is of course an overhead cost involved in running processes as opposed to threads, since processes do not have shared memory which will make communication more costly performance-wise. A balanced approach could be to group processes with frequent communication as threads within the same process, thus reducing the total number of processes from the current minimum six (plus `DataProviders`) to two or three.

4.2.3 Data acquisition

The execution flow when receiving measurements from a RabbitMQ is shown below:




Figure 4.6: Sequence diagram of data acquisition

4.2.4 Web server

We intend to provide a web interface for users to access the system. This will run in a separate web server, but in the same machine. The preliminary plan is to build the webapp using Django since this supports Python.

The web interface could in itself grow to a rather large application with support for building configuration, device configuration, user administration, actuation interfaces and so on. This will require a substantial design and development effort. In the initial version, we plan to support only very basic interaction as proof of concept.