SECTION 06 41 16 - PLASTIC-LAMINATE-FACED ARCHITECTURAL CABINETS

PART 1 - GENERAL

1.1 SUMMARY

A. Section includes plastic-laminate-faced architectural cabinets, cabinet hardware and accessories, and countertops at casework.

1.2 SUBMITTALS

A. Shop Drawings: Show location of each item, dimensioned plans and elevations, large-scale details, attachment devices, and other components.

B. Samples: Submit plastic laminate samples, 8 by 10 inches, for each type, color, pattern, and surface finish.

C. Product Certificates: Submit AWI Quality Certification Program labels and certificates for each type of casework.

1.3 QUALITY ASSURANCE

A. Fabricator Qualifications: Shop that employs skilled workers who custom fabricate products similar to those required for this Project and whose products have a record of successful in-service performance.

B. Mockups: Build mockup of typical base cabinet, wall cabinet, and countertop, approximately 8 feet long.

1.4 WARRANTY

A. Provide a two-year warranty on all casework, hardware, and installation, starting at Substantial Completion.

PART 2 - PRODUCTS

2.1 PLASTIC-LAMINATE-FACED CABINETS

A. Grade: Custom grade in accordance with AWI/AWMAC/WI Architectural Woodwork Standards, 2nd Edition.

B. Type of Construction: Frameless.

C. Cabinet Style: Flush overlay.

D. Laminate Cladding for Exposed Surfaces: High-pressure decorative laminate, NEMA LD 3, Grade HGS, 0.048 inch nominal thickness.

E. Edgebanding: 3 mm PVC edgebanding matching laminate in color and pattern at all exposed edges.

F. Core Material: Particleboard, ANSI A208.1, Grade M-2, 3/4 inch thick, with no added urea formaldehyde.

2.2 CABINET HARDWARE

A. Hinges: Concealed European-style, self-closing, 170 degree opening, BHMA A156.9, Grade 1.

1. Basis of Design: Blum Clip Top 170.

B. Drawer Slides: Full-extension, ball-bearing, 100 lbf load rating, BHMA A156.9, Grade 1.

C. Pulls: Back-mounted 4 inch wire pulls, satin stainless steel finish.

D. Locks: Provide cam locks on all drawers and doors where indicated, keyed alike within each room.

E. Shelf Supports: 5 mm metal pin supports, 32 mm system spacing.

2.3 COUNTERTOPS

A. Solid Surface Countertops: 1/2 inch thick, ANSI Z124.3, with 4 inch high integral backsplash.

B. Countertop Height: 36 inches above finished floor unless otherwise indicated; 34 inches maximum at accessible locations.

PART 3 - EXECUTION

3.1 INSTALLATION

A. Install cabinets level, plumb, and true; shim as required using concealed shims. Maximum variation 1/8 inch in 96 inches.

B. Anchor cabinets to in-wall blocking with No. 10 wafer-head screws at 16 inches on center.

C. Scribe and cut casework to fit adjoining work; refinish cut surfaces.

END OF SECTION 06 41 16

SECTION 12 36 61 - SIMULATED STONE COUNTERTOPS

PART 1 - GENERAL

1.1 SUMMARY

A. Section includes quartz agglomerate countertops, backsplashes, and support brackets.

1.2 SUBMITTALS

A. Samples: Submit 6 by 6 inch samples of each color and finish.

B. Maintenance Data: Provide care and maintenance instructions.

1.3 WARRANTY

A. Manufacturer warranty: 10 years against defects in materials.

PART 2 - PRODUCTS

2.1 QUARTZ COUNTERTOPS

A. Manufacturers: Caesarstone, Silestone, or approved equal.

B. Thickness: 3 cm (1-1/4 inch).

C. Edge Profile: Eased edge, 1/8 inch radius.

D. Color: QZ-1, Caesarstone 4141 Misty Carrera, polished finish.

2.2 SUPPORT BRACKETS

A. Concealed steel countertop support brackets, powder-coated, rated 1000 lbs per pair, at 36 inches on center maximum.

PART 3 - EXECUTION

3.1 INSTALLATION

A. Seams: Locate seams as shown on approved shop drawings, maximum one seam per run under 10 feet.

B. Sealant: Seal joints with mildew-resistant silicone sealant matching countertop color.

END OF SECTION 12 36 61

SECTION 09 91 23 - INTERIOR PAINTING

PART 1 - GENERAL

1.1 SUMMARY

A. Section includes surface preparation and field painting of interior substrates.

PART 2 - PRODUCTS

2.1 PAINT

A. Manufacturers: Sherwin-Williams, Benjamin Moore, or approved equal.

B. Interior Latex: Eggshell finish, two coats over primer.

PART 3 - EXECUTION

3.1 APPLICATION

A. Apply paint at manufacturer's recommended spreading rate.

END OF SECTION 09 91 23