

本圖完工後請速歸還

FABRICATION MATERIALS

PT NO	COMPONENT DESCRIPTION	N.S. (INS)	ITEM CODE	QTY
PIPE				
1	PIPE A312-TP304 EFW SCH40S BE ASME B36.19M	3	S1P4/P-3"-40S	56.1M

FITTINGS

2	REDUCER ECC BW A403-WP304 SMLS SCH40S ASME B16.9	4 x 3	S1P4/RE-4"X3"	1
3	90 ELBOW LR BW A403-WP304 SMLS SCH40S ASME B16.9	3	S1P4/EB-3"X90	6


ERECTION MATERIALS

PT NO	COMPONENT DESCRIPTION	N.S. (INS)	ITEM CODE	QTY
SUPPORTS				
4	SUPPORT REINFORCING PAD (SRP-3)	3	SUP/SRP-3"	11
5	PIPE SHOE (S1)	3	SUP/S1-3"	11
6	PIPE GUIDE (G5-1)	3	SUP/G5-1-3"	5

CUT PIPE LENGTH FOR REFERENCE ONLY

PIECE NO	CUT LENGTH	N.S. (INS)	REMARKS	PIECE NO	CUT LENGTH	N.S. (INS)	REMARKS
<24>	6000	3		<25>	3520	3	
<26>	2272	3		<27>	6000	3	
<28>	6000	3		<29>	6000	3	
<30>	1552	3		<31>	522	3	
<32>	6000	3		<33>	6000	3	
<34>	6000	3		<35>	2302	3	
<36>	972	3		<37>	2874	3	

N



流水號:1168

FOR CONSTRUCTION

JUL. 04, 2025

管線編號  
WW-18014-3"-S1P4

E-shine 鴻勝化學科技股份有限公司  
E-shine Advanced Chemicals Ltd.

富台工程股份有限公司  
FU-TAI ENGINEERING CO., LTD.

管線工程  
立體配管圖

檔號: WW-18014-S1P4- 4

管件序號 <1>直管編號 [1]管段編號  
& 須設計會驗管線

操作壓力: 2  $\frac{KG}{CM^2}$  G 操作溫度: 25  $^{\circ}C$

設計壓力: 4  $\frac{KG}{CM^2}$  G 設計溫度: 70  $^{\circ}C$

試驗基準: Air 4.4  $\frac{KG}{CM^2}$  G X 60 分

管路塗裝:

管支撐

資料庫  
名稱:

管線等級: S1P4

保溫(冷)等級:

熱追蹤等級:

焊接基準:

NDE 抽驗: 10 %

工廠焊接 套焊 螺紋銜接 配合現場焊接 配合現場接合點 管支撐 蒸汽追蹤管

製圖 胡庭璋 2025.04.21

設計 林信助 2025.04.21

審核 陳安誠 2025.04.21

認可 陳逢明 2025.04.21

依據圖號: C2418-4-529 C2418-4-552

會  
簽

圖號:

圖號:

圖號:

圖號:

圖號:

△

△

△

△

序次 日期 修改說明 修改 認可