		FABRICATION MATERIALS				_→ ^N 流水號:1150
昌	PT NO	COMPONENT DESCRIPTION	N.S. (INS)	ITEM CODE	QTY	がした。 が に に に に に に に に に に に に に
完	1	TEE BW A403-WP304 SMLS SCH40S	ASME B16.9 2 x 2	S1P1/TB-2"	2	
1/4.	2	FLANGE WN 150# RF A182-F304 SCH ASME B16.5	140S BORE 2	S1P1/FRWN-2"	6	F2 G3 B4
後請		ERECTION MATERIALS				S8 C-501
速	PT NO	COMPONENT DESCRIPTION GASKETS	N.S. (INS)	ITEM CODE	QTY	G3 B4 178 2"x2"NS
歸	3	GASKET 150# RF 4.5 MM THICK 3045 WOUND W/GRAPHITE FILLER W/SS3 RING ASME B16.20/B16.5		S1P1/GR-2"	4	CONN. TO V-617/N46A E 104955 N 47000
還	4	STUD BOLT A193 GR.B8 W/ TWO HE HEAVY NUT A194 GR.8 ASME B1.1 B VALVES / IN-LINE ITEMS		S1P1/BS4-5/8"X85I	L 16	EL.+2245 S1P1/VA-2"-4144-E
	5	BALL 150# RF A351-CF8/304SS+PTFI FIRE SAFE WRENCH OPER. ASME B (VOC<100 vppm)		S1P1/VA-2"-4144-E	2	S8 C-501 F2 E 105270 CONN. TO N 46718
	6 7	INSTRUMENTS LEVEL TRANSMITTER 150# RF LT 61 LEVEL GAUGE 150# RF LG 61702	702 2 2		1 1	V-617/N46B EL.+2309 128 F2 E 104955 N 47000
	8	SUPPORTS FLANGE GROUNDING CONDUCTOR	(C-501) 2	MISC/C-501	4	EL.+1350 S8 C-501 G
						E 105553 N 47000 EL.+1287
						G3 B4 \ F 105270 \ \ \(\begin{picture}(5) \\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \
						N 46/18 2"NS/ LEZ EL.+1287
						LT 61702 F2 G3 B4
						√1 2"x2"NS
會簽						
	7					FOR CONSTRUCTION
						JUL. 04, 2025
	-					
						管線編號 TRIM-V617-N46AB-2"-S1P1
		,				□ 管件序號 <1>直管編號 [1] 管段編號 資料庫
	\triangle					操作壓力: 0.05 KG/M² G 操作溫度: -16~38 C 管線等級: S1P1 製 圖 陳怡如 2025.04.21 _會 富台工程股份有限公司 設計壓力: 0.14 KG/M² G 設計溫度: -26~80 C 保溫(冷)等級: 設 計 黃炳富 2025.04.21
++						
	<u>^</u>	2025.07.03 FOR CONSTR 2025.04.21 FOR APPROV			が 原逢明 原逢明 原逢明	試驗基準: Air