| | | FABRICATION MATERIALS | | | | N |
|-----------------------------|-------------|---|---------------|------------------------|-------------------|---|
| | PT NO | COMPONENT DESCRIPTION | N.S. (INS) | ITEM CODE | QTY | |
| 完 | 1 | FLANGES FLANGE SW 150# RF A182-F304 SCH40S BORE ASME B16.5 | 3/4 | S1P4/FRSW-3/4" | 1 | |
| | | ERECTION MATERIALS | | | | |
| 後 | PT NO | COMPONENT DESCRIPTION | N.S. (INS) | ITEM CODE | QTY | |
| | 2 | FITTINGS NIPPLE (L=100MM) TOE(NPT) A312-TP304 SMLS | 3/4 | S1P4/NIP-3/4"X100LXTOE | 1 | |
| 速 | 3 | SCH80S ASME B36.19M CAP 3000# SCRD (FNPT) A182-F304 ASME B16.11 GASKETS | 3/4 | S1P4/CT-3/4" | 1 | |
| 歸還 | 4 | GASKET 150# RF 3.0 MM THICK VIRGIN PTFE ZW#7500 ASME B16.21/B16.5 | 3/4 | S1P4/GR-3/4"-ZW#7500 | 2 | |
| | 5 | BOLTS STUD BOLT A193 GR.B8 W/ TWO HEX. HEAD HEAVY NUT A194 GR.8 ASME B1.1 B18.2.2 | 1/2 | S1P4/BS4-1/2"X65L | 8 | |
| | 6 | VALVES / IN-LINE ITEMS BALL 150# RF A351-CF8/304SS+PTFE FULL PORT | 3/4 | S1P4/VA-3/4"-4144-E | 1 | |
| | | FIRE SAFE WRENCH OPER. ASME B16.34 (VOC<100 vppm) SUPPORTS | | | • | |
| | 7 | FLANGE GROUNDING CONDUCTOR (C-401) | 3/4 | MISC/C-401 | 2 | VENT EL.+1345 |
| | | | | | | 2 2 105 S7 C-401 |
| | | | | | | 1 117 F1 G4 B5 EL.+1237 |
| | | | | | | G4 B5 CONN. TO |
| | | | | | | S7 / STR-10102./V E 23200 N 33217 |
| | | | | | | EL.+1117 6 S1P4/VA-3/4"-4144-E |
| | | | | | | 31F4/VA-3/4 -4144-L |
| | - | | | | | |
| | _ | | | | | |
| ♦ ₩ | _ | | | | | |
| 全 会 分 配 人 | _ | | | | | FOR CONSTRUCTION |
| | _ | | | | | JUL. 04, 2025 |
| | | | | | | 00L: 04, 2020 |
| | | | | | | 管線編號 |
| | _ | | | | | TRIM-STR10102-V-3/4"-S1P4 ① 管件序號 <1>直管編號 [1] 管段編號 [3] 管段編號 [3] 管段編號 [4] 管科庫. 工廠焊接 套焊 螺紋銜接 配合現場焊接 配合現場接 配合現場 表現 本 表現 |
| | | | | | | & 須設計會驗管線 |
| | \triangle | | | | | 設計壓力: 3.5 KS/ _{M²} G 設計溫度: 80 C 保溫(冷)等級: |
| | \triangle | 2025 07 02 FOR CONCERNATION | | * 本 = | 庙 & 中 | 試驗基準: Air 3.85 KC |
| | <u>♪</u> | 2025.07.03 FOR CONSTRUCTION | | 黃炳富 修 改 | 陳逢明 認 可 | 管路塗装: 管 で 水 塗 装 |
| | 1,4 //\ | - 701 12 W | | 12 6/1 | un 1 | <u> </u> |