	-	FABRICATION	I MATERIALS				N
	- 11	PT COMPONENT D		NS	ITEM CODE	OTY	_≫ ^N
	- 11	NO FLANGES	SECONI HON	N.S. (INS)	TEM CODE	QTY	
	뒨		0# RF A182-F304 SCH40S BORE	1	S1P4/FRSW-1"	1	
		ERECTION MA	ATEDIAI C				
1/2	- 11	PT COMPONENT D		N C	ITEM CODE	QTY	
		NO	DESCRIPTION	N.S. (INS)	TEW CODE	<u>QIT</u>	
	- 11	2 NIPPLE (L=100I	MM) TOE(NPT) A312-TP304 SMLS	1	S1P4/NIP-1"X100LXTOE	1	
泛	- 11		RD (FNPT) A182-F304 ASME B16.11	1	S1P4/CT-1"	1	
記			RF 3.0 MM THICK VIRGIN PTFE	1	S1P4/GR-1"-ZW#7500	2	
75		ZW#7500 ASME BOLTS	E B16.21/B16.5				
			93 GR.B8 W/ TWO HEX. HEAD 94 GR.8 ASME B1.1 B18.2.2	1/2	S1P4/BS4-1/2"X65L	8	
		VALVES / IN-LINI	E ITEMS				404
			A351-CF8/304SS+PTFE FULL PORT ENCH OPER. ASME B16.34	1	S1P4/VA-1"-4144-E	1	DRAIN (2) 104
		SUPPORTS	,				3 168 2
		7 FLANGE GROU	INDING CONDUCTOR (C-401)	1	MISC/C-401	2	F1 G4 B5 H G4 B5 6
							S1P4/VA-1"-4144-E
							45° C-401
							S7 / / C-401 /
							CONN. TO / STR-61701./D
							E 104182 N 40208
							EL.+435
	簽						
分配△							FOR CONSTRUCTION
							JUL. 04, 2025
							管線編號 TRIM-STR61701-D-1"-S1P4
							① 管件序號 <1>直管編號 [1] 管段編號 資料庫. 工廠焊接 套焊 螺紋銜接 配合現場焊接 配合現場接合點 管支撑 蒸汽追蹤管 Gdb8oo 鴻勝化學科技股份有限公司
		<u> </u>					& 須設計會驗管線
							操作壓力: 0.9 KS _M ² G 操作溫度: 38 °C 管線等級: S1P4 製 圖 陳怡如 2025.04.21 會
	-	<u>0</u> 2025.07.03	FOR CONSTRUCTION		黄炳富	陳逢明	試驗基準: Air
	4	<u>A</u> 2025.04.21	FOR APPROVAL		黃炳富	陳逢明	管路塗装: 管
	F	予次 日期	修 改	説 明	修改	認可	操語: