	-	FABRICATION MATERIALS				N	
居回	PT NO		N.S. [1]	TEM CODE	QTY		12.5.3.01=10
] - 1	PIPE A312-TP304 EFW SCH40S PE ASME B36.19M	1 S	s1P1/P-1"-40S	0.4M		
1/4	- 2	FITTINGS TEE 3000# SW A182-F304 ASME B16.11	1 x 1 S	S1P1/TS-1"	1		
後記言	11 3	FLANGE SW 150# RF A182-F304 SCH40S BORE ASME B16.5	1 S	31P1/FRSW-1"	3	2	104
	11	ERECTION MATERIALS				1"x1"NS EL.+9046 217 ————————————————————————————————————	
	II PT	COMPONENT DESCRIPTION FITTINGS	N.S. (INS)	TEM CODE	QTY	CONT. FROM	
漫	11	NIPPLE (L=100MM) TOE(NPT) A312-TP304 SMLS SCH80S ASME B36.19M CAP 3000# SCRD (FNPT) A182-F304 ASME B16.11		31P1/NIP-1"X100LXTOE	1	(3) (4) F3 G6 B7	45°
	6	GASKETS GASKET 150# RF 4.5 MM THICK 304SS SPIRAL	1 S	51P1/GR-1"	3	126	F3 G6 B7
		WOUND W/GRAPHITE FILLER W/SS304 OUTER RING ASME B16.20/B16.5				w ²	_8 S1P1/VA-1"-4144 VALVE STEM W 45 N VENT
	7	STUD BOLT A193 GR.B8 W/ TWO HEX. HEAD HEAVY NUT A194 GR.8 ASME B1.1 B18.2.2	1/2 S	1P1/BS4-1/2"X65L	12	SNIII-	VENT
	8	VALVES / IN-LINE ITEMS BALL 150# RF A351-CF8/304SS+PTFE FULL PORT FIRE SAFE WRENCH OPER. ASME B16.34	1 S	31P1/VA-1"-4144	2		
		> 194 1				EL.+8915 127 8 S1P1/VA-1"-4144 DRAIN CONT. FROM 1	4
分配 //						FOR CONS	STRUCTION
						JUL. (04, 2025
						管線編號 ICW-15313-	-3"-S1P1-C40
							券化學科技股份有限公司 hine Advanced Chemicals Ltd.
	\wedge	<u> </u>				操作壓力: 6.1 KG/Kg 操作溫度: 12 C 管線等級: S1P1 製 圖 陳郁惟 2025.04.21 🚖 富台	工程股份有限公司 N ENGINEERING CO., LTD.
	\bigcirc	2025.07.03 FOR CONSTRUCTION		陳至鉉	—————————————————————————————————————	B 対験 其注・Air 10.67 KG/ 2.C V / O 分 執护 ※ Y 2.C V / O 分 執	管線工程 2
	Â			陳至鉉	陳逢明		立體配管圖 2
	序》		說 明	修改	認可	→ 1 10 May (√), M3 ·	