		FABRICATION MATERIALS				_→ ^N 流水號:1029
	PT NO	COMPONENT DESCRIPTION	N.S.	ITEM CODE	QTY	がL小流、IUZ9
	NO NO	FITTINGS	(INS)			
元	1	REDUCING TEE BW A403-WP304 SMLS SCH40S ASME B16.9	2 x 1	S1P4/TB-2"X1"	1	
	2		1 x 3/4	S1P4/SC-1"PX3/4"T	1	
後	3	FLANGES FLANGE WN 150# RF A182-F304 SCH40S BORE ASME B16.5	2	S1P4/FRWN-2"	2	
		ERECTION MATERIALS				
速	PT NO	COMPONENT DESCRIPTION	N.S. (INS)	ITEM CODE	QTY	
記冊		GASKETS				
還	4	GASKET 150# RF 3.0 MM THICK VIRGIN PTFE ZW#7500 ASME B16.21/B16.5 BOLTS	2	S1P4/GR-2"-ZW#7500	2	
	5	STUD BOLT A193 GR.B8 W/TWO HEX. HEAD HEAVY NUT A194 GR.8 ASME B1.1 B18.2.2	5/8	S1P4/BS4-5/8"X85L	8	T PT
		VALVES / IN-LINE ITEMS				EL.+7741 13201
	6	GATE 150# RF A351-CF8 BB OS &Y RS TRIM 304SS STELLITED FLEXIBLE WEDGE API-600	2	S1P4/VA-2"-1144	1	F3 1 2"x1"NS
	7	PRESSURE INSTRUMENT 150# RF PT 13201	2		1	89 EL.+7613
	,	THEOGOTE MOTHOWENT 100% NOT TO 10201	_		·	2 1"x3/4"NS
						EL.+7482
						G4 B5 6
						CONN. TO S1P4/VA-2"-1144 PW-132/N38
						E 23244 N 89275
						EL.+7301
分配 /						
						FOR CONSTRUCTION
						JUL. 04, 2025
						管線編號
						TRIM-PW132-N38-2"-S1P4
						① 管件序號 <1>直管編號 [1] 管段編號 資料庫.
		ı				C. ALVAII E SALE PAR
	\triangle					操作壓力: 5.3 K _{CM} ² G 操作溫度: 30 °C 管線等級: S1P4 製 圖 陳郁惟 2025.04.21 會 富台工程股份有限公司 設計壓力: 8.5 K _{CM} ² G 設計溫度: 70 °C 保溫(冷)等級: 設 計 陳郁惟 2025.04.21
	\triangle					
	<u>ô</u>	2025.07.03 FOR CONSTRUCTION		陳郁惟	陳逢明	試驗基準: Air 9.35 KC
	Â	2025.04.21 FOR APPROVAL	±A ==□	陳郁惟	陳逢明	管路塗装: 管
	序次	日 期 修 改	說 明	修改	認可	焊道: