


本圖完工後請速歸還

流水號:992

FABRICATION MATERIALS				
PT NO	COMPONENT DESCRIPTION	N.S. (INS)	ITEM CODE	QTY
PIPE				
1	PIPE A312-TP304 EFW SCH40S BE ASME B36.19M	2	S1P4/P-2"-40S	0.2M
FITTINGS				
2	90 ELBOW LR BW A403-WP304 SMLS SCH40S ASME B16.9	2	S1P4/EB-2"X90	2
FLANGES				
3	FLANGE WN 150# RF A182-F304 SCH40S BORE ASME B16.5	2	S1P4/FRWN-2"	4
ERECTION MATERIALS				
PT NO	COMPONENT DESCRIPTION	N.S. (INS)	ITEM CODE	QTY
GASKETS				
4	GASKET 150# RF 4.5 MM THICK 304SS SPIRAL WOUND W/GRAPHITE FILLER W/SS304 OUTER RING ASME B16.20/B16.5	2	S1P4/GR-2"	4
BOLTS				
5	STUD BOLT A193 GR.B8 W/ TWO HEX. HEAD HEAVY NUT A194 GR.8 ASME B1.1 B18.2.2	5/8	S1P4/BS4-5/8"X85L	16
VALVES / IN-LINE ITEMS				
6	GATE 150# RF A351-CF8 BB OS &Y RS TRIM 304SS STELLITED FLEXIBLE WEDGE API-600 (VOC<100 vppm)	2	S1P4/VA-2"-1144-E	2
INSTRUMENTS				
7	LEVEL GAUGE 150# RF LG 21321	2		1
SUPPORTS				
8	FLANGE GROUNDING CONDUCTOR (C-501)	2	MISC/C-501	4

CUT PIPE LENGTH FOR REFERENCE ONLY							
PIECE NO	CUT LENGTH	N.S. (INS)	REMARKS	PIECE NO	CUT LENGTH	N.S. (INS)	REMARKS
<1>	150	2					



REVISED  
FOR CONSTRUCTION

SEP. 12, 2025

管線編號 TRIM-D2131-N45AB-2"-S1P4	
E-shine 鴻勝化學科技股份有限公司 E-shine Advanced Chemicals Ltd.	
富台工程股份有限公司 FU-TAI ENGINEERING CO., LTD.	
審尾一期 建廠工程	管線工程 立體配管圖
檔號: TRIM-D2131-N45AB-S1P4- 1	

△							
①	2025.09.12	REVISED FOR CONSTRUCTION	鄧基宏	陳逢明			
②	2025.07.03	FOR CONSTRUCTION	鄧基宏	陳逢明			
③	2025.04.21	FOR APPROVAL	鄧基宏	陳逢明			
序次	日期	修改說明	修改	認可			

① 管件序號 <1> 直管編號 [1] 管段編號 & 須設計會驗管線		資料庫名稱:	工廠焊接 套焊 螺紋銜接 配合現場焊接 配合現場接合點 管支撐 蒸汽追蹤管	
操作壓力: 0.05~0.6 $\frac{KG}{CM^2}$ G	操作溫度: AMB~152℃	管線等級: C1P1	製圖: 謝鳳菁	2025.04.21
設計壓力: 3.5 $\frac{KG}{CM^2}$ G	設計溫度: 200℃	保溫(冷)等級:	設計: 鄧基宏	2025.04.21
試驗基準: Air	3.85 $\frac{KG}{CM^2}$ G X 60 分	熱追蹤等級:	審核: 陳安誠	2025.04.21
管路塗裝:	管支撐 管材料塗裝	焊接基準:	認可: 陳逢明	2025.04.21
焊道: 塗裝:	碳鋼及不銹鋼保溫(冷): 不銹鋼	NDE 抽驗: 10 %	依據圖號: C2418-4-507	圖號: