		FABRICATION MATERIALS				N	流水號:218
	PT NO	COMPONENT DESCRIPTION	N.S. (INS)	ITEM CODE	QTY	CONT. ON 2	711/3/\day
定	1	PIPE PIPE A312-TP304 EFW SCH10S BE CNS 6331	3	S1P1F/P-3"-10S	9.9M	EL.+6509 3"NS	
	2	FITTINGS 90 ELBOW LR BW A403-WP304 WELD SCH10S ASME B16.9	3	S1P1F/EB-3"X90	6	114	
後 請	3	FLANGES FLANGE WN 150# RF A182-F304 SCH10S BORE ASME B16.5	3	S1P1F/FRWN-3"	1	3 ₁₀₀ S9 S1	
		ERECTION MATERIALS				\$10	
歸	PT NO	COMPONENT DESCRIPTION	N.S. (INS)	ITEM CODE	QTY	G5-1 (1) O58	
還	4	GASKETS GASKET 150# RF 4.5 MM THICK 304SS SPIRAL WOUND WIGRAPHITE FILLER W/SS304 OUTER RING ASME B16.20/B16.5	3	S1P1F/GR-3"	4	<5>1 (5) (2)	
	5	BOLTS STUD BOLT A193 GR.B8 W/ TWO HEX. HEAD HEAVY NUT A194 GR.8 ASME B1.1 B18.2.2	5/8	S1P1F/BS4-5/8"X95L	16	S10 SRP-3 2585 47 1	
	6	VALVES / IN-LINE ITEMS GATE 150# RF A351-CF8 BB OS &Y RS TRIM 304SS	3	S1P1F/VA-3"-1144	2	2 EL.+5545 500 S8 S8 FS14-1-10	
	7	STELLITED FLEXIBLE WEDGE API-600 INSTRUMENTS DELUGE VALVE 150# RF (BY OTHER) BDV 618	3		1	500 S9 FS14-1-10 S1	
	8	SUPPORTS FIELD SUPPORT (FS14-1-10)	3	SUP/FS14-1-3"	2	S10 SRP-3 EL.+4145	
	9 10 11	PIPE SHOE (S1) SUPPORT REINFORCING PAD (SRP-3) PIPE GUIDE (G5-1)	3 3 3	SUP/S1-3" SUP/SRP-3" SUP/G5-1-3"	3 3 1	₩ <u>S9</u> 500 (3) (3) (1>1	
	PIEC	CUT PIPE LENGTH FOR REFERENCE ONLY E CUT N.S. REMARKS PIECE	CUT N	N.S. REMARKS		(a) (b) (c) (c) (c) (c) (c) (c) (c) (c) (c) (c	
	NO <1> <3> <5>	LENGTH (INS) NO 2034 3 <2> 1172 3 <4> 622 3 <6>	772 2357	(INS) 3 3 3		S8	
						6 S1P1F/VA-3"-1144 203 EL.+1922	
						G4 B5 230 EL.+1715 EL.+1480 G4 B5 203	
						6 S1P1F/VA-3"-1144 BDV 618 HOLD!	
<u></u>						CONT. ON FW-90301-6"-C1A1	
						FOR CONSTRUCTION	
						JUL. 15, 2025	
						管線編號 FW-914EC	8-3"-S1P1F
				I	I	& 須設計會驗管線	勝化學科技股份有限公司 shine Advanced Chemicals Ltd.
						設計壓力: 12.3 K½ _{M²} G 設計溫度: 60 (保溫(冷)等級:	工程股份有限公司 FAI ENGINEERING CO., LTD.
	<u> </u>	2025.07.15 FOR CONSTRUCTION 2025.04.21 FOR APPROVAL		陳至鉉 陳至鉉	陳逢明 陳逢明	試驗基準: Water	管線工程 1 立體配管圖 4
	序次		說 明	除主监 修 改	認可	T W T W T W T T T T	4E08-S1P1F- 1