

138KV GIS 365 DAYS PM FORM

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____ PM Cycle: 365 Days

No	PM Item	Standard	Result	Comment
1	GIS Room Environment	1. Check A/C & lights condition	PASS ☐ Abnormal ☐	
		2. Temp: 65-80°F, Humidity: <65%	PASS ☐ Abnormal ☐ Temp: _____ Humidity: _____	
		3. Check for dust, water, smoke, corrosion, cracks or inflammable vapors	PASS ☐ Abnormal ☐	
		4. Check fireproofing and wall seals	PASS ☐ Abnormal ☐	
2	Circuit Breaker	1. Check for abnormal noise, dust, water, smoke, corrosion, cracks, signs of arcing, burning, melting or discoloration	PASS ☐ Abnormal ☐	
		2. Check gauges	PASS ☐ Abnormal ☐	
		3. Check switches	PASS ☐ Abnormal ☐	
		4. Check indicator	PASS ☐ Abnormal ☐	
		5. Check labels, signs	PASS ☐ Abnormal ☐	
		6. Check operating mechanism heater	PASS ☐ Abnormal ☐	
		7. Check cable and conduit entry seals	PASS ☐ Abnormal ☐	
		8. Check operations counter	PASS ☐ Abnormal ☐ Counter: _____	
3	Disconnecter earthing switch	1. Check for abnormal noise, dust, water, smoke, corrosion, cracks, signs of arcing, burning, melting or discoloration	PASS ☐ Abnormal ☐	
		2. Check gauges	PASS ☐ Abnormal ☐	
		3. Check indicator	PASS ☐ Abnormal ☐	
		4. Check labels, signs	PASS ☐ Abnormal ☐	

4	Make-proof earthing switch	1. Check for abnormal noise, dust, water, smoke, corrosion, cracks, signs of arcing, burning, melting or discoloration	PASS ☐ Abnormal ☐	
		2. Check gauges	PASS ☐ Abnormal ☐	
		3. Check indicator	PASS ☐ Abnormal ☐	
		4. Check labels, signs	PASS ☐ Abnormal ☐	
5	Grounding Test	Grounding wire test (resistance < 5 Ω)	PASS ☐ Abnormal ☐	
6	Complete PM	1. THM check	PASS ☐ Abnormal ☐	
		2. Close the cabinet and door	PASS ☐ Abnormal ☐	

- PM Result: PASS ✓ Abnormal X; Abnormal condition can explain in comment
- Make sure to record all the PM result and follow the SOP standard
- Only record if ΔT higher than 4° C (7.2 ° F), Follow NEMA Standard Table 100.18

Rev. 0

Review By:_____

Inspect By:_____