

CABLE 90 DAYS PM FORM

Cable#: _____

Unit: _____

WO# _____

Date: _____

PM Cycle: 90 Days

	PM Item	Standard	Result	Comment
1	Label (cable)	1. Labeled every 150Ft by nameplate with cable number	PASS ☐ Abnormal ☐	
		2. If there is a splice, labeled 50Ft before and after the splice	PASS ☐ Abnormal ☐	
		3. The location where enter and exit the cable tray	PASS ☐ Abnormal ☐	
		4. The location where different cable tray connected	PASS ☐ Abnormal ☐	
2	Label (cable tray)	1. Labeled on side of cable tray if there is a cable splice	PASS ☐ Abnormal ☐	
		2. The label should include circuit number, departure and arrival units	PASS ☐ Abnormal ☐	
3	Condition Check	1. Visual check on cable (Obvious Crack, Sign of arc flash)	PASS ☐ Abnormal ☐	
		2. Visual check on cable tray (Rusting, Deformation, Falling off, Damage, Chemical Liquid on tray, Foreign item attached on tray)	PASS ☐ Abnormal ☐	
		3. Visual check on termination kit and cable splice (Abnormal sound, Sign of arc flash, Crack, Discolor, Damage)	PASS ☐ Abnormal ☐	
		*cable splice requires picture for each one		

Action:

Engineer: _____

Inspect By: _____