

CABLE SPLICES 180 DAYS PM FORM

Cable#: _____ Unit: _____ WO# _____ Date: _____ PM Cycle: 180 Days

	PM Item	Standard	Result	Comment
1	Splices Note: Only check cable splices with voltage level above 5kV	1. PD (e.g., PD74i)	PASS ☐ Abnormal ☐ N/A ☐	
		2. IR scan (e.g., FLIR)	PASS ☐ Abnormal ☐	
		3. Ultrasound (e.g., FLUKE)	PASS ☐ Abnormal ☐	

Action: