

DC CHARGER 90 DAYS PM FORM

For Lead-Acid Battery Only

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____ PM Cycle: 90 Days

Unit		PM Item	Standard	Result	Comment
DC Charger	1	Grounding	1. No loose or broken wires	PASS ☐ Abnormal ☐	
			2. IR scan → no abnormal	PASS ☐ Abnormal ☐	
			3. Ground resistance < 5 Ω	_____ Ω	
Battery (Lead-acid)	1	Battery rack grounding	No loose or broken wires, < 5 Ω	PASS ☐ Abnormal ☐	
	2	Battery breakers IR scan	No abnormal temp	PASS ☐ Abnormal ☐	
	3	Battery IR scan	No abnormal temp	PASS ☐ Abnormal ☐	
	4	Battery Test	1.Voltage(2.2V/cell) (Fluke BT521 screen pass)	PASS ☐ Abnormal ☐	
	5		2.Internal Res (Fluke BT521 screen pass)	PASS ☐ Abnormal ☐	
	6		3.Intercell Res (Fluke BT521 screen pass)	PASS ☐ Abnormal ☐	
	7	Specific gravity test	1.Use DMA35	PASS ☐ Abnormal ☐	
*Fluke BT521 need to be setting at first time.					

Action:

Rev. 0.

Engineer Review By: _____ Supervisor Review: _____ Inspect By: _____

DC CHARGER 90 DAYS PM FORM

For Lithium Battery Only

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____ PM Cycle: 90 Days

Unit		PM Item	Standard	Result	Comment
DC Charger	1	Grounding	1. No loose or broken wires	PASS ☐ Abnormal ☐	
			2. IR scan → no abnormal	PASS ☐ Abnormal ☐	
			3. Ground resistance < 5 Ω	_____ Ω	
Battery Breaker Panel	1	IR scan via back side	1. All breakers no abnormal temp	PASS ☐ Abnormal ☐	
			2. All connection no abnormal temp	PASS ☐ Abnormal ☐	
			3. All buses no abnormal temp	PASS ☐ Abnormal ☐	
	2	IR scan front	1. Rect input no abnormal temp	PASS ☐ Abnormal ☐	
			2. Res input no abnormal temp	PASS ☐ Abnormal ☐	
	3	Grounding	1. No loose or broken wires	PASS ☐ Abnormal ☐	
			2. IR scan → no abnormal	PASS ☐ Abnormal ☐	
			3. Ground resistance < 5 Ω	_____ Ω	
	4	Control compartment IR scan	No overheat, no burn	PASS ☐ Abnormal ☐	
Battery	1	Battery rack grounding	No loose or broken wires, < 5 Ω	PASS ☐ Abnormal ☐	
	2	Battery Terminal inspection	No sign of overheat	PASS ☐ Abnormal ☐	
	3	Battery breakers IR scan	no abnormal temp	PASS ☐ Abnormal ☐	
	4	BMS module (include battery)	No dust, no loose connection	PASS ☐ Abnormal ☐	

Action:

Rev. 0.

Engineer Review By: _____ Supervisor Review: _____ Inspect By: _____