

DC Motor 365 DAYS PM CHECKLIST

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____ PM Cycle: 365 Days

EQ	PM Item	Standard	Result	Comment
Motor	1 Appearance	No rust, no damage, no contamination, nameplate legible.	PASS ☐ Abnormal ☐	
	2 Guards for Rotating Parts	No looseness, no damage, no missing guards	PASS ☐ Abnormal ☐	
	3 Grounding	1. Grounding wire connect to ground terminal on the motor frame, cannot connect to terminal box, fan cover or foundation bolt. 2. Grounding wire firmly connected, no looseness.	PASS ☐ Abnormal ☐	
	4 Accessories	No damage; indicators show no abnormalities	PASS ☐ Abnormal ☐	
	5 Terminal Box & Conduit	No looseness or damage; no water or dust ingress	PASS ☐ Abnormal ☐	
	6 Bearing Temperature	No abnormal high temperature (for units equipped with temperature indicator)	PASS ☐ Abnormal ☐	
	7 Carbon brush sparks	No spark on the contact surface between the carbon brush and the commutator segment	PASS ☐ Abnormal ☐	
	8 Carbon brush cover	Intact, no deformation, no damage	PASS ☐ Abnormal ☐	
	9 Carbon brush contact	Good elasticity and sealed contact surface	PASS ☐ Abnormal ☐	
	10 Explosion-Proof Rating Check	1. Body undamaged and not deformed. 2. Conduits and cable terminations tight and undamaged; sealing compound intact. 3. Explosion-Proof related parts meet requirements and working normally.	PASS ☐ Abnormal ☐	
	11 SWGR PM Inspection Checklist	Complete "SWGR PM Inspection Checklist"	YES ☐ NO ☐	
Lubrication System	1 Automatic Grease Feeder	Operating normally, oil level drops normally	PASS ☐ Abnormal ☐	
	2 Grease Outlet	Grease discharge normal at outlet; waste-grease collector working normally without grease contamination	PASS ☐ Abnormal ☐	
Cooling System	1 Cooling Fan	Fan grille clean, unobstructed	PASS ☐ Abnormal ☐	

MISC	1	Abnormal Odor	No odor	PASS ☐ Abnormal ☐	
	2	Abnormal Noise	No abnormal noise	PASS ☐ Abnormal ☐	
	3	Abnormal Vibration	No abnormal vibration	PASS ☐ Abnormal ☐	
	4	Motor Body Temperature	Normal temperature, no overheating (for units with temperature indicator)	PASS ☐ Abnormal ☐	

Reviewed By:_____

Inspected By:_____