

LBS 90 DAY PM FORM

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____ PM Cycle: 90 Days

No	PM Item	Standard	Result	Comment
1	LBS Checkup	1. Check for abnormal noise, dust, water, smoke, corrosion, cracks or inflammable vapors	PASS ☐ Abnormal ☐	
		2. Check gauges/meter	PASS ☐ Abnormal ☐	
		3. Check switches	PASS ☐ Abnormal ☐	
		4. Check wire and conduit entry seals	PASS ☐ Abnormal ☐	
		5. Check indication lights	PASS ☐ Abnormal ☐	
		6. Ground resistance < 5 Ω	PASS ☐ Abnormal ☐	
		7. Visually check that door locks, interlocks, and safety warning labels are intact and not damaged.	PASS ☐ Abnormal ☐	
2	CBM (Condition Based Maintenance)	1. IR Scan (Fuse, main contacts, cable terminal, TR bushing)	PASS ☐ Abnormal ☐	
		2. PD Testing	PASS ☐ Abnormal ☐	

Action: