

LV SWGR 365 DAYS PM CHECKLIST

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____ PM Cycle: 365 Days

No	PM Item	Standard	Result	Comment
1	MCC Room Environment	1. Check A/C & lights condition	PASS ☐ Abnormal ☐	
		2. Temp: 65-80°F, Humidity: <65%	PASS ☐ Abnormal ☐ Temp: _____ Humidity: _____	
		3. Check for dust, water, smoke, corrosion, cracks or inflammable vapors	PASS ☐ Abnormal ☐	
		4. Check fireproofing and wall seals, cable entry seals, verify no signs of animal intrusion	PASS ☐ Abnormal ☐	
2	Panel Visual Inspection	1. Check for abnormal noise, odor, dust, water, smoke, corrosion, cracks, signs of arcing, burning, melting or discoloration	PASS ☐ Abnormal ☐	
		2. Check meter	PASS ☐ Abnormal ☐	
		3. Check indication light	PASS ☐ Abnormal ☐	
		4. Check switch handle position	PASS ☐ Abnormal ☐	
		5. Check arc flash label up to date	PASS ☐ Abnormal ☐	
3	Complete PM	1. THM check	PASS ☐ Abnormal ☐	
		2. Close the cabinet and door	PASS ☐ Abnormal ☐	

- PM Result: PASS ✓ Abnormal X; Abnormal condition can explain in comment
- Make sure to record all the PM result and follow the SOP standard
- Only record if ΔT higher than 4° C (7.2 ° F), Follow NEMA Standard Table 100.18