

UPS 45 DAYS PM FORM

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____ PM Cycle: 45 Days

	PM Item	Standard	Result	Comment
1	UPS Environment	1. Temp: 65-80°F, Humidity: < 65%	PASS ☐ Abnormal ☐ Temp: _____ Humidity: _____	
		2. Lights & A/C all working	PASS ☐ Abnormal ☐	
		3. All cables or conduit entry sealed	PASS ☐ Abnormal ☐	
2	Operation condition	No abnormal noise, vibration & corrosion	PASS ☐ Abnormal ☐	
3	LCD Display	No abnormal, all lights working	PASS ☐ Abnormal ☐	
4	UPS LCD Rectifier input	V: within 576V – 384V (480V +/- 20%) A: <175A	U V : _____ V , _____ A V W : _____ V , _____ A W U : _____ V , _____ A	
5	UPS LCD Battery voltage check	Float charge = 405V, Battery capacity = 100%	PASS ☐ Abnormal ☐	
6	UPS LCD invert output voltage	V: 120V/208V (+/- 1%) (CWTP:480/280)	R : _____ V , _____ V S : _____ V , _____ V T : _____ V , _____ V	
7	UPS LCD output loading	A: < 278A each phase	R : _____ % , _____ A S : _____ % , _____ A T : _____ % , _____ A	
8	UPS LCD output KVA	< 80KVA, PF > 0.8	R: _____ kva, _____ kw, PF: _____ S: _____ kva, _____ kw, PF: _____ T: _____ kva, _____ kw, PF: _____	
9	UPS LCD Bypass voltage	120V/ 208V (+/- 1%) (CWTP:480/280)	R : _____ V , _____ V S : _____ V , _____ V T : _____ V , _____ V	
10	Fan	No abnormal noise, no dust, and all working	PASS ☐ Abnormal ☐	
11	UPS enclosure	All seal good, no corrosion	PASS ☐ Abnormal ☐	
12	UPS LCD Temp check	Normal, below 40°C	Rect: _____ Invert: _____ UPS: _____	

13	Via inspect window check Cap & control boards	No leak, No burn, Cap in good condition	PASS ☐ Abnormal ☐	
14	UPS Event log	Report abnormal event/alarm	PASS ☐ Abnormal ☐	

Action:

Supervisor Review By: _____ **Inspected By:** _____

UPS BATTERY 45 DAYS PM FORM

For Lithium Battery Only

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____

PM Cycle: 45 Days

Unit		PM Item	Standard	Result	Comment
Battery Breaker Panel	1	Operation condition	1. No abnormal noise 2. No abnormal vibration 3. No corrosion	PASS ☐ Abnormal ☐	
	2	Breakers	No abnormal, No corrosion	PASS ☐ Abnormal ☐	
	3	Panel condition	All seal good, no corrosion & water	PASS ☐ Abnormal ☐	
	4	Control compartment IR scan	No overheat, no burn	PASS ☐ Abnormal ☐	
Battery	1	Battery Environment	A/C working, no leaks	PASS ☐ Abnormal ☐	
	2	Battery condition	No dust, crack, expansion & corrosion	PASS ☐ Abnormal ☐	
	3	BMS HMI	All batteries no alarm	PASS ☐ Abnormal ☐	
	4	Total voltage	405V +/- 2V	_____ V	
	5	HMI screenshot for each cell	Attach all pic	PASS ☐ Abnormal ☐	

Action:

Supervisor Reviewed By: _____

Inspected By: _____

UPS BATTERY 45 DAYS PM FORM

For Lead-Acid Battery Only

EQ#: _____ Unit: _____ SN# _____ WO# _____ Date: _____

PM Cycle: 45 Days

Unit		PM Item	Standard	Result	Comment
Battery Breaker Panel	1	Operation condition	1. No abnormal noise 2. No abnormal vibration 3. No corrosion	PASS ☐ Abnormal ☐	
	2	Breakers	No abnormal, No corrosion	PASS ☐ Abnormal ☐	
	3	Panel condition	All seal good, no corrosion & water	PASS ☐ Abnormal ☐	
	4	Control compartment IR scan	No overheat, no burn	PASS ☐ Abnormal ☐	
Battery	1	Battery Environment	A/C working, no leaks	PASS ☐ Abnormal ☐	
	2	Battery condition	No dust, crack, expansion & corrosion	PASS ☐ Abnormal ☐	

Action:

Rev. 0.

Supervisor Reviewed By: _____

Inspected By: _____