Drinking Water Exceedance Alert

NETLAB Work Order Number: 3D18082
Client: WhiteWater
Client Project: Corn Hill Condominiums

Notification Date: 27-April-2023

This is a preliminary report intended to advise the client that results associated with a drinking water submission exceed established limits. The following table presents analyses performed on samples within the submission as of the notification date. Entries only occur when an analyte's concentration exceeds limits in one or more samples in the submission. The custody record for the submission is attached.

Note: Nitrate results (limit 10 mg/L) that are greater than or equal to 5 mg/L are commented in this report.

New England Testing Laboratory, Inc.

Case Number: 3D18082

Report Date: 4/27/2023

Project: Corn Hill Condominiums
PWS ID: 4300027

LabNumber: 3D18082-01 LOC ID: 10002 Location: WELL # 1 & 2
Date Sampled: 04/26/23

Analyte	Result	Units	Limit
Manganese	**0.307**	**mg/L**	**0.05**

WATEI

3 D 1 8082 !

253B Worcester Road, Charlton MA 01507 Phone: (888) 377-7678 Fax: (508) 248-2895

- [x] ROUTINE SAMPLE
- [ ] SPECIAL SAMPLE
- [ ] REPEAT SAMPLE
- [ ] WAF SAMPLE
- [ ] 24 HR RUSH?
- [ ] PRESEASON SAMPLE

PWS ID #: 4300027 **PWS CLASS:** TNC **JOB/SO #:**

PWS NAME: Corn Hill Condominiums

PWS ADDRESS: 62 Corn Hill Road, Truro, MA 02666

PWS PHONE #:

DATE COLLECTED: 4/18/23

Is the source treated? YES (NO)

Sample after treatment? YES (NO)

SPECIAL NOTES:
Quarterly Chemistry Q2 2023

METER READINGS: Cu Ft. or Gal

LOCATION CODE	SAMPLE LOCATION	SAMPLE TYPE	TIME	CHLORINE RESIDUAL	Mn					NOTES (# of Bottles)
10002	Well # 1 & 2	Finish	10:59		✓					

Custody Transfer	Name & Signature	DATE	TIME
Sampler:	Chris Sullivan	4/18/23	10:30
Relinquished by:		4/18/23	2:17
Received by:		4 18 23	1430
Relinquished by:		↓	1600
Received by:		4-18-23	1600

PLEASE EMAIL THIS REPORT WITH RESULTS & INVOICE TO: ADonnelly@RHWhite.com and CAstephen@RHWhite.com