



BTC ETICKET

TICKET NUMBER

1010088333

CUSTOMER / JOB INFORMATION

Customer / Job Name: Customer
Address: -
Job Number: 29
PO / Reference: -
Date: 05/07/2026
Load Time: 02:02 PM

MIX / TRUCK INFORMATION

Mix #: Concrete
Truck: B-48
Description: Mix
Strength (ASTM C31): -
Slump (ASTM C143): 4.5 in $\pm$ 1.5 in
Air Content (ASTM C231): 1.5% $\pm$ 1.5%

LOAD SIZE
0.0 cys

QTY DELIVERED TOTAL
0.0 cys

ORDER TOTAL
0.0 cys

WEATHER CONDITIONS

Temp: 67.0°F | Feels Like: 67.0°F | Conditions: Partially cloudy | Humidity: 63.11% | Wind: 2.2 mph @ 160.0° | Precip: 0.0 in | Rain Chance: 1.0% | Clouds: 85.0% | Coords: (32.86643, -96.93204)

WATER ALLOWED
25.0 gal

WATER ADDED
18.0 gal


BATCH WEIGHTS

Description	Design	Target	Actual	UOM	% Var	Moisture (%)	Water (gal)
01-Cement	388	3,880	3,940	lb	1.6	-	-
04-Slag	129	1,290	1,310	lb	1.6	-	-
06-Natural Sand	1,400	14,263	14,230	lb	-0.2	3.00	31.46
09-Water	28	230	226	gal	-1.6	-	-
10-#57 Crushed Rock	1,885	18,794	18,760	lb	-0.2	0.50	-6.71
36-SIKA 686 (MRWR)	41	414	414	floz	0.1	0.00	0.00
37-SIKA Air	2	21	21	floz	-0.9	0.00	0.00


CURB LINE SIGNATURE - 05/07/2026 10:12 PM

Customer / Contractor Signature

FINAL SIGNATURE PHOTO



BTC TERMS & CONDITIONS



Scan for terms

FINAL SIGNATURE - 05/07/2026 10:13 PM

Rejected Delivery | Reason: Slump