

Service Completion Report

Date of service rendered: October 8, 2026

This report covers the scheduled inspection of fire extinguishers across all five floors.

Findings and recommendations: 22 of 24 units passed inspection with current pressure gauges in the green zone and valid seals. Two units on the fourth floor were past their recertification date and have been pulled for servicing, with loaner units placed in their mounts in the meantime. All inspection tags were updated with today's date.

Approved By: _____