

39

Total Items

39

Completed

6

Issues Found

1

Add-Ons

Customer Information

Name

Taylor Reed

Email

TaylorReed@gmail.com

Address

8472 Maple Ridge Dr, St. Louis, MO 63129

Technician

Chris Dalton

Date

2026-05-10

Equipment

Service Type: furnace

Brand: Goodman

Model #: GMES800805CN

Serial: 2104F7K91234

Age: 12

Service Type: ac

Brand: Goodman

Model #: GSXH503610

Serial: 2019C3L55678

Age: 12

System Readings

Furnace / Air Handler

Blower Capacitor	7.5
Blower Amps	3.2
Inducer Motor Amps	1.1
Gas Pressure	3.5
Temperature Rise	45
Return Air Temp	70
Supply Air Temp	115

AC / Heat Pump

Outdoor Temp	78
Indoor Wet Bulb	63
Low Side Pressure	136
High Side Pressure	325
Superheat	12
Subcooling	10
Compressor Amps	8.5
Condenser Fan Amps	1.2
Capacitor Herm	45

	Capacitor Fan	5
	Capacitor Common	common

Add-Ons

★ **Compressor blanket**

\$150

Reduce outdoor unit noise by up to 50% and protect your compressor from harsh weather. Extend equipment life while keeping your outdoor space peaceful. Great for units near bedrooms or patios.

General Notes

The flame sensor has light buildup and should be cleaned to help prevent ignition issues or furnace lockouts. The air filter is dirty and should be replaced. A dirty filter can restrict airflow and cause the system to work harder than normal. The blower squirrel cage has some dust buildup. Cleaning is recommended to improve airflow and overall system efficiency. The UV light bulb appears aged and may need replacement soon to maintain proper performance. Airflow appears slightly restricted, likely due to the dirty filter and dust buildup. Recommend replacing the filter and monitoring system performance. The outdoor condenser coil has light debris buildup. Cleaning is recommended to help maintain proper cooling performance and efficiency.

Detailed Inspection Checklist

Issues Found

Inspect Air Filter

Severity 5/10

Notes: Air filter is dirty and should be replaced. A dirty filter can restrict airflow and cause the system to work harder than normal.

Check For Airflow Concerns

Severity 5/10

Notes: Airflow appears slightly restricted, likely due to the dirty air filter and dust buildup. Recommend replacing filter and monitoring system performance.

Inspection Of Squirrel Cage

Severity 4/10

Notes: Squirrel cage has some dust buildup. Recommend cleaning during future service to improve airflow and efficiency.

Inspect UV Light Condition

Severity 4/10

Notes: UV light condition was checked. Bulb appears aged and may need replacement soon for proper performance.

Notes: UV light condition was checked. Bulb appears aged and may need replacement soon for proper performance.

Clean Condenser

Severity 4/10

Notes: Condenser coil has light debris buildup. Recommend cleaning to help maintain proper cooling performance and efficiency.

Inspect Flame Sensor

Severity 3/10

Notes: Flame sensor has light buildup and should be cleaned to help prevent ignition issues or furnace lockouts.

All Checklist Items

Thermostat Check

Completed

Severity 0/10

Notes: Thermostat was checked and operating properly at the time of inspection.

Inspect Flame Sensor

Issue Found

Severity 3/10

Notes: Flame sensor has light buildup and should be cleaned to help prevent ignition issues or furnace lockouts.

Inspect Electrical Components Of Furnace

Completed

Severity 0/10

Notes: Electrical components were inspected and appeared to be operating normally at the time of inspection.

Inspect Flue And Venting

Completed

Severity 0/10

Notes: Flue and venting were inspected and no visible concerns were found.

Carbon Monoxide Test

Completed

Severity 0/10

Notes: Carbon monoxide test was completed and no unsafe levels were detected at the time of inspection.

Check Burner Flame

Completed

Severity 0/10

Notes: Burner flame was checked and appeared normal at the time of inspection.

Inspect Air Filter

Issue Found

Severity 5/10

Notes: Air filter is dirty and should be replaced. A dirty filter can restrict airflow and cause the system to work harder than normal.

Inspect And Clean Interior Coil

Completed

Severity 0/10

Notes: Interior coil was inspected and no major concerns were found at the time of inspection.

Inspection Of Squirrel Cage

Issue Found

Severity 4/10

Inspect Return Duct Condition

Issue Found

Severity 4/10

Notes: Squirrel cage has some dust buildup. Recommend cleaning during future service to improve airflow and efficiency.

Inspect Heat Exchanger

Completed

Severity 0/10

Notes: Heat exchanger was visually inspected and no visible issues were found at the time of inspection.

Inspect Gas Connect For Leaks (Furnace)

Completed

Severity 0/10

Notes: Gas connection was checked and no leak was detected at the time of inspection.

Test Safety Switches

Completed

Severity 0/10

Notes: Safety switches were tested and appeared to be operating properly.

Inspect Duct Connections For Leaks/Disconnects (Visible Areas)

Completed

Severity 0/10

Notes: Visible duct connections were inspected and no major issues were found.

Check Carbon Monoxide Level

Completed

Severity 0/10

Notes: Carbon monoxide level was checked and no unsafe readings were detected.

Inspect Humidifier Condition

Completed

Severity 0/10

Notes: Humidifier condition was inspected and no major concerns were found.

Inspect UV Light Condition

Issue Found

Severity 4/10

Notes: UV light condition was checked. Bulb appears aged and may need replacement soon for proper performance.

Inspect Air Purifier Condition

Completed

Severity 0/10

Notes: Air purifier condition was inspected and no major concerns were found.

Inspect Media Filter Condition

Completed

Severity 0/10

Notes: Media filter condition was inspected and appeared acceptable at the time of inspection.

Check If Germicidal Bulb Needs Replacement

Completed

Severity 0/10

Notes: Germicidal bulb was checked and no immediate replacement was needed at the time of inspection.

Inspect Return Duct Condition

Completed

Severity 0/10

Notes: Return duct condition was inspected and no visible concerns were found.

Inspect Supply Duct Condition

Completed

Severity 0/10

Notes: Supply duct condition was inspected and no visible concerns were found.

Check For Visible Air Leaks At Duct Connections

Completed

Severity 0/10

Notes: Visible duct connections were checked and no major air leaks were found.

Check Filter Rack Seal

Completed

Severity 0/10

Notes: Filter rack seal was inspected and appeared acceptable at the time of inspection.

Check For Airflow Concerns

Issue Found

Severity 5/10

Notes: Airflow appears slightly restricted, likely due to the dirty air filter and dust buildup. Recommend replacing filter and monitoring system performance.

Inspect Electrical Components Of AC Unit

Completed

Severity 0/10

Notes: AC electrical components were inspected and appeared to be operating normally at the time of inspection.

Check Interior Coils And Line Set For Refrigerant Leaks

Completed

Severity 0/10

Notes: Interior coils and line set were inspected and no visible refrigerant leak concerns were found.

Check Exterior Coils And Line Set For Refrigerant Leaks

Completed

Severity 0/10

Notes: Exterior coils and line set were inspected and no visible refrigerant leak concerns were found.

Measure Refrigerant Pressures If Leak Is Suspected

Completed

Severity 0/10

Notes: No refrigerant leak was suspected at the time of inspection.

Clear Condensate Pan Of Debris And Flush Drain

Completed

Severity 0/10

Notes: Condensate pan and drain were checked and no major concerns were found.

Clean Condenser

Issue Found

Severity 4/10

Notes: Condenser coil has light debris buildup. Recommend cleaning to help maintain proper cooling performance and efficiency.

Check Refrigerant Line Insulation

Completed

Severity 0/10

Notes: Refrigerant line insulation was inspected and appeared acceptable at the time of inspection.

Inspect Outdoor Fan/Motor

Completed

Severity 0/10

Notes: Outdoor fan and motor were inspected and appeared to be operating normally at the time of inspection.

Inspect Evaporator Coil Condition

Completed

Severity 0/10

Notes: Evaporator coil condition was inspected and no major concerns were found.

Inspect Primary Condensate Drain

Completed

Severity 0/10

Notes: Primary condensate drain was inspected and appeared acceptable at the time of inspection

Inspect Secondary Condensate Drain

Completed

Severity 0/10

Notes: Secondary condensate drain was inspected and no major concerns were found.

Inspect Drain Safety Switch

Completed

Severity 0/10

Notes: Drain safety switch was inspected and appeared to be operating properly.

Inspect Condensate Drain Pan

Completed

Severity 0/10

Notes: Condensate drain pan was inspected and no major concerns were found.

Inspect TXV Bulb Position And Insulation

Completed

Severity 0/10

Notes: TXV bulb position and insulation were inspected and appeared acceptable.

Add Drain Pan Treatment If Needed

Completed

Severity 0/10

Notes: Drain pan treatment was not needed at the time of inspection.

Completed With No Issues



Thermostat Check

Thermostat was checked and operating properly at the time of inspection.



Inspect Electrical Components Of Furnace

Electrical components were inspected and appeared to be operating normally at the time of inspection.



Inspect Flue And Venting

Flue and venting were inspected and no visible concerns were found.



Carbon Monoxide Test

Carbon monoxide test was completed and no unsafe levels were detected at



Check Burner Flame

Burner flame was checked and appeared normal at the time of



Inspect And Clean Interior Coil

Interior coil was inspected and no major concerns were found at the time

the time of inspection.

inspection.

of inspection.



Inspect Heat Exchanger

Heat exchanger was visually inspected and no visible issues were found at the time of inspection.



Inspect Gas Connect For Leaks (Furnace)

Gas connection was checked and no leak was detected at the time of inspection.



Test Safety Switches

Safety switches were tested and appeared to be operating properly.



Inspect Duct Connections For Leaks/Disconnects (Visible Areas)

Visible duct connections were inspected and no major issues were found.



Check Carbon Monoxide Level

Carbon monoxide level was checked and no unsafe readings were detected.



Inspect Humidifier Condition

Humidifier condition was inspected and no major concerns were found.



Inspect Air Purifier Condition

Air purifier condition was inspected and no major concerns were found.



Inspect Media Filter Condition

Media filter condition was inspected and appeared acceptable at the time of inspection.



Check If Germicidal Bulb Needs Replacement

Germicidal bulb was checked and no immediate replacement was needed at the time of inspection.



Inspect Return Duct Condition

Return duct condition was inspected and no visible concerns were found.



Inspect Supply Duct Condition

Supply duct condition was inspected and no visible concerns were found.



Check For Visible Air Leaks At Duct Connections

Visible duct connections were checked and no major air leaks were found.



Check Filter Rack Seal

Filter rack seal was inspected and appeared acceptable at the time of inspection.



Inspect Electrical Components Of AC Unit

AC electrical components were inspected and appeared to be operating normally at the time of inspection.



Check Interior Coils And Line Set For Refrigerant Leaks

Interior coils and line set were inspected and no visible refrigerant leak concerns were found.



Check Exterior Coils And Line Set For Refrigerant Leaks

Exterior coils and line set were inspected and no visible refrigerant leak concerns were found.



Measure Refrigerant Pressures If Leak Is Suspected

No refrigerant leak was suspected at the time of inspection.



Clear Condensate Pan Of Debris And Flush Drain

Condensate pan and drain were checked and no major concerns were found.



Check Refrigerant Line Insulation

Refrigerant line insulation was inspected and appeared acceptable at the time of inspection.



Inspect Outdoor Fan/Motor

Outdoor fan and motor were inspected and appeared to be operating normally at the time of inspection.



Inspect Evaporator Coil Condition

Evaporator coil condition was inspected and no major concerns were found.



Inspect Primary Condensate Drain

Primary condensate drain was inspected and appeared acceptable at the time of inspection



Inspect Secondary Condensate Drain

Secondary condensate drain was inspected and no major concerns were found.



Inspect Drain Safety Switch

Drain safety switch was inspected and appeared to be operating properly.

**Inspect Condensate Drain Pan**

Condensate drain pan was inspected and no major concerns were found.

**Inspect TXV Bulb Position And Insulation**

TXV bulb position and insulation were inspected and appeared acceptable.

**Add Drain Pan Treatment If Needed**

Drain pan treatment was not needed at the time of inspection.

Not Completed

All items were checked off.