

			ADNOC GAS HABSHAN & BAB CONTROL SYSTEMS UPGRADE (PACKAGE 1) PROJECT NO. 0405323										
			COMMENTS RESOLUTION SHEET										
Document Title:			PIPING & INSTRUMENTATION DIAGRAM FEED GAS COMPRESSOR 1ST STAGE TRAIN 1 EARLY THAMMAMA 'B' (HABSHAN)				AGP Response Code			Prepared By:	CA		
Document No:			13-00-205		Revision No:	B	1. Revise and Re-submit		3. Approved	✓	Checked By:	DV	
AG Ref. No:			ADNOCGP-WTRAN-007160		Date:	23-Aug-2024	2. Approved with comments		4. For Information only		Approved By:	YVR	
SN	Reference		COMPANY Comments				CONSULTANT Response			COMPANY Resolution			
	Page No.	Clause No.											
1	-	-	No Comments				-						
2	1	-					Following changes are made in P&ID w.r.t. Rev.B submission as per piping/instrumentation inputs. 1. Note 12 and 14 updated. 2. Note 24,25,26,27 and 28 added. 3. All PT valve are now updated as flange valve. 4. Existing thermowell TW-5015 & 5017 shown as these thermowells are not used and new thermowell will be installed. 5. New Tie-in number provided for TE-5642C & 5643C for installation of new thermowell. 6. Pipe spec is mentioned for segment in piping scope for FE-1626, TE-5642C and TE-5643C. 7. Tag no. corrected for temperature element (TE-5108), temperature transmitter (TT-5108) and temperature indicator (TI-5108) to TE-5018, TT-5018 and TI-5018 respectively. 8. Tie-in point location for FE-1626 is updated. 9. Cause and effect document no. added in reference list.						

