

			ADNOC GAS HABSHAN & BAB CONTROL SYSTEMS UPGRADE (PACKAGE 1) PROJECT NO. 0405323									
			COMMENTS RESOLUTION SHEET									
Document Title:			PIPING & INSTRUMENTATION DIAGRAM EARLY THAMMAMA 'B' (HABSHAN) THAMMAMA 'B' (HABSHAN) FEED GAS COMPRESSOR 2ND STAGE TRAIN			AGP Response Code			Prepared By:	CA		
Document No:			13-00-206		Revision No:	B	1. Revise and Re-submit	3. Approved	✓	Checked By:	DV	
AG Ref. No:			ADNOCGP-WTRAN-007160		Date:	23-Aug-2024	2. Approved with comments	4. For Information only		Approved By:	YVR	
SN	Reference		COMPANY Comments				CONSULTANT Response			COMPANY Resolution		
	Page No.	Clause No.										
1	-	-	No Comments									
2	1	-					Following changes are made in P&ID w.r.t. Rev.B submission as per piping/instrumentation inputs. 1. Note 14 and 15 updated. 2. Note 24,25,26 and 27 added. 3. All PT valve are now updated as flange valve. 4. Existing thermowell TW-5021 & 5023 shown as these thermowells are not used and new thermowell will be installed. 5. New Tie-in number provided for TE-5644C & 5645C for installation of new thermowell. 6. Pipe spec is mentioned for segment in piping scope for TE-5644C and TE-5645C. 7. Tie-in point location updated for FE-1627. 8. Cause and effect document no. added in reference list.					

