

			ADNOC GAS HABSHAN & BAB CONTROL SYSTEMS UPGRADE (PACKAGE 1) PROJECT NO. 0405323									
			COMMENTS RESOLUTION SHEET									
Document Title:			PIPING & INSTRUMENTATION DIAGRAM FEED GAS COMPRESSOR 1ST STAGE TRAIN 2 EARLY THAMMAMA 'B' (HABSHAN)			AGP Response Code			Prepared By:	CA		
Document No:			13-00-207		Revision No:	B	1. Revise and Re-submit	3. Approved	✓	Checked By:	DV	
AG Ref. No:			ADNOCGP-WTRAN-007160		Date:	23-Aug-2024	2. Approved with comments	4. For Information only		Approved By:	YVR	
SN	Reference		COMPANY Comments				CONSULTANT Response			COMPANY Resolution		
	Page No.	Clause No.										
1	-	-	No Comments									
2	-	-					Following changes are made in P&ID w.r.t. Rev.B submission as per piping/instrumentation inputs. 1. Note 14 and 15 updated. 2. Note 25, 26, 27, 28 and 29 added. 3. All PT valve are now updated as flange valve. 4. Existing thermowell TW-5115 & 5117 shown as these thermowells are not used and new thermowell will be installed. 5. New Tie-in number provided for TE-5742C & 5743C for installation of new thermowell. 6. Pipe spec is mentioned for segment in piping scope for TE-5742C and TE-5743C. 7. Tie-in point location updated for FE-1726. 8. Cause and effect document no. added in reference list.					

