

			ADNOC GAS HABSHAN & BAB CONTROL SYSTEMS UPGRADE (PACKAGE 1) PROJECT NO. 0405323						  				
			COMMENTS RESOLUTION SHEET										
Document Title:			PIPING & INSTRUMENTATION DIAGRAM EARLY THAMMAMA 'B' (HABSHAN) MP BOOSTER COMPRESSOR 1ST STAGE			AGP Response Code			Prepared By:	CA			
Document No:			13-00-216		Revision No:	B	1. Revise and Re-submit		3. Approved	✓	Checked By:	DV	
AG Ref. No:			ADNOCGP-WTRAN-007160		Date:	23-Aug-2024	2. Approved with comments		4. For Information only		Approved By:	YVR	
SN	Reference		COMPANY Comments				CONSULTANT Response			COMPANY Resolution			
	Page No.	Clause No.											
1	-	-	No Comment.										
2	1	-					Following changes are made in P&ID w.r.t. Rev.B submission as per piping/instrumentation inputs. 1. Note 15 and 16 updated. 2. Note 27,28,29 and 30 added. 3. All PT valve are now updated as flange valve. 4. Existing thermowell TW-5014 & 5006 shown as these thermowells are not used and new thermowell will be installed. 5. New Tie-in number provided for TE-5542C & 5543C for installation of new thermowell. 6. Pipe spec is mentioned for segment in piping scope for TE-5542C and TE-5543C. 7. Tie-in point location updated for FE-1526. 8. Cause and effect document no. added in reference list.						

