

			ADNOC GAS HABSHAN & BAB CONTROL SYSTEMS UPGRADE (PACKAGE 1) PROJECT NO. 0405323						  			
			COMMENTS RESOLUTION SHEET									
Document Title:			PIPING & INSTRUMENTATION DIAGRAM CONDENSATE STABILISATION UNIT-22 CONDENSATE SURGE DRUM-THAMMAMA 'C'			AGP Response Code			Prepared By:	JM		
Document No:			22-00-30003		Revision No:	0		1. Revise and Re-submit	3. Approved	x	Checked By:	DV
AG Ref. No:			ADNOCGP-WTRAN-004650		Date:	03-Oct-2024		2. Approved with comments	4. For Information only		Approved By:	YVR
SN	Reference		COMPANY Comments				CONSULTANT Response			COMPANY Resolution		
	Page No.	Clause No.										
1	1	-	Spell mistake in CRS sheet				Noted, Latest CRS sheet attached for Rev 0.					
2	1	-					The following changes are made in P&ID w.r.t. Rev.0 submission. 1) Tie in location of 22-TP-4303A & 22-TP-4303B shifted based on piping input. 2) Tie in Point 22-TP-506A/B and 22-TP-507A/B updated as 22-TP-506 and 22-TP-507 respectively based on Piping input. 3) Tie in location for 22-TP-4301B shifted. 4) OPC CD 5000 deleted as this is connected to existing line 22-0012-WDX-1"-E15X-N based on piping input. 5) DBB drain valve updated for 22-XV-9203.					

