

			ADNOC GAS HABSHAN & BAB CONTROL SYSTEMS UPGRADE (PACKAGE 1) PROJECT NO. 0405323						  				
			COMMENTS RESOLUTION SHEET										
Document Title:			PIPING & INSTRUMENTATION DIAGRAM GAS COOLER & HP SEPERATOR THAMMAMA 'B' & 'C'				AGP Response Code			Prepared By:	JM		
Document No:			22-00-301		Revision No:	0	1. Revise and Re-submit		3. Approved	x	Checked By:	DV	
AG Ref. No:			ADNOCGP-WTRAN-004650		Date:	03-Oct-2024	2. Approved with comments		4. For Information only		Approved By:	YVR	
SN	Reference		COMPANY Comments				CONSULTANT Response			COMPANY Resolution			
	Page No.	Clause No.											
1	1	-	No Comments				Noted						
2	1	-					The following changes are made in P&ID w.r.t. Rev.0 submission. 1) Tie in location of 22-TP-4305A & 22-TP-4305B updated based on piping input. 2) OPC 5437 WDX deleted as this is connected to existing line 22-0002-WDX-1"-E15X-N based on piping input 3) Note No 16 updated for Closure of LV-2012 as per process comment on other P&ID. 4) DBB drain valve updated for 22-XV-9200						

