

			ADNOC GAS HABSHAN & BAB CONTROL SYSTEMS UPGRADE (PACKAGE 1) PROJECT NO. 0405323						  					
			COMMENTS RESOLUTION SHEET											
Document Title:			PIPING & INSTRUMENTATION DIAGRAM MP SEPERATION THAMAMA 'B' & 'C'			AGP Response Code			Prepared By:	JM				
Document No:			22-00-302		Revision No:	0		1. Revise and Re-submit		3. Approved	x	Checked By:	DV	
AG Ref. No:			ADNOCGP-WTRAN-004330		Date:	27-Sep-2024		2. Approved with comments		4. For Information only		Approved By:	YVR	
SN	Reference		COMPANY Comments				CONSULTANT Response			COMPANY Resolution				
	Page No.	Clause No.												
1	1	Process Comment	Please review the removing the reverse cloud				Noted, Reverse cloud removed from the P&ID.							
2	1	Process Comment	Please review to add the note that level control valve LV-2107 will also close.				Noted, Note 20 updated for closure of LV-2107.							
3	1	Process Comment	Please ensure that design review comments are incorporated.				Noted, Design review comments already incorporated in the P&ID with note 26.							
4	1	-					The following changes are made in P&ID w.r.t. Rev.0 submission. 1) Tie in location of 22-TP-515A/B both tie in updated with pair of flanges added based on piping input.							

