

			ADNOC GAS HABSHAN & BAB CONTROL SYSTEMS UPGRADE (PACKAGE 1) PROJECT NO. 0405323						  				
			COMMENTS RESOLUTION SHEET										
Document Title:			PIPING AND INSTRUMENTATION DIAGRAM GAS GENERATOR OIL DIAGRAM FOR 13-C-101A/B/102				AGP Response Code			Prepared By:	VK		
Document No:			5323P1-H1-013-00-50-013		Revision No:	B	1. Revise and Re-submit	☐	3. Approved	☐	Checked By:	DV	
AG Ref. No:			ADNOCGP-WTRAN-007250		Date:	6-Jun-2024	2. Approved with comments	☒	4. For Information only	☐	Approved By:	YVR	
SN	Reference		COMPANY Comments				CONSULTANT Response			COMPANY Resolution			
	Page No.	Clause No.											
1	1	Process Comment	Additional DCS symbol from TCS shall be deleted and same shall be updated in the CRS				The DCS symbol was repeated in Rev A. Hence, only one symol is retained and other DCS symbol is deleted.						
2	1	Process Comment	Based on piping input P&ID shall be updated				Noted, and root valve for PTs are now updated in scope cloud and it is updated as per piping input						
3	1	-	-				Following changes are made in P&ID w.r.t. Rev.B submission as per piping/instrumentation inputs: 1. Instrument manifold valves for all PT are shown in project scope cloud based on instrument input. 2. Note-21 added. 3. Table to mention instruments in project scope for 13-C-101A, 13-C-101B and C-102 is added. Refer detail "B".						

