

Corporation of the City of Quinte West

Trenton/Bayside Drinking Water System (Trenton Service Area)

2021 Annual Drinking Water System Report



A Natural Attraction



The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

2021 Annual Drinking Water System Report	4
Drinking Water System Information	4
Does your Drinking Water System service more than 10,000 people?	4
Is your Annual Report available to the public at no charge on a website	4
Location where Summary Report required under O.Reg.170/03 Schedule 22 will be available for inspection	4
List all Drinking Water Systems (if any), that receive all of their Drinking Water from your System:	4
Indicate how you notified system users that your annual report is available, and is free of charge.	5
Description of the Drinking Water System	5
List all water treatment chemical used over this Reporting Period:	6
Were any significant expenses incurred to:	6
Provide a brief description, and a breakdown of monetary expenses incurred to facilitate Equipment upgrades:	6
Notices submitted in accordance with subsection 18(1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg. 170/03 and reported to Spills Action Centre during this Reporting Period:	7
Microbiological Testing completed in accordance with Schedule 10, 11, or 12 of Regulation 170/03 during this Reporting Period:	8
Operational Testing completed in accordance with Schedule 7, 8, or 9 of O.Reg.170/03 during this Reporting Period:	9
Summary of additional testing and sampling carried out in accordance with the requirement of an Approval, Order, or other Legal Instrument:	9
Summary of Inorganic parameters tested during this Reporting Period or the most recent Sample Results:	11
Summary of Lead Testing under Schedule 15.1 during this Reporting Period:	12
Summary of Organic parameters sampled during this Reporting Period:	12
Inorganic or Organic parameter(s) that have exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards:	16
2021 Summary Report to Council	17
Prescribed Instruments applicable to the Trenton DWS	17
Compliance with Prescribed Instruments, Acts and Regulations	18
Safe Drinking Water Act	18
Clean Water Act	18



The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

A Natural Attraction

Permit to Take Water	19
Drinking Water Works Permit/Municipal Drinking Water Licence	19
2021 Water Quantity and Flow Rates (Raw Water Assessment)	21
2021 Water Quantity and Flow Rates (Treated Water Assessment)	22
Historical Flow Comparison	23



The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

2021 Annual Drinking Water System Report

Drinking Water System Information

Drinking Water System Number:	220001619
Drinking Water System Name:	Trenton/Bayside Drinking Water System (Trenton Service Area)
Drinking Water System Owner:	The Corporation of the City of Quinte West
Drinking Water System Category:	Large Municipal-Residential System
Period being Reported:	January 1, 2021 through December 31, 2021

Does your Drinking Water System service more than 10,000 people?

Yes

Is your Annual Report available to the public at no charge on a website

Yes, please visit www.quintewest.ca

Location where Summary Report required under O.Reg.170/03 Schedule 22 will be available for inspection

Water/Wastewater Division Administration Office

25 Couch Crescent

Trenton, ON, K8V 1G8

List all Drinking Water Systems (if any), that receive all of their Drinking Water from your System:

Carrying Place/Consecon Water Distribution System, DWS number 260005099



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Indicate how you notified system users that your annual report is available, and is free of charge.

- ☒ Public access/notice via City website
- ☐ Public access/notice via Government Office
- ☒ Public access/notice via newspaper
- ☒ Public access/notice via City social media platform(s)
- ☐ Public access/notice via a Public Library
- ☐ Public access/notice via other method:

Description of the Drinking Water System

The Trenton Water Treatment Plant draws water from the Trent River upstream of Dam No. 1 through two intake pipes; one 53 m long, 400 mm diameter raw water intake pipe, and a second, 18 m long, 600 mm diameter intake. This conventional, chemically assisted filtration plant has a rated capacity of 35,800 cu.m/day. Processes used at the filtration plant include flocculation, sedimentation, and Granular Activated Carbon Filtration. Chlorine gas is applied as a disinfectant before filtered water enters two interconnected baffled clearwells with a combined capacity of 5,454 cu.m. The potable (drinkable) water is then pumped into the distribution system through a set of four (4) highlift pumps. There are two elevated water storage tanks in service. The first is the 2nd Dug Hill Road Water Tower; capacity 2,273 cu.m, the second is the Oak Street Water Tower; capacity 2,273 cu.m. Three Booster Pumping Stations are located within the Trenton WDS; they are Catherine Street Booster Pumping Station, Mount Pelion Booster Pumping Station, and Telephone Road Booster Pumping Station. These stations are used to boost system pressure, and supply water into areas at a higher elevation than the Water Treatment Plant.

The Trenton distribution system services approximately 22,000 people in the Trenton community, in addition to part of CFB Trenton. The Trenton Water Treatment plant also supplies all drinking water to the Carrying Place and Consecon Water Distribution System in



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Prince Edward County. In 2015 the City installed a watermain along Old Hwy 2 that effectively connected the Trenton Water Distribution System (WDS) to the Bayside WDS. On April 21, 2017 the Trenton, and Bayside Drinking Water System's were consolidated and governed under one Drinking Water Works Permit (DWWP) # 163-202, and Municipal Drinking Water Licence (MDWL) # 163-102. Each system is still assigned a separate Drinking-Water System number by the Ministry of Environment, Conservation and Parks.

List all water treatment chemical used over this Reporting Period:

- ✓ Aluminum Sulphate (Tradename: Alum)
- ✓ Chlorine Gas

Were any significant expenses incurred to:

- ✓ Install Required Equipment?
- ✓ Repair required Equipment?
- ✓ Replace required Equipment?

Provide a brief description, and a breakdown of monetary expenses incurred to facilitate Equipment upgrades:

Preventative Maintenance (PM) activities for lubrication, inspections, testing and cleaning of equipment is scheduled and completed routinely, along with other lifecycle replacement needs. A new digital operations and asset management platform was implemented in 2021 providing a more accessible and easier to use workflow for management and staff. In addition to the PM activity, the following Capital expenditures were incurred this Reporting Period:



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Water Meter Automation and Replacement	~ \$630,000 (combined with all Drinking Water Systems)
High Lift Pump 4 Replacement	~ \$33,000
Air Scour Rotork Replacement (6)	~ \$37,000
Secondary Floc Mixer Replacement	~ \$43,000
Hydro Lines for High Lift and Low Lift Buildings	~ \$50,000
McGill Street watermain replacement	\$390,000
Lorne Avenue watermain replacement	\$129,000
King Street watermain replacement	\$216,000
Richard Street watermain replacement	\$143,000

Notices submitted in accordance with subsection 18(1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg. 170/03 and reported to Spills Action Centre during this Reporting Period:

Incident Date (DD-MM-YY)	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date (DD-MM-YY)
01-APR-21 to 03-APR-21	<i>Turbidity</i>	No flow to online continuous turbidity analyzer	NTU	Repaired outlet valve (discharge line)	03-APR-21



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

13-MAY-21	<i>Free Chlorine</i>	Dual Media Filter 2 underdrain system failure	mg/L	Operator removed media from inlet line - filter out of service until further repairs can be made	Outstanding
-----------	----------------------	---	------	--	-------------

Microbiological Testing completed in accordance with Schedule 10, 11, or 12 of Regulation 170/03 during this Reporting Period:

	Number of Samples	Range of E.Coli (min - max)	Range of Total Coliform (min - max)	Number of Heterotrophic Plate Count Samples	Range of HPC results (min - max)
Raw	52	0 - NDOGT ¹	10 - NDOGT	NA	NA
Treated	52	0 - 0	0 - 0	52	0 - 3
Distribution	407	0 - 0	0 - 0	178	0 - 24

¹ NDOGT stands for No Data: Overgrown with Target Bacteria. Prior, and subsequent datasets within normal range.



The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

**Operational Testing completed in accordance with
Schedule 7, 8, or 9 of O.Reg.170/03 during this Reporting
Period:**

Parameter	Number of Grab Samples	Range of Results (min-max)
Turbidity, (NTU)	8760	0.000 ² - 1.996 ³
Primary Disinfection FAC ⁴ , (mg/L)	8760	0.27 ⁵ - 3.05
Secondary Disinfection FAC, (mg/L)	8760	0.62 - 2.34

**Summary of additional testing and sampling carried out in
accordance with the requirement of an Approval, Order,
or other Legal Instrument:**

In accordance with Condition 4.0 of MDWL #163-102, monthly samples must be collected and tested for Total Suspended Solids, and Total Residual Chlorine⁶, from the following waste streams that may impact the natural environment:

- Waste Residual Management Sedimentation Tank - Clear Water Discharge

Condition 1.5 of the MDWL outlines the maximum annual average concentration for each of these parameters. Outlined below are the sample results obtained throughout the year.

² Value obtained when analyzer fails. Four (4) events occurred throughout reporting period. Desiccant Pouch (analyzer component) required replacement. Lasts less than 1 min. Before alarm interlock shuts filter down.

³ Isolated incident occurring for less than 30 seconds. Filter effluent valved closed.

⁴ Free Available Chlorine. Defined as the free amount of chlorine available in water.

⁵ Suspected erroneous reading. CT calculation performed using this value. CT(req) = 42.4 mg/L*min, CT(ach) = 73.9 mg/L*min.

⁶ Total Residual Chlorine. Defined as the total amount of chlorine available in water.



The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Monitoring month	Total Flow (cu.m)	Total Suspended Solids (mg/L)	Minimum Total Residual Chlorine (mg/L)	Maximum Total Residual Chlorine (mg/L)
January, 2021	10,171	2	0.00	0.02
February, 2021	8,551	5	0.02	0.03
March, 2021	10,185	5	0.01	0.01
April, 2021	11,308	3	0.02	0.03
May, 2021	9,703	3	0.02	0.03
June, 2021	12,392	7	0.03	0.03
July, 2021	12,448	3	0.04	0.04
August, 2021	11,410	6	0.03	0.03
September, 2021	10,499	3	0.02	0.03
October, 2021	10,081	6	0.04	0.04
November, 2021	10,842	3	0.02	0.06
December, 2021	10,965	8	0.04	0.04
Annual Average	10,713	4.5	0.03	

The maximum annual average concentration for Total Residual Chlorine is outlined to be 0.02 mg/L. This value was exceeded during the period and upon further investigation it is determined that the cause is attributed to the level of accuracy with monitoring equipment.



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Operators are researching equipment options that will offer a lower range of results for more accurate data.

Summary of Inorganic parameters tested during this Reporting Period or the most recent Sample Results:

Inorganic Compound Results				
Parameter	Sample Date (dd/mm/yy)	Result Value	Unit of Measure	Exceedance?
Antimony	05-JAN-21	< 0.09	ug/L	No
Arsenic	05-JAN-21	< 0.2	ug/L	No
Barium	05-JAN-21	26.8	ug/L	No
Boron	05-JAN-21	10	ug/L	No
Cadmium	05-JAN-21	< 0.003	ug/L	No
Chromium	05-JAN-21	0.14	ug/L	No
Mercury	05-JAN-21	< 0.01	ug/L	No
Selenium	05-JAN-21	0.05	ug/L	No
Sodium	05-JAN-21	8.72	mg/L	No
Fluoride	05-JAN-21	< 0.06	mg/L	No
Uranium	05-JAN-21	0.029	ug/L	No
Nitrate	05-JAN-21 07-APR-21 06-JUL-21 05-OCT-21	0.255 0.230 0.057 0.060	mg/L	No
Nitrite	05-JAN-21 07-APR-21 06-JUL-21 05-OCT-21	< 0.003 < 0.003 < 0.003 < 0.003	mg/L	No



The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Summary of Lead Testing under Schedule 15.1 during this Reporting Period:

Lead Sampling Results				
Sampling Period	Location Type	Number of Samples	Range of Lead Results (ug/L), 'min-max'	Number of Exceedances
Winter Sampling Period ⁷	Drinking Water System exempt from sampling in accordance with Section 15.1-5(9) under Schedule 15 of O.Reg.170/03. Sampling and testing for Lead not required until Winter 2021/2022 for sampling period.			
Summer Sampling Period ⁸	Drinking Water System exempt from sampling in accordance with Section 15.1-5(9) under Schedule 15 of O.Reg.170/03. Sampling and testing for Lead not required until Summer 2022 sampling period.			

Summary of Organic parameters sampled during this Reporting Period:

Organic Compound Results				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	05-JAN-21	< 0.02	ug/L	No
Atrazine + N-dealkylated metabolites	05-JAN-21	< 0.01	ug/L	No

⁷ Winter Sampling Period runs from December 15 - April 15. The last sample collected in accordance with the Regulation was sampled on April 9, 2019.

⁸ The Summer Sampling Period runs from June 15 through October 15. The last sample collected in accordance with the Regulation was sampled on September 16, 2019.



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Azinphos-methyl	05-JAN-21	< 0.05	ug/L	No
Benzene	05-JAN-21	< 0.32	ug/L	No
Benzo(a)pyrene	05-JAN-21	< 0.004	ug/L	No
Bromoxynil	05-JAN-21	< 0.33	ug/L	No
Carbaryl	05-JAN-21	< 0.05	ug/L	No
Carbofuran	05-JAN-21	< 0.01	ug/L	No
Carbon Tetrachloride	05-JAN-21	< 0.17	ug/L	No
Chlorpyrifos	05-JAN-21	< 0.02	ug/L	No
Diazinon	05-JAN-21	< 0.02	ug/L	No
Dicamba	05-JAN-21	< 0.20	ug/L	No
1,2-Dichlorobenzene	05-JAN-21	< 0.41	ug/L	No
1,4-Dichlorobenzene	05-JAN-21	< 0.36	ug/L	No
1,2-Dichloroethane	05-JAN-21	< 0.35	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	05-JAN-21	< 0.33	ug/L	No
Dichloromethane	05-JAN-21	< 0.35	ug/L	No



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

2-4 Dichlorophenol	05-JAN-21	< 0.15	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	05-JAN-21	< 0.19	ug/L	No
Diclofop-methyl	05-JAN-21	< 0.40	ug/L	No
Dimethoate	05-JAN-21	< 0.06	ug/L	No
Diquat	05-JAN-21	< 1	ug/L	No
Diuron	05-JAN-21	< 0.03	ug/L	No
Glyphosate	05-JAN-21	< 1	ug/L	No
Malathion	05-JAN-21	< 0.02	ug/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA)	05-JAN-21	< 0.00012	mg/L	No
Metolachlor	05-JAN-21	< 0.01	ug/L	No
Metribuzin	05-JAN-21	< 0.02	ug/L	No
Monochlorobenzene	05-JAN-21	< 0.3	ug/L	No
Paraquat	05-JAN-21	< 1	ug/L	No
Pentachlorophenol	05-JAN-21	< 0.15	ug/L	No



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Phorate	05-JAN-21	< 0.01	ug/L	No
Picloram	05-JAN-21	< 1	ug/L	No
Polychlorinated Biphenyls(PCB)	05-JAN-21	< 0.04	ug/L	No
Prometryne	05-JAN-21	< 0.03	ug/L	No
Simazine	05-JAN-21	< 0.01	ug/L	No
THM (NOTE: show latest annual average)	05-OCT-21	62.0	ug/L	No
HAA (Running Annual Average)	05-OCT-21	55.2	ug/L	No
Terbufos	05-JAN-21	< 0.01	ug/L	No
Tetrachloroethylene	05-JAN-21	< 0.35	ug/L	No
2,3,4,6-Tetrachloroph enol	05-JAN-21	< 0.20	ug/L	No
Triallate	05-JAN-21	< 0.01	ug/L	No
Trichloroethylene	05-JAN-21	< 0.44	ug/L	No
2,4,6-Trichlorophenol	05-JAN-21	< 0.25	ug/L	No
Trifluralin	05-JAN-21	< 0.02	ug/L	No



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Annual Drinking Water System Report
(Trenton Service Area)

Vinyl Chloride	05-JAN-21	< 0.17	ug/L	No
----------------	-----------	--------	------	----

**Inorganic or Organic parameter(s) that have exceeded
half the standard prescribed in Schedule 2 of Ontario
Drinking Water Quality Standards:**

None.



2021 Summary Report to Council

In accordance with Schedule 22 requirements outlined in Ontario Regulation 170/03, a Summary Report shall be prepared no later than March 31 for the preceding year, and supplied to members of municipal council.

The Report shall list the requirements of the Act, Regulations, Drinking Water Works Permit, Municipal Drinking Water Licence, and any Orders applicable to the system that were not met at any time during the period covered by the Report.

The Report must also include a summary of the quantities and flow rates of potable (drinkable) water supplied during the Reporting Period, including monthly average and maximum daily flows. A comparison of these flows to the rated capacity and flow rates approved in the system Drinking Water Works Permit, and Municipal Drinking Water Licence, must also be provided.

Prescribed Instruments applicable to the Trenton DWS

The Trenton DWS is governed by, and must operate their DWS primarily in accordance with, the following Acts and Regulations at minimum:

- Safe Drinking Water Act, 2002;
- O. Reg. 128/04 – Certification of Drinking Water System Operators and WQA
- O. Reg. 170/03 – Drinking Water Systems
- O. Reg. 169/03 – Ontario Drinking Water Quality Standards
- Environmental Protection Act, where applicable;
- Clean Water Act, where applicable;
- Municipal Drinking Water Licence 163-102;
- Drinking Water Works Permit 163-202;
- Permit to Take Water 1007-9HJP6L, expires April 30, 2024.



A Natural Attraction

The Corporation of the City of Quinte West

Public Works and Environmental Services

Water/Wastewater Division

2021 Summary Report to Council (Trenton Service Area)

Councillors wishing to obtain a copy of any Act or Regulation are welcome to contact the Manager of Water and Wastewater Services at mattd@quintewest.ca to obtain a current consolidated copy and interpretation of the legislation.

Compliance with Prescribed Instruments, Acts and Regulations

Safe Drinking Water Act

In addition to the two Adverse Water Quality events detailed in section [Notices submitted in accordance with subsection 18\(1\) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg. 170/03 and reported to Spills Action Centre during this Reporting Period](#), the following noteworthy activities occurred through the Reporting Period.

NSF International conducted an offsite Surveillance Audit on November 10, 2021. The intent of the audit is to confirm continued conformance to the Drinking Water Quality Management Standard. There was one minor Non-Conformance identified in the Audit Report.

The City achieved a 100% Inspection Rating on its 2021 MECP Compliance Inspection and there were no regulatory non-compliance items cited.

Clean Water Act

The Source Protection Plan was approved by the Minister of Environment, Conservation and Parks, and came into effect on January 1, 2015. The City has put the necessary internal processes in place with the Planning, Building, and Public Works Departments to screen applications and ensure compliance with the Source Protection Plan. In 2021 there were



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Summary Report to Council
(Trenton Service Area)

nine (9) applications submitted to the Risk Management Official for review and approval specific to the Trenton system. In general the screening, application, and approval processes implemented by staff seem to be working reasonably well. Throughout the screening and verification process it has been determined that currently there are three (3) Risk Management Plans (RMPs) required for affected properties in the Intake Protection Zone surrounding the Trenton Intake. Draft RMPs have been distributed to affected property owners for review, and to start the consultation/negotiation process.

Permit to Take Water

The City operates its Trenton Water Treatment Plant in accordance with Permit to Take Water (PTTW) number 1007-9JHP6L which expires on April 30, 2024. This Permit allows the City to take 35,800 cu.m/day from the Trent River watershed at a maximum flow rate of 530.4 L/s. The maximum recorded daily taking was 14,855.2 cu.m/day on June 2, 2021. The maximum recorded flow rate was 515.6 L/s on April 26, 2021.

For a detailed summary of water quantities and flow rates, see [2021 Water Quantity and Flow Rates \(Raw Water Assessment\)](#).

Drinking Water Works Permit/Municipal Drinking Water Licence

The City applied for renewal of its Municipal Drinking Water Licence, and Drinking Water Works Permit in 2020. The Trenton/Bayside DWS is now governed by Number: 05 of Municipal Drinking Water Licence number 163-102, and Issue Number: 08 of Drinking Water Works Permit number 163-202. The Municipal Drinking Water Licence will expire September 28, 2025. Noteworthy changes to the City's Licence are listed below:

- A Harmful Algal Bloom monitoring, reporting and sampling plan was implemented.



A Natural Attraction

The Corporation of the City of Quinte West

Public Works and Environmental Services

Water/Wastewater Division

2021 Summary Report to Council (Trenton Service Area)

In accordance with Condition 1.1 of the MDWL, the Trenton Water Treatment Plant has a rated capacity to treat and distribute 35,800 cu.m/day. Over the Reporting Period the maximum daily volume of treated water distributed to the distribution system was 13,324.3 cu.m/day on June 2, 2021. The Annual Average Daily Flow pumped to the Distribution System was 9,516 cu.m/day. For a detailed summary of treated water quantities and flow rates, see [2021 Water Quantity and Flow Rates \(Treated Water Assessment\)](#).



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Summary Report to Council
(Trenton Service Area)

2021 Water Quantity and Flow Rates (Raw Water Assessment)

Raw Water Flow: PTTW Limit = 35,800 cu.m/d			
Month	Average Daily Flow (cu.m/d)	Maximum Daily Flow (cu.m/d)	Total Monthly Flow (cu.m/month)
January	9958.1	11100.2	308700.6
February	9800.6	10865.6	274416.4
March	9800.6	10919.3	303817.5
April	9482.5	10526.2	284475.9
May	11169.9	13454.8	346267.5
June	12269.6	14855.2	368088.7
July	10987.5	12505.2	340611.0
August	11615.1	13008.1	360069.2
September	10613.7	12473.9	318410.1
October	10029.7	11035.5	310922.2
November	9733.4	10447.3	292003.2
December	9551.7	10315.1	296102.0
Total Raw Water Flow =			3,803,884



A Natural Attraction

The Corporation of the City of Quinte West
Public Works and Environmental Services
Water/Wastewater Division
2021 Summary Report to Council
(Trenton Service Area)

2021 Water Quantity and Flow Rates (Treated Water Assessment)

Treated Water Flow: Facility Rated Capacity = 35,800 cu.m/day			
Month	Average Daily Flow (cu.m/d)	Maximum Daily Flow (cu.m/d)	Total Monthly Flow (cu.m/month)
January	9079.3	10076.9	281457.7
February	8890.3	9840.2	248928.4
March	8905.9	9708.1	276082.7
April	8582.4	9491.0	257471.8
May	10285.7	12466.1	318856.1
June	11231.6	13324.3	336949.1
July	10005.8	11310.6	310179.0
August	10679.5	12040.5	331063.0
September	9781.9	11488.4	293457.6
October	9231.3	10089.5	286169.9
November	8879.1	9780.3	266372.9
December	8590.5	9346.2	266304.8
Total Treated Water Flow =			3,473,293

- Annual Average Daily (Treated Water) Flow = 9,516 cu.m/day. This accounts for 27% of the facility Rated Capacity.
- Maximum Daily (Treated Water) Flow = 13,324 cu.m/day. This accounts for 37% of the facility Rated Capacity during record peak daily flow conditions.



A Natural Attraction

The Corporation of the City of Quinte West

Public Works and Environmental Services

Water/Wastewater Division

2021 Summary Report to Council (Trenton Service Area)

Historical Flow Comparison

The facility has operated at 27% of its rated capacity over the past five years. The construction of a new booster station and watermain was initiated in 2021 to supply water from the Trenton Drinking Water System to the Frankford Drinking Water System. Due to equipment supply issues, the completion of this project is scheduled for 2022.

