| Control | CE04OSPS CE04OSPS-PC01B CE04OSPS-PC01B-4A-CTDPFA109 ctdpf_optode_sample oxy_calphase | | | | CE04OSPS-PC01B-4A-CTDPFA109 | | |
|--|--|--|--|--|---|--|---|
| Fig. 1997 | CE04OSPS-PC01B-4A-CTDPFA109 ctdpf_optode_sample oxy_calphase | | | | | | |
| Page | | la constitución de la constituci | | | | | |
| March Marc | | | | | | | |
| Company | - | | | | | | |
| March Marc | | | | | | | |
| Level Degree Section | density | Provide | | | | | |
| March Marc | pressure | Pro Colonia de Colonia | | | | | |
| Internal | | Processing and the second seco | | | | | |
| Cacific Clarif Part Clarif Part Clarif Clarif Part | conductivity | Nov 2014 | Feb 2015 N | _{laV} 201 ⁵ Aug 201 ¹ | 5 Nov 2015 Feb 2016 | May 2016 Aug 2016 Nov 2016 | Feb 2017 |
| CHINGUISPER CONCEST | | Deploymen 109 D00001 | t StartTime 2014-08-30T09:16:00Z | EndTime 2014-10-08T19:51:58Z | Annotation Testing instrument: No data collected. | | Status NOT_OPERATIONAL |
| CER-AGENS 2014 19 07 19 44 000 2014 14 19 100 100 200 2014 19 100 100 200 2014 19 100 100 200 2014 19 100 100 200 2014 19 100 100 200 2014 19 100 100 200 2014 19 100 100 200 2014 19 100 100 200 2014 19 100 100 200 2014 19 100 100 200 2014 19 100 100 2014 2014 19 100 2014 2014 19 100 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 2014 19 100 2014 19 | CE04OSPS-PC01B-4A-CTDPFA | D00001 D00001 | 2014-11-04T16:05:39Z 2014-11-04T16:05:39Z | 2014-11-05T19:25:40Z 2014-11-05T19:25:40Z | Data gap under investigation. Data gap under investigation. | | NOT_OPERATIONAL NOT_AVAILABLE |
| 2015-01-0710-05-0000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-0710-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-05-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-000 2015-01-01-01-01-000 2015-01-01-01-01-000 2015-01-01-01-01-000 2015-01-01-01-01-000 2015-01-01-01-01-000 2015-01-01-01-01-000 2015-01-01-01-01-01-000 2015-01-01-01-01-01-01-01-01-01-01-01-01-01- | ctdpf_optode_sample CE04OSPS ctdpf_optode_sample CE04OSPS | D00001 | 2014-12-07T19:45:00Z 2014-12-07T19:45:00Z | 2014-12-16T00:00:00Z 2014-12-16T00:00:00Z | PFE down. HVPS1 MOV explosion, 800A breaker | - · · · | NOT_OPERATIONAL NOT_AVAILABLE |
| | ctdpf_optode_sample | | 2015-01-07T07:32:00Z 2015-01-30T23:08:24Z | 2015-01-07T08:06:00Z 2015-02-05T21:13:35Z | PNWGP Portland <-> Seattle outage. Intermittent partial data loss due to storage drive p | • | NOT_AVAILABLE NOT_OPERATIONAL |
| CECHOSPS 2015-03-2111-410.0002 2015-03-22110-20.0002 2015-05-13110-20.0002 2015-05-13110-20.0002 2015-05-13110-20.0002 2015-05-13110-20.0002 2015-05-13110-20.0002 2015-05-13110-20.0002 2015-05-2110-22.5472 2015-06-20170.000002 2015-05-20172-25.5592 2015-06-20170.000002 2015-05-20172-25.5592 2015-06-20170.000002 2015-06-20172-25.5592 2015-06-20170.000002 2015-06-20172-25.5592 2015-06-20170.000002 2015-06-20172-25.5592 2015-06-20170.000002 2015-06-20172-25.5592 2015-06-20170.000002 2015-06-20172-25.5592 2015-06-20170.000002 2015-06-20172-25.5592 2015-06-20170.000002 2015-06-20170.000002 2015-06-20170.000002 2015-06-20170.000002 2015-06-20170.000002 2015-06-20170.000002 2015-06-20170.000002 2015-06-20170.000002 2015-06-20170.000002 2015-06-20170.0000002 2015-06-20170.0000002 2015-06-20170. | | | 2015-01-31T00:00:00Z 2015-03-07T23:06:04Z | 2015-02-04T00:00:00Z 2015-03-09T07:39:57Z | Intermittent partial data loss due to storage drive partial gap under investigation. | | NOT_AVAILABLE NOT_OPERATIONAL |
| 2015-09-0071-09-0000 2015-09-0000 2015- | CE04OSPS CE04OSPS | | 2015-03-21T14:10:00Z 2015-06-13T00:00:00Z | 2015-03-22T04:20:00Z 2015-06-15T16:30:00Z | Gappy Data: PNWGP outage due to City of Seattl Gappy Data: Network issues due to fire that dama | aged fibers between Portland and Seattle. | |
| CED4OSPS 2015-08-29700.00.002 2015-08-29700.30.002 CED4OSPS 2016-01-0770610.002 2016-01-077065.2002 Four 1-minute outages between Portland and Seattle due to maintenance. NOT_OPERATIONAL (didpt_optode_sample 2016-03-10723.06.002 2016-03-10730.0002 Fiber break between Portland and Seattle due to maintenance. NOT_AVAILABLE (DED4OSPS 2016-03-10723.06.002 2016-03-10730.0002 Fiber break between Portland and Seattle due to maintenance. NOT_AVAILABLE (DED4OSPS 2016-03-10733.06.002 2016-03-207163.00.002 Fiber break between Portland and Seattle (as to maintenance). NOT_AVAILABLE (DED4OSPS 2016-03-207163.00.002 2016-03-207163.00.002 Fiber break between Portland and Seattle (as to maintenance). NOT_AVAILABLE (DED4OSPS 2016-03-207163.00.002 2016-03-207163.00.002 Eiber break between Portland and Seattle (as to maintenance). NOT_AVAILABLE (DED4OSPS 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2016-03-207163.00.002 2017-01-097102.50.002 2017-01-09710 | ctdpf_optode_sample ctd_tc_oxygen dissolved_oxygen | D00001 D00002 D00002 | 2015-07-15T12:25:47Z 2015-08-03T23:59:59Z 2015-08-03T23:59:59Z | 2015-08-02T00:00:00Z 2015-08-05T06:47:21Z 2015-08-05T06:47:21Z | Instrument operational up to July 1 2015. Unknown Values are too high exceeded 400 umol L-1. Values are too high exceeded 400 umol kg-1. | | NOT_AVAILABLE FAIL FAIL |
| 2016-03-10723.06.00Z 2016-03-11703.00.00Z 2016-03-11703.00.00Z 2016-03-11703.00.00Z 2016-03-11703.00.00Z 2016-03-11703.00.00Z 2016-03-20716.03.00Z 2016-12-20715.00Z 2016-12-20715.00Z 2016-12-20715.00Z 2016-12-20715.00Z 2016-12-20715.00Z 2016-12-20715.00Z 2017-01-08712.13.00Z 2017-01-08712.13.00Z 2017-01-08712.13.00Z 2017-01-08712.13.00Z 2017-01-08712.13.00Z 2017-01-08712.13.00Z 2017-01-08712.13.00Z 2017-01-09718.30.53Z 2017-01-09712.25.00Z 2017-01-09712.25.00Z 2017-01-09718.30.53Z 2017-01-09712.25.00Z 2017-01-09712.25.00Z 2017-01-09712.25.00Z 2017-01-09712.25.00Z 2017-01-09712.25.00Z 2017-01-09712.25.00Z 2017-01-09712.25.00Z 2017-01-09712.03.00Z 2017-01-09712.03.00Z 2017-01-09712.03.00Z 2017-01-09713.00.00Z 2017-01-09713.00.00Z 2017-01-09713.00.00Z 2017-01-09713.00.00Z 2017-01-09713.00.00Z 2017-01-09713.00.00Z 2017-01-09713.00.00Z 2017-02-15714.43.05Z 2017-02-15717.16.00Z 2017-02-15717.1 | oxygen CE04OSPS CE04OSPS ctdpf_optode_sample | D00002 | 2015-08-29T00:00:00Z 2016-01-07T06:10:00Z | 2015-08-29T00:30:00Z 2016-01-07T06:52:00Z | Gappy Data: Outage during major utility power fail Four 1-minute outages between Portland and Sea | attle due to maintenance. | NOT_OPERATIONAL |
| CE04OSPS 2016-07-12T02:53:00Z 2016-07-12T03:51:00Z Unexplained loss of power at Pittock Building in Portland - data exist. CE04OSPS 2016-12-22T101:50:00Z 2016-12-23T12:44:00Z Fiber break in Portland due to train crash - data exist. CE04OSPS 2017-01-08T19:58:00Z 2017-01-08T21:41:00Z Network outage during major Seattle utility power failure - data exist. CE04OSPS 2017-01-09T18:30:53Z 2017-01-09T20:25:00Z Lightning strike in Pacific City led to isolation of both cable lines from shore station equipment, when Power Feed Equipment High Voltage Opening Switches operated. All deployed infrastructure went offline. CE04OSPS-PC01B-4A-CTDPFA109 D0003 2017-01-09T18:30:53Z 2017-01-11T01:02:52Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS 2017-02-15T14:43:05Z 2017-02-15T17:16:00Z 20 | CE04OSPS ctdpf_optode_sample CE04OSPS | | 2016-03-10T23:06:00Z 2016-03-10T23:06:00Z 2016-05-20T16:33:00Z | 2016-03-11T09:30:00Z 2016-03-11T09:30:00Z 2016-05-20T18:04:00Z | Fiber break between Portland and Seattle. Fiber break between Portland and Seattle. Fiber break between Portland and Pacific City. | | NOT_OPERATIONAL NOT_AVAILABLE NOT_OPERATIONAL |
| CE04OSPS 2017-01-08T19:58:002 2017-01-08T21:41:00Z Network outage during major Seattle utility power failure - data exist. CE04OSPS 2017-01-09T18:30:53Z 2017-01-09T20:25:00Z Lightning strike in Pacific City led to isolation of both cable lines from shore station equipment, when Power Feed Equipment High Voltage Opening Switches operated. All deployed infrastructure went offline. CE04OSPS-PC01B-4A-CTDPFA109 D0003 2017-01-09T20:25:00Z 2017-01-11T01:02:52Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS D0003 2017-01-09T20:25:00Z 2017-01-11T01:02:52Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS D0003 2017-02-07T13:00:00Z 2017-02-07T15:00:00Z Outage during PNWGP 1-hour router-maintenance - data exist with gap(s). CE04OSPS CE04OSPS D0003 2017-02-15T14:43:05Z 2017-02-15T17:16:00Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS-PC01B-AA-CTDPFA109 D0003 2017-02-15T14:43:05Z 2017-02-15T17:16:00Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS-PC01B-AA-CTDPFA109 D0003 2017-02-15T14:43:05Z 2017-02-15T17:16:00Z CTD offline because of power interruption caused by lightning strike on Pacific City in close proximity to shore station. CE04OSPS-PC01B-AA-CTDPFA109 D0003 2017-02-15T14:43:05Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS-PC01B-AA-CTDPFA109 D0003 2017-02-15T17:16:00Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS-PC01B-AA-CTDPFA109 D0003 2017-02-15T17:16:00Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in clos | ctdpf_optode_sample CE04OSPS CE04OSPS CE04OSPS | | 2016-07-12T02:53:00Z 2016-12-17T18:00:00Z | 2016-07-12T03:51:00Z 2016-12-17T19:00:00Z | Unexplained loss of power at Pittock Building in P Corvalis data center lost power - data exist. | | NOT_AVAILABLE |
| when Power Feed Equipment High Voltage Opening Switches operated. All deployed infrastructure went offline. CE04OSPS-PC01B-4A-CTDPFA109 D00003 2017-01-09T18:30:53Z 2017-01-11T01:02:52Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS D00003 2017-02-07T13:00:00Z 2017-02-07T15:00:00Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS 2017-02-07T13:00:00Z 2017-02-07T15:00:00Z Outage during PNWGP 1-hour router-maintenance - data exist with gap(s). CE04OSPS 2017-02-15T14:43:05Z 2017-02-15T17:16:00Z Power Feed Equipment failure during major utility power issues related to lightning strike on Pacific City electrical sub-station. All deployed infrastructure went offline. Power was restored on February 16. No hardware issue subsea was identified. CE04OSPS-PC01B-4A-CTDPFA109 D00003 2017-02-15T14:43:05Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in close proximity to shore station. CE04OSPS-PC01B-4A-CTDPFA109 D00003 2017-02-15T17:16:00Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in close NOT_AVAILABLE | CE04OSPS CE04OSPS | | 2017-01-08T19:58:00Z | 2017-01-08T21:41:00Z | Network outage during major Seattle utility power Lightning strike in Pacific City led to isolation of bowhen Power Feed Equipment High Voltage Open | failure - data exist. oth cable lines from shore station equipment, | NOT_OPERATIONAL |
| ctdpf_optode_sample D00003 2017-01-09T20:25:00Z 2017-01-11T01:02:52Z CTD offline because of power interruption caused by lightning strike in Pacific City in close Proximity to shore station. CE04OSPS 2017-02-07T13:00:00Z 2017-02-07T15:00:00Z 2017-02-15T14:43:05Z 2017-02-15T17:16:00Z 2017-02-15T17:16:00Z 2017-02-15T14:43:05Z 2017-02-15T17:16:00Z 2017-02-16T23:12:00Z 2017-02-16T23:12:0 | ctdpf_optode_sample CE04OSPS-PC01B-4A-CTDPFA | 109 D00003 | | | when Power Feed Equipment High Voltage Open went offline. CTD offline because of power interruption caused | ing Switches operated. All deployed infrastructure | |
| City electrical sub-station. All deployed infrastructure went offline. Power was restored on February 16. No hardware issue subsea was identified. Ctdpf_optode_sample 2017-02-15T14:43:05Z 2017-02-15T17:16:00Z Power Feed Equipment failure during major utility power issues related to lightning strike on Pacific City electrical sub-station. All deployed infrastructure went offline. Power was restored on February 16. No hardware issue subsea was identified. CE04OSPS-PC01B-4A-CTDPFA109 D00003 2017-02-15T14:43:05Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in close NOT_OPERATIONAL proximity to shore station. Ctdpf_optode_sample D00003 2017-02-15T17:16:00Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in close NOT_AVAILABLE | ctdpf_optode_sample CE04OSPS CE04OSPS | D00003 | 2017-02-07T13:00:00Z | 2017-02-07T15:00:00Z | CTD offline because of power interruption caused proximity to shore station. Outage during PNWGP 1-hour router-maintenance | ce - data exist with gap(s). | |
| CE04OSPS-PC01B-4A-CTDPFA109 D00003 2017-02-15T14:43:05Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in close NOT_OPERATIONAL ctdpf_optode_sample D00003 2017-02-15T17:16:00Z 2017-02-16T23:12:03Z CTD offline because of power interruption caused by lightning strike in Pacific City in close NOT_AVAILABLE | ctdpf_optode_sample | | | | City electrical sub-station. All deployed infrastruct 16. No hardware issue subsea was identified. Power Feed Equipment failure during major utility City electrical sub-station. All deployed infrastruct | ture went offline. Power was restored on February power issues related to lightning strike on Pacific | NOT_AVAILABLE |
| | CE04OSPS-PC01B-4A-CTDPFA | | | | CTD offline because of power interruption caused proximity to shore station. CTD offline because of power interruption caused | | |
| | | | | | | | |
| | | | | | | | |