# EGSF 300V INSTRUMENTATION CABLES
**Cu/PVC/OSCR/PVC**

BİRTAŞ KABLO

## APPLICATION

These cables are used for transmission of analoge and digital signals in instrument and control systems at chemistry and petrochemistry industry plants, power plants, natural gas and petroluem plants, etc... . Instrumentation cables are not allowed for direct connection to a low impedance sources, e.g. public mains electricity supply. They are for indoor installation, in dry and wet locations; on racks, trays, in conduits.

## CABLE DESIGN

| | | |
|---|---|---|
| Conductor | : | Stranded plain copper wires, EN 60228 Class 2 |
| Insulation | : | 90ºC grade, PVC compound |
| Core identification | : | White and red coloured cores |
| Pair | : | Two cores twisted to a pair |
| Stranding | : | Pairs stranded in layers of optimum pitch |
| Separator | : | Polyester tape |
| Screen | : | Aluminium polyester tape with tinned copper drain wire (0,20 mm$^2$~7x0,20 mm) |
| Outer sheath | : | 90ºC grade, PVC compound |
| Sheath colour | : | ~RAL 7001, Grey or ~RAL 5015, Blue |

## TECHNICAL DATA @20ºC

| | |
|---|---|
| Standard | : Acc. to NF M 87-202 & EN 50288-7 |
| Insulation Resistance | : Min. 20 Mohm x km |
| Nominal capacitance (1 kHz) | : Max. 160 nF/km |
| Voltage rating | : 300V |
| Test Voltage (AC 50 Hz) | : 2000 V |
| Min.bending radius | : 10 x D |
| Temperature Range | : Fixed: -30 °C ~ +90 °C<br>Installation: -5 °C ~ +50 °C |
| Flame test | : IEC 60332-1 & TS EN 60332-1-2<br>EN IEC 60332-3-24 Cat C |
| Oil resistant | : IEC 60811 (4hours @70°C in IRM 902) |
| Sunlight resistance | : UL 1581 section 1200 |

**CE : Conform to 2014/35/EU (Low Voltage Directive)**

**Conform to 2011/65/EU & 2015/863 (RoHS Directives)**

## Kesitler / Cross Sections

| Type of Cable | Insulation Thickness | Approx. Outer Diameter | Copper Weight | Approx. Cable Weight |
|---|---|---|---|---|
| | (mm) | (mm) | (kg/km) | (kg/km) |
| 1x2x0,50 | 0,50 | 6,00 | 12 | 50 |
| 1x2x0,88 | 0,50 | 7,10 | 19 | 65 |

***Diameter tolerance ±7%**
**YK 40155-31.07.2025 (YÇ)**