Doak - All Unite in (noh)	10-10 22 11 02	Reporting Limit	EDA MOLO	EDA MOI	MN Short torm	MN Chronic
Peak - All Units in (ppb) Chloromethane (methyl chloride)	10-10-23-JI-03 BRL	Reporting_Limit 1.0	EPA MCLG	EPA MCL	MN Short-term	MN Chronic
Chloroethene (vinyl chloride)	BRL	1.0	0.0	2.0		10.0
Bromomethane (methyl bromide)	BRL	1.0				10.0
Chloroethane (ethyl chloride)	BRL	1.0				
Trichlorofluoromethane Diethyl ether	BRL BRL	1.0	150.0			2000.0
1,1-Dichloroethene	BRL	1.0				
Acetone	36.9	1.8			9000.0	4000.0
lodomethane	BRL	1.0				
Carbon disulfide	BRL	1.0				700.0
3-Chloropropene (allyl chloride) Methylene chloride (DCM)	BRL BRL	1.0				30.0
trans-1,2-Dichloroethene	BRL	1.0	100.0	100.0		9.0
Methyl tert-butyl ether (MTBE)	BRL	1.0	13.0		700.0	700.0
1,1-Dichloroethane	BRL	1.0	0.0	5.0	400.0	80.0
2,2-Dichloropropane	BRL	1.0	7.0	7.0	20.0	C 0
cis-1,2-Dichloroethene 2-Butanone (MEK)	BRL BRL	1.0	7.0	7.0	20.0	4000.0
Methyl acrylate	BRL	1.0				
Bromochloromethane	BRL	1.0				
Methacrylonitrile	BRL	1.0				
Tetrahydrofuran Trichloromethane (chloroform)	50.2	1.0	70.0		600.0 20.0	20.0
1,1,1-Trichloroethane	BRL	1.0	200.0	200.0	20.0	5000.0
1-Chlorobutane (butyl chloride)	BRL	1.0				
Carbon tetrachloride	BRL	1.0	0.0	5.0	3.0	3.0
1,1-Dichloropropene	BRL	1.0				
Benzene 1,2-Dichloroethane	BRL BRL	1.0	0.0	5.0	200.0	60.0
Trichloroethene	BRL	1.0	0.0	3.0	200.0	
1,2-Dichloropropane	BRL	1.0	0.0	5.0	20.0	20.0
Dibromomethane	BRL	1.0				
Methyl methacrylate	BRL	1.0	0.0		20.0	20.0
Bromodichloromethane 2-Nitropropane	18.3 BRL	1.0	0.0		30.0	30.0
cis-1,3-Dichloropropene	BRL	1.0				
4-Methyl-2-pentanone (MIBK)	BRL	1.8				
Toluene	BRL	1.0	1000.0	1000.0	70.0	70.0
trans-1,3-Dichloropropene Ethyl methacrylate	BRL BRL	1.0	3.0	5.0		
1,1,2-Trichloroethane	BRL	1.0	3.0	5.0		3.0
Tetrachloroethene	BRL	1.0				
1,3-Dichloropropane	BRL	1.0				
2-Hexanone	BRL	1.8	60.0			10.0
Dibromochloromethane 1,2-Dibromoethane (EDB)	8.5 BRL	1.0	60.0		10.0	9.0
Chlorobenzene	BRL	1.0	100.0	100.0		100.0
1,1,1,2-Tetrachloroethane	BRL	1.0				70.0
Ethylbenzene	BRL	1.0	700.0	700.0	40.0	40.0
m/p-Xylene o-Xylene	BRL BRL	1.0	10000.0	10000.0	300.0 300.0	300.0
Styrene	BRL	1.0	100.0	10000.0	300.0	300.0
Bromoform	1.1	1.0	0.0			
Isopropylbenzene (cumene)	BRL	1.0				300.0
Bromobenzene 1.1.2.2 Totrachloroothano	BRL	1.0				
1,1,2,2-Tetrachloroethane trans-1,4-Dichloro-2-butene	BRL BRL	1.0	1.0			
1,2,3-Trichloropropane (TCP)	BRL	1.0	0.005		7.0	7.0
n-Propylbenzene	BRL	1.0				
2-Chlorotoluene	BRL	1.0				
1,3,5-Trimethylbenzene 4-Chlorotoluene	BRL BRL	1.0			30.0	30.0
4-Chlorotoluene Pentachloroethane	BRL	1.0				
tert-Butylbenzene	BRL	1.0				
1,2,4-Trimethylbenzene	BRL	1.0			30.0	30.0
1-Methylpropylbenzene (sec-butylbenzene)	BRL	1.0				
1,3-Dichlorobenzene 4-Isopropyltoluene (p-cymene)	BRL BRL	1.0				
1,4-Dichlorobenzene	BRL	1.0			50.0	50.0
n-Butylbenzene	BRL	1.0				
1,2-Dichlorobenzene	BRL	1.0				600.0
Hexachloroethane	BRL	1.0				
1,2-Dibromo-3-chloropropane (DBCP) Nitrobenzene	BRL BRL	1.0	0.0	0.2		
1,2,4-Trichlorobenzene	BRL	1.0	70.0	70.0	100.0	100.0
Hexachloro-1,3-butadiene	BRL	1.0				
Naphthalene	BRL	1.0			70.0	70.0
1,2,3-Trichlorobenzene	BRL BRL	1.0				
Total Trihalomethanes	78.2	1.0		80.0		

Reporting Limit = The smallest concentration (in ppb) we can report based on our calibration curve
BRL = Value detected is below the reporting limit
EPA MCLG = The EPA and HI DOH Maximum Contaminant Level Goal, or the California MCL
EPA MCL = The EPA and HI DOH regulatory Maximum Contaminant Level (legal limit)
Short-term = Short-term exposure health limit denoted by MN Dept. of Health
Chronic = Long-term exposure health limit denoted by MN Dept. of Health
Colors: RED is above EPA MCL, YELLOW is detectable above chronic health limit or EPA MCLG, ORANGE is above Short-term limit, GREEN is below all limits
Created on 2023-10-27 by CKS. Questions? email: infowrrc@hawaii.edu