Peak - All Units in (ppb)	10-25-24-KDP-08	Reporting_Limit	EPA MCLG	EPA MCL	MN Short-term	MN Chronic
Chloromethane (methyl chloride) Chloroethene (vinyl chloride)	BRL BRL	1.0	0.0	2.0		10.0
Bromomethane (methyl bromide)	BRL	1.0				10.0
Chloroethane (ethyl chloride) Trichlorofluoromethane	BRL BRL	1.0	150.0			2000.0
Diethyl ether	BRL	1.0	150.0			2000.0
1,1-Dichloroethene	BRL	1.0				
Acetone lodomethane	3.6 BRL	2.0			9000.0	4000.0
Carbon disulfide	BRL	1.0				700.0
3-Chloropropene (allyl chloride)	BRL	1.0				30.0
Methylene chloride (DCM)	BRL	1.0	100.0	100.0		0.0
trans-1,2-Dichloroethene Methyl tert-butyl ether (MTBE)	BRL BRL	1.0	100.0	100.0	700.0	9.0
1,1-Dichloroethane	BRL	1.0	0.0	5.0	400.0	80.0
2,2-Dichloropropane	BRL	1.0	7.0	7.0	20.0	6.0
cis-1,2-Dichloroethene 2-Butanone (MEK)	BRL BRL	1.0	7.0	7.0	20.0	6.0 4000.0
Methyl acrylate	BRL	2.0				
Methacrylonitrile	BRL	2.0				
Bromochloromethane Tetrahydrofuran	BRL BRL	1.0			600.0	600.0
Trichloromethane (chloroform)	BRL	1.0	70.0		20.0	20.0
1,1,1-Trichloroethane	BRL	1.0	200.0	200.0		5000.0
1-Chlorobutane (butyl chloride) Carbon tetrachloride	BRL BRL	1.0	0.0	5.0	3.0	3.0
1,1-Dichloropropene	BRL	1.0		5.0	5.0	5.0
Benzene	BRL	0.5	0.0	5.0	10.0	3.0
1,2-Dichloroethane Trichloroethene	BRL BRL	1.0	0.0	5.0	200.0	60.0
1,2-Dichloropropane	BRL	1.0	0.0	5.0	20.0	20.0
Dibromomethane	BRL	1.0				
Methyl methacrylate Bromodichloromethane	BRL BRL	1.0	0.0		30.0	30.0
2-Nitropropane	BRL	5.0	0.0		30.0	30.0
cis-1,3-Dichloropropene	BRL	1.0				
4-Methyl-2-pentanone (MIBK) Toluene	BRL BRL	2.0	1000.0	1000.0	70.0	70.0
trans-1,3-Dichloropropene	BRL	1.0	3.0	5.0	70.0	70.0
Ethyl methacrylate	BRL	1.0				
1,1,2-Trichloroethane	BRL	1.0	3.0	5.0		3.0
Tetrachloroethene 1,3-Dichloropropane	BRL BRL	1.0				
2-Hexanone	BRL	2.0				
Dibromochloromethane	1.3	1.0	60.0		10.0	10.0
1,2-Dibromoethane (EDB) Chlorobenzene	BRL BRL	1.0	100.0	100.0	10.0	9.0
1,1,1,2-Tetrachloroethane	BRL	1.0				70.0
Ethylbenzene	BRL	0.5	700.0	700.0	40.0	40.0
m/p-Xylene o-Xylene	BRL BRL	1.0 0.5	10000.0	10000.0	300.0	300.0
Styrene	BRL	0.5	100.0	100.0		
Bromoform	5.7	1.0	0.0			
Isopropylbenzene (cumene) Bromobenzene	BRL BRL	1.0				300.0
1,1,2,2-Tetrachloroethane	BRL	1.0	1.0			
1,2,3-Trichloropropane (TCP)	BRL	1.0	0.005		7.0	7.0
trans-1,4-Dichloro-2-butene n-Propylbenzene	BRL BRL	1.0				
2-Chlorotoluene	BRL	1.0				
1,3,5-Trimethylbenzene	BRL	1.0			30.0	30.0
4-Chlorotoluene tert-Butylbenzene	BRL BRL	1.0				
Pentachloroethane	BRL	1.0				
1,2,4-Trimethylbenzene	BRL	1.0			30.0	30.0
1-Methylpropylbenzene (sec-butylbenzene) 1,3-Dichlorobenzene	BRL BRL	1.0				
4-Isopropyltoluene (p-cymene)	BRL	1.0				
1,4-Dichlorobenzene	BRL	1.0			50.0	50.0
n-Butylbenzene	BRL	1.0				C00.0
1,2-Dichlorobenzene Hexachloroethane	BRL BRL	1.0				600.0
1,2-Dibromo-3-chloropropane (DBCP)	BRL	1.0	0.0	0.2		
Nitrobenzene	BRL	5.0				
1,2,4-Trichlorobenzene Hexachloro-1,3-butadiene	BRL BRL	1.0	70.0	70.0	100.0	100.0
Naphthalene	BRL	0.5			70.0	70.0
1,2,3-Trichlorobenzene	BRL	1.0				
Total Trihalomethanes	7.2	1.0		80.0		

Reporting Limit = The smallest concentration (in ppb) we can report based on our calibration curve

BRL = Value detected is below the reporting limit

EPA MCLG = The EPA and HI DOH Maximum Contaminant Level Goal, or the California MCL

EPA MCL = The EPA and HI DOH regulatory Maximum Contaminant Level (legal limit)

Short-term = Short-term exposure health limit denoted by MN Dept. of Health

Chronic = Long-term exposure health limit denoted by MN Dept. of Health

Colors: RED is above EPA MCL, YELLOW is detectable above chronic health limit or EPA MCLG, ORANGE is above Short-term limit, GREEN is below all limits

Created on 2024-12-13 by CKS. Questions? email: infowrrc@hawaii.edu